



**West Bengal State Electricity Distribution Company Limited
(A Government of West Bengal Enterprise)**

Office of the Chief Engineer : Procurement & Contracts

Vidyut Bhavan (4th Floor) : Bidhannagar : Block-DJ, Sector-II,

Kolkata-700 091 ,Phone No. 033-2359-8397 :: Fax No. 033-2359-1921

CIN-U40109WB2007SGC113473/Website-www.wbsedcl.in/email-procurementdept@wbsedcl.in

Memo. No: P&C/P-60/25-26/PC-II/Addl.Emp/DTR/98

Dated: 29.09.2026

List of Empanelled/Provisionally Empanelled Bidders against additional empanelment i.r.o. 11/0.433KV 25KVA, 63KVA, 100KVA, 160KVA, 250KVA & 315KVA Energy Efficiency Level- 2 (as per amendment no. 4 of IS:1180 (Part-1)) Distribution Transformer


Ref: i) NIT No. P-49/2023-24/PC-II/DTR opened on 18.01.2024 (Extended) & subsequent order vide memo No.- P&C/PC-II/DTR/61 dated 07.06.2024.
ii) P-60/25-26/PC-II/Addl. Emp/DTR opened on 06.04.2026 (extended).

In addition to the bidders empanelled against tender No. P-49/2023-24/PC-II/DTR opened on 18.01.2024 (Extended) i.r.o. 11/0.433KV 25KVA, 63KVA, 100KVA, 160KVA, 250KVA & 315KVA Energy Efficiency Level- 2 (as per amendment no. 4 of IS:1180 (Part-1)) Distribution Transformer vide memo no.- P&C/PC-II/DTR/61 dated 07.06.2024, the following bidders with the following factory addresses have been Empanelled/ Provisionally Empanelled against NIT No. P-60/25-26/PC-II/Addl. Emp/DTR opened on 06.04.2026 (extended) for the Energy Efficiency Level-2 (As per Amendment no. 4 of IS:1180(Part-1)) DTR rating as mentioned below and the empanelment will remain valid for at least upto 07.06.2027, with effect from the date of issuance of this order with a provision for further extension of maximum one year subject to approval of the competent authority:

Sl. No.	Name of the Bidder	Empanelled/Provisionally Empanelled for Energy Efficiency Level-2 (As per Amendment no. 4 of IS:1180(Part-1)) DTR of Rating.	Details of BIS certificate possessed by the bidder	Type & Special Tests to be Conducted after placement of Purchase Order in the subsequent limited tender for the 1 st time after Empanelment as per relevant clauses of NIT & Minutes of Pre-bid Meeting
1.	M/s. MEI Power Private Limited Factory Address: Mathura Road, Artoni Agra-282 007	Empanelled for 11/0.433KV 25KVA, 63KVA, 100KVA & 160KVA DTR	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 200KVA DTR and above 200 KVA up to and including 1000 KVA DTR	For 11/0.433KV 25KVA, 63KVA, 100KVA & 160KVA EEL-2 DTR: Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H,1Kg Pressure) as per ASTM:A194/IS:101 Part5, Sec-I 1988 RS 2014.
2.	M/s RTS Power Corporation Ltd. Factory Address: Jaladhulagori, Begri Road, Howrah-711302	Empanelled for 11/0.433KV 63KVA & 100KVA DTR	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) up to and including 200KVA DTR and above 200 kVA up to and including 630 kVA DTR	For 11/0.433KV 63KVA & 100KVA EEL-2 DTR: Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H,1Kg Pressure) as per ASTM:A194/IS:101 Part5, Sec-I 1988 RS 2014.
3.	M/S. Tacent Industries Private Limited Factory Address: Killa No 68/8/5, Khewat No. 561 Bagru, Khata No-716, Sonipat Haryana-131022.	Provisionally Empanelled for 11/0.433KV 63KVA & 100KVA DTR subject to submission of proof against safety enclosures integrated with interlocking arrangement.	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 25kVA, 63kVA and 100kVA DTR	For 11/0.433KV 63KVA & 100KVA EEL-2 DTR: Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H,1Kg Pressure) as per ASTM:A194/IS:101 Part5, Sec-I 1988 RS 2014.

Sl. No.	Name of the Bidder	Empanelled/Provisionally Empanelled for Energy Efficiency Level-2 (As per Amendment no. 4 of IS:1180(Part-1)) DTR of Rating.	Details of BIS certificate possessed by the bidder	Type & Special Tests to be Conducted after placement of Purchase Order in the subsequent limited tender for the 1 st time after Empanelment as per relevant clauses of NIT & Minutes of Pre-bid Meeting
4.	M/s. Raksan Transformers Private Limited <u>Factory Address:</u> Plot No. 1675, 76 & 77, Industrial Estate, HSIIDC, Rai Sonipat Haryana-131029	Provisionally Empanelled for 11/0.433KV 25KVA, 63KVA, 100KVA, 160KVA, 250KVA & 315KVA DTR subject to submission of proof against safety enclosures integrated with interlocking arrangement.	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 25KVA, 63KVA, 100KVA, 160KVA & 200KVA DTR & Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 250KVA, 315KVA, 400KVA, 630KVA, 1000KVA & 2500KVA DTR.	<u>For 11/0.433KV 25KVA, 63KVA, 100KVA, 160KVA, 250KVA & 315KVA EEL-2 DTR:</u> Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H, 1Kg Pressure) as per ASTM: A194/IS:101 Part5, Sec-I 1988 RS 2014.
5.	M/S. Truvolt Engineering Co. Pvt. Ltd. <u>Factory Address:</u> Vill & PO: Rasapunja Bakrahat Road, Dist:-24 Paraganas(South) Kolkata-700104	Provisionally Empanelled for 11/0.433KV 25KVA, 63KVA, 100KVA & 160KVA DTR subject to submission of Fire License.	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) up to and including 200KVA DTR.	<u>For 11/0.433KV 25KVA, 63KVA, 100KVA & 160KVA EEL-2 DTR:</u> Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H, 1Kg Pressure) as per ASTM: A194/IS:101 Part5, Sec-I 1988 RS 2014.
6.	M/s Green Power Transmission Private Limited <u>Factory Address:</u> Sitalpur Kamalpur P.O.-Bidupur Bazar Dist- Vaishali Bihar-844503	Provisionally Empanelled for 11/0.433KV 25KVA & 63KVA DTR subject to submission of valid Fire License.	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 63KVA, 100KVA up to and including 200KVA DTR.	<u>For 11/0.433KV 25KVA & 63KVA EEL-2 DTR:</u> Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H, 1Kg Pressure) as per ASTM: A194/IS:101 Part5, Sec-I 1988 RS 2014.
7.	M/s. Pachal Transformers Pvt. Ltd. <u>Factory Address:</u> Kantalia, Nibra, P.O.-Domjur Howrah, West Bengal -711409	Provisionally Empanelled for 11/0.433KV 250KVA & 315KVA DTR subject to submission of Fire License.	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 250KVA, 315KVA, 400KVA, 500KVA DTR.	<u>For 11/0.433KV 250KVA & 315KVA EEL-2 DTR:</u> Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H, 1Kg Pressure) as per ASTM: A194/IS:101 Part5, Sec-I 1988 RS 2014.
8.	M/s. H-Bus Equipment Manufacturing Company <u>Factory Address:</u> Industrial Growth Centre, Mornoi Matia Goalpara, Assam-783101	Provisionally Empanelled for 11/0.433KV 25KVA, 63KVA & 100KVA DTR subject to submission of valid Fire License.	Energy efficiency level-2 (as per Amendment no. 4 of IS:1180 (Part-1)) 25KVA, 63KVA, 100KVA, 160KVA & 200KVA DTR.	<u>For 11/0.433KV 25KVA, 63KVA & 100KVA EEL-2 DTR:</u> Lightning Impulse Test (The wave shape shall be chopped on tail), Dynamic Short Circuit Withstand Test, Temperature Rise Test, Pressure Test, Vacuum Test along with Salt Spray Test as per ASTM B117:2019 (Duration-100 Hrs) & Scratch Hardness Test (Grade-2H, 1Kg Pressure) as per ASTM: A194/IS:101 Part5, Sec-I 1988 RS 2014.

N.B. :- For any procurement process other than P&C Department of WBSEDCL i.r.o. any particular rating of DTR, bidders have to submit the Energy Efficiency Level-2 (As per Amendment no. 4 of IS:1180(Part-1)) Type Test Reports as mentioned in the above table as per exact WBSEDCL Technical Specification before placement of any order. The bidders (under sl. no.3,4,5,6,7 & 8) who are presently Empanelled under provisional category will be converted to Empanelled category subject to fulfilling the specified condition as mentioned above.


 Chief Engineer
 Procurement & Contracts Department