

West Bengal State Electricity Distribution Company Limited
(A Government of West Bengal Enterprise)

(IT & Communication Cell)

Vidyut Bhavan, 3rd Floor, C&D Block, Bidhan Nagar, Block-DJ, Sec-II, Kolkata-700091

Phone No.033-2358-9665, FAX No.033-2337-2427, 033-2358-9244

Website: www.wbsedcl.in, e-mail: itcell@wbsedcl.in

CIN: U40109WB2007SGC113473

Memo no.: WBSEDCL/IT&C/33.10(i)/ 211

Date: 10.07.2024

NOTICE

Sub: Amendment/ Corrigendum Notice against Tender No: WBSEDCL/IT&C/33.10(i)/405 Dated: 10.06.2024.

Following amendments has been made to the tender document: -

Sl	Clause No.	Page No.	Existing Clause	Amended/ Modified clause
1.	Instruction to Bidders (IB).	Page-12, of the NIT	Copy of Balance Sheet and Profit & Loss Statement duly certified by Chartered Accountant or published Audited Annual Reports for Fiscal Year 2021-22, 2020-21, 2019-20. Minimum Average Annual Turnover for in each of the above fiscal years must be at least INR 300 (three hundred) Crore.	Copy of Balance Sheet and Profit & Loss Statement duly certified by Chartered Accountant or published Audited Annual Reports for Fiscal Year 2020-2021, 2021-2022, 2022-23. Minimum Average Annual Turnover for in each of the above fiscal years must be at least INR 2.5 Crore.
2	Scope of Work, SW9	Page-23, of the NIT	VENDOR shall provide one dedicated manpower at DC and DRC in 7 x 24x365 mode i.e one dedicated manpower shall sit at DC and same at DRC in 7x24x365 mode and he/she will perform monitoring of all non-IT equipment of DC and DRC as mentioned in Annexure V. He/she shall have sufficient knowledge of the non-IT equipment of Data Centre and should have the expertise for titbit maintenance work of non-IT equipment of Data Centre during any occurrence of any fault at DC and DRC. He/she should be responsible for docketing any call during the breakdown of any equipment under this scope of work. He/she should be responsible for providing any type of MIS reports for this maintenance activity. He/ She should have at least a diploma in electrical engineering. Proof of his/her educational qualification/CV needs to be submitted.	VENDOR shall provide one dedicated manpower at DC and DRC in 7 x 24x365 mode i.e one dedicated manpower shall sit at DC and same at DRC in 7x24x365 mode and he/she will perform monitoring of all non-IT equipment of DC and DRC as mentioned in Annexure V. He/she shall have sufficient knowledge of the non-IT equipment of Data Centre and should have the expertise for titbit maintenance work of non-IT equipment of Data Centre during any occurrence of any fault at DC and DRC. He/she should be responsible for docketing any call during the breakdown of any equipment under this scope of work. He/she should be responsible for providing any type of MIS reports for this maintenance activity. He/ She should have at least a diploma in Electrical/Electronics engineering or equivalent with at least 3 years relevant experience of working in Data Centre/ DR Centre. Proof of his/her educational qualification/ Experience /CV needs to be submitted.

3	Scope of Work, SW10	23	Project manager should be at least B.TECH/ BE in electrical engineering having 5years of relevant experience of maintaining Data Centre.	Project manager should be at least B.TECH/ BE in Electrical/ Electronics Engineering or equivalent having 5 years of relevant experience of maintaining Data Centre/ DR Centre.
3	Annexure - XV	Page-58, of the NIT	<p>DC: Diesel Generator of 625 KVA, Make:- Jackson, Engine:- Cummins, Model:- CJ625D5P</p> <p>DRC: Diesel Generator of 625 KVA, Make:- Jackson, Engine:- Cummins, Model:- CJ625D5P</p>	<p>DC : Diesel Generator of 625 KVA, Make:- Jackson, Engine:- Cummins, Model:- CJ625D5P</p> <p>SET 1: GENSET SL NO: CJS-10110230 ENGINE SL NO :25358048 ALTERNATOR SL NO: N10H15354</p> <p>SET 2: GENSET SL NO: CJS-10110229 ENGINE SL NO :25357474 ALTERNATOR SL NO: N10G13238</p> <p>DRC : Diesel Generator of 625 KVA, Make:- Jackson, Engine:- Cummins, Model:- CJ625D5P</p> <p>SET 1: GENSET SL NO: CJS-10110234 ENGINE SL NO :25359362 ALTERNATOR SL NO: N10I16712</p> <p>SET 2: GENSET SL NO: CJS-10110235 ENGINE SL NO :25358250 ALTERNATOR SL NO: N10I16446</p>
4	BOQ	BOQ	<p>DC: Precision Air Conditioning (PAC) Units of Libert PeX Model</p> <p>Quantity : 12</p>	<p>DC: Precision Air Conditioning (PAC) Units of Libert PeX Model</p> <p>Revised Quantity : 06</p>

Some queries received from the vendors. The committee discussed the queries and after threadbare discussion the following clarification has been given:

Bidder Name	NIT Clause No.	NIT Page No.	Clause Details as per NIT	Query/Clarification/ Suggestion	WBSEDCL's Remarks
Planet Infrastructure Management	Section - 1; Instruction to Bidders (IB).	12	Copy of Balance Sheet and Profit & Loss Statement duly certified by Chartered	Please clarify the "Minimum Average Annual Turnover" value	Typo error. Please refer the


LTD.			submitted through online mode in e-tender website. Bid guarantee may also be submitted through Bank Guarantee (BG).	MSME firm/company	
	GTC.9.1	19	Performance Bank Guarantee: successful bidder shall furnish a Performance Guarantee in the form of unconditioned & irrevocable Bank Guarantee amounting to 10% of the total awarded contract price	Kindly allow Bank Guarantee amounting to 3% of the total awarded contract price	As per RFP
	GTC.10.1	19	Additional Performance Bank Guarantee An additional performance guarantees equivalent to 10% of the tendered amount has to be submitted by successful bidder if the bid is in the range of -20% to - 80% of the estimated rate.	Kindly allow additional performance guarantees equivalent to 5% on the difference amount of the capping value and the quoted rates.	As per RFP
	GTC.13.3	20	Terms of payment: The CAMC charges shall be paid by WBSedcl on quarterly basis at the end of each three-monthly periods from the date of start of CMAC Service. The payments will be made after deducting LD/penalties if any, based on the SLA and other reports	Payment Within 30 days after submission of the Invoice	As per RFP
	SW.13.7	27	BATTERIES FOR 10 KVA Qty 4 nos.	Kindly confirm the replace of batteries during the contract period is in Bidder scope also provide the capacity and quantity of batteries installed with each UPS	34 Nos of 42AH batteries of 12V in the Battery Bank. The replacement is under the scope of Bidder

Pvt. Ltd.	IB.11.2 Technical Proposal IB.11.2.15		Accountant or published Audited Annual Reports for Fiscal Year 2021-22, 2020-21, 2019-20. Minimum Average Annual Turnover for in each of the above fiscal years must be at least INR 300 (three hundred) Crore.	required for the three consecutive financial years as two different values are mentioned in the NIT. The specified years are also different in the mentioned two clauses. So, kindly clarify the required financial years of the Audited Annual reports.	corrigendum.
	Annexure - II Mandatory Condition	33	Annual Turn Over for each of last three consecutive financial years i.e 2020-2021, 2021-2022, 2022-23 must be at least 2.5 Crore. Net worth of each of the above years has to be positive.		
Nirvaa Solutions Pvt Ltd	Technical Proposal & Mandatory Condition	12 & 33	On page no 12, clause no IB.11.2.15. it is stated that, Minimum Average Annual Turnover for in each of the above fiscal years must be at least INR 300 (three hundred) Crore. & On page no 33, Sr.No.1, it is stated that, Annual Turn Over for each of last three consecutive financial years i.e. 2020-2021, 2021-2022, 2022-23 must be at least 2.5 Crore.	Request to confirm exactly which value should be considered for Average Annual Turnover for eligibility.	Typo error. Please refer the corrigendum.
	Mandatory Condition	34	On page no 34, Sr.No.9, it is stated that, The bidder shall have a site office in Kolkata and having operations in India for the last five years: A documentary proof with complete address details and contact person details and Certificate of Incorporation.	Request to confirm, it the bidder is registered/located outside West Bengal and has its branch office in West Bengal, then Trade license will be considered for same?	Bidder should have a branch office/ site office in Kolkata. As per RFP.
	Earnest Money	8	Clause No: IB.11.1.4, Point No 2,2. A bid guarantee of INR 7,00,000/- (Rupees Seven Lakh only) shall be submitted through online mode in e-tender website. Bid guarantee may also be submitted through Bank Guarantee (BG).	Request you to confirm if there is any EMD exemption for MSME Bidders. It can help for wider bid participation.	As per RFP.
		1	Period (2+1 year)	Need to clarify	As per RFP
MAXX Systems Pvt.	IB.11.1.4	8	INR 7,00,000/- (Rupees Seven Lakh only) shall be	Kindly allow Exemption to deposit EMD for	As per RFP

MAXX Systems Pvt. LTD.	SW.15.13	29	BMS devices like CCTV, DC/DRC Biometric, Desigo systems etc. also are significantly old and completely obsoleted. Some of them are EOL/EOS products. In case of any fault, the replacement must be made through a similar or upgraded compatible device to ensure functionality of the overall system. In case any of the above-mentioned equipment are non-repeatable or not available in market or become end of support, the entire system needs to be changed / replaced by the bidder to ensure functionality of the overall system.	Kindly add replacement of BMS in BOQ	As per RFP
		Page 34, Point No 7	A). Project manager needs to have educational qualification of B.Tech in Electrical with relevant experience of handling Data Centre for minimum 05 years. Experience certificate to be attached. Project Manager should be available at site as an when required by WBSedCL. B). Shift engineers needs to have minimum educational qualification of Diploma in Electrical C) If required, WBSedCL may take interview of the Project Manager/ Shift Engineer	A). Kindly consider Project manager needs to have educational qualification of B.Tech in Electrical/ Mechanical/ Electronic with relevant experience of handling Data Centre for minimum 03 years. B). Shift engineers need to have minimum educational qualification of ITI/Diploma in Electrical C) Bidder is fully responsible for smooth running of data centre so it is the bidder responsibly to appoint responsible and qualified Project Manager/ Shift Engineer	Please see the amendment/ corrigendum.
	ANNEXUREIII	Page No. 40	Manufacture's Authorization Form (MAF)	100% inclusion (No exclusion) is allowed in back- to-back agreement with the OEM	As per RFP
Vertiv Pvt Ltd.				For 10kVA UPS systems, two different makes are mentioned (ABB and Emerson) in two placed, need clarity on the	Emerson Make 10 KVA UPS

				same.	
				Details of Batteries of 10 KVA UPS are not mentioned, scope of work also does not clarify whether the replacement will be in bidder's scope or not.	34 Nos of 42AH batteries of 12V in the Battery Bank. The replacement is under the scope of Bidder
				<p>We need proper health assessment of all Emerson / Vertiv make equipment like UPS with Batteries, PAC, ATS etc. before entering into support agreement.</p> <p>In order to ensure proper assessment of pour equipment, one day site visit at each location is required, kindly allow the same.</p>	On approval of competent authority of WBSEDCL

All other terms and conditions of the existing tender will remain unchanged.


M K Das
Chief Engineer, IT&C Cell
WBSEDCL