



West Bengal State Electricity Distribution Company Ltd.

(A Government of West Bengal Enterprise)

Office of the Project Site-In-Charge
PURULIA PUMPED STORAGE PROJECT

Telephone: 03252-250201

E-Mail : ppsp.site@wbasedcl.in

Bagmundi

Purulia-723152

NOTICE INVITING TENDER

NIT NO.: WBSEDCL / PPSP Site / IPH/ Proc./ Tender/ 24-25/ 06/ 416 Dated: 05.08.2024

- 1) West Bengal State Electricity Distribution Company Ltd. (WBSEDCL) invites sealed quotation from reputed vendors for the supply & delivery of **2 Feet LED Batten Light, 33 KV Electrical Insulating Mat and System Sensor Conventional Fire Alarm Control Panel** as per the specification mentioned in Annexure-I for Purulia Pumped Storage Project Site. The sealed cover shall be super scribed with "NIT No" Name & Date of the Tender and "Date & Time of opening of the Tender". The sealed cover shall also bear the name and address of the tenderers.
- 2) Scope of Work: Supply and delivery of **2 Feet LED Batten Light, 33 KV Electrical Insulating Mat and System Sensor Conventional Fire Alarm Control Panel** as per the specification mentioned in Annexure-I at Purulia Pumped Storage Project Site, Bagmundi, Purulia within the stipulated time period.
- 3) Quantity required: **As mentioned in Annexure – I.**
- 4) The Bidder shall submit offer duly signed and filled in their Letter head super scribing the NIT no. The bidder may submit their Offer by post or by dropping their Offer in tender Box at **The Office of the Addl. CE & Project Site In-Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia, West Bengal-723152.**
- 5) Place and time of Submission of offer: The sealed offer will be received at the Office of The Addl. CE & Project Site In-Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Dist.: Purulia, West Bengal, PIN: 723152 during office hours on all working days except Sunday and Holidays.
- 6) End time of Submission of Offer: Up to 11:30 hrs. Dated 05.09.2024.
- 7) Place, Date & Time for opening of Offer:
The Office of The Addl. CE & Project Site In-Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia West Bengal on 05.09.2024 at 12:00 Hrs.
- 8) Estimated Cost: Rs. 90, 000/- (Rs. Ninety Eight Thousand) only excluding GST (Approx.).
- 9) Availability of Tender Document:
 - a. WBSEDCL official website: www.wbasedcl.in
 - b. Office of the Chief Engineer & Project Manager, PPSP HQ, WBSEDCL, Vidyut Bhavan, Salt Lake City, Kolkata, West Bengal, PIN: 700091

Registered Office : "VidyutBhavan", Bidhannagar, Block – DJ, Sector – II, Kolkata – 700 091

Telephones : 033 2359 1930 to 1940, Fax : 033 2359 1954

CIN: U40109WB2007SGC113473, Web: www.wbasedcl.in

WBSEDCL



c. Office of the Addl. Chief Engineer & Project Site-in-Charge, PPSP Site, WBSEDCL, Bagmundi, Dist.: Purulia, West Bengal, PIN: 723152.

10) Contact Person, if any clarification is needed: Mr. M Biswal, Superintending Engineer (Electrical), IPH, PPSP Site (E-mail ID: manoranjana.biswal@wbasedcl.in).

Offers will be opened in presence of available Bidder or their authorized representative.

Terms and Conditions:

1. **Delivery Period:** Within 60 Days from placement of order.
2. **Place of delivery:** The materials will be delivered at PPSP Site Store, WBSEDCL, Bagmundi, Purulia.
3. **Price:** Price should be firm inclusive of all incidental charges. GST should be mentioned separately as applicable.
4. **Payment:** 100% Payment will be made after successful delivery of materials, drawal of Store Receipt Voucher from this end and on submission of original bill in GST Tax Invoice in triplicate with advanced pre-receipt (Duly signed on Revenue Stamp), Guarantee/Warranty Certificate & challan which are to be submitted at the time of delivery of materials. Payment will be made by RTGS/NEFT whose charge shall be borne by the agency.
5. **Transit Insurance:** In the scope of the supplier.
6. **FOR:** Purulia Pumped Storage Project Site, Bagmundi, District: Purulia, PIN: 723152.
7. **Packing & Forwarding:** The materials should be duly packed taking all reasonable precautions to protect the materials against damage and loss during transit. The bidder will bear total responsibility against any losses & damages during transit.
8. **Penalty:** Penalty for delay in delivery @1/2 % (half percent) of the order value for each week delay or part thereof upto ten (10) weeks and @1% of the order value per week or part thereof beyond ten (10) weeks subject to maximum limit of 10% (Ten percent) of the order value will be deducted from the agency.
9. **Guarantee:** Original manufacturer/ Supplier's Guarantee/warranty is to be provided for a minimum period of 12 months from the date of successful delivery of the materials. In case the supply materials are beyond our specification or found defective/damage /broken within the guaranty/ warranty period, the same should be replaced by the agency at their own risk, cost and responsibility within 15 days of intimation.
10. **Freight:** It will be borne by the agency.

Registered Office : "VidyutBhavan", Bidhannagar, Block – DJ, Sector – II, Kolkata – 700 091

Telephones : 033 2359 1930 to 1940, Fax : 033 2359 1954

CIN: U40109WB2007SGC113473, Web: www.wbasedcl.in

WBSEDCL



11. **Vendor Details:** PAN/GSTIN no. & bank NEFT/RTGS details are to be provided for vendor approval along with a cancelled cheque.
12. **Validity:** The offer must remain valid for 60 days from the date of opening of the tender.
13. **Rejection:** WBSEDCL reserves the right to reject any or all offer at its own discretion without assigning any reasons whatsoever and do not bind itself to accept the lowest tender.
14. **Risk Purchase Clause:** Risk Purchase Clause will be applicable as per norms of WBSEDCL.
15. **Site Visit for Sample Inspection:** Authorized representatives of interested agencies can view the sample of items physically at PPSP Site, Baghmundi if required. Necessary transportation, accommodation etc for site visit has to be arranged by the agency at their own cost, risk and responsibility.
16. **Evaluation :** Evaluation of the tender will be done item wise.
17. **Non Compliance:** In case of non-compliance of the order by the L1 bidder, necessary action will be taken as per norms of WBSEDCL. It may also lead to Holiday Listing of L1 bidder.

Note:

- * Any Offer submitted after the expiry of the time prescribed for submission or Incomplete in any respect shall be rejected. Late receipt of Offer in case of postal delivery will not be considered. Offer by FAX/E-mail will not be accepted.
- * Overwriting is not allowed.
- * Quantity may be increase or decrease subject to limit of 10% at the discretion of WBSEDCL.


05.03.24

(S.K. Mondal)

Addl. CE & PSIC, PPSP Site



Annexure – I

NIT NO.: WBSEDCL / PPSP Site / IPH/ Proc./ Tender/ 24-25/ 06/ AIG Dated: 05.08.2024

Supply and delivery of 2 Feet LED Batten Light, 33 KV Electrical Insulating Mat and System Sensor Conventional Fire Alarm Control Panel for Purulia Pumped Storage Project Site, Baghmundi, District: Purulia

Sl. No.	Description of Item	HSN Code	Qty. Req.	Unit rate (Rs.)	% of GST Applicable (Rs.)	GST per Unit (Rs.)	Price per unit including GST (Rs.)	Total Price including applicable Tax
1.	1. <u>Item</u> : LED Batten Light 2. <u>Power</u> : 9 Watt or higher 3. <u>Length</u> : 2 Feet 4. <u>Make</u> : Philips/ Havells/ Crompton/ Eveready/ Bajaj		30 Nos.					
2.	1. <u>Item</u> : 33 KV Electrical Insulating Mat 2. <u>Make</u> : Jyoti Rubber Udyog (I) Ltd 3. <u>Dimension</u> : 1 meter (Width) * 2 meter (Length) 4. <u>Thickness</u> : 3 mm 5. <u>Class</u> : C 6. <u>Category</u> : III 7. <u>Breakdown Voltage</u> : 65 KV should withstand for 1 minute 8. <u>Dielectric Strength</u> : 65 KV 9. <u>Leakage Current at 11 KV</u> : 10 mA 10. <u>Other Details</u> : The Mat should be ISI marked and conform with IS Standard: 15652		40 Sq. Meter					
3.	1. <u>Item</u> : System Sensor Conventional Fire Alarm Control Panel, 2. <u>Make</u> : Honeywell International Inc., 3. <u>Model (Ordering Part Code)</u> : SS/ 4ZEC 4. <u>Detection Circuits</u> : 4 Zones, Max 2 mA per Detector Class B Circuit 5. <u>Operating Voltage</u> : 230 VAC, 50 Hz, Alarm Load (Sounder) 0.5 Amp (Max), NAC output 0.5 Amp (Max) 6. <u>External Outputs</u> : Sounder Outputs: 18.5 to +28.0 V DC, 0.5 Amp (Max) Auxiliary Output: 18.5 to +28.0 V DC, 0.5 Amp (Max) 7. <u>Display</u> : 16 × 2 Character LCD		03 Nos.					

Signature of the Bidder with office seal and designation.

Registered Office : "VidyutBhavan", Bidhannagar, Block – DJ, Sector – II, Kolkata – 700 091
Telephones : 033 2359 1930 to 1940, Fax : 033 2359 1954
CIN: U40109WB2007SGC113473, Web: www.wbsedcl.in

WBSEDCL