



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

INVITATION OF e-TENDER FOR

**Construction of Three storied Administrative Building for North Malda Division Office And Chanchal CCC at Existing Chanchal 33/11 kV Sub-Station premises including Sanitary & plumbing works, construction of RCC approach road, Boundary wall & other ancillary civil works and electrical & LAN wiring works under North Malda Division, Dist- Malda
(2nd Call)**

N.I.T. NO.: RM/MRO/ CIVIL/ e-TENDER/ 2022-23/ 13 Dt.16.02.2023

**MALDA REGIONAL OFFICE Administrative Building (WBSEDCL), 1st Floor,
Rabindra Avenue, Malda – 732101**

E-mail: rm.malda@wbasedcl.in



CONTENTS

Section I	: Notice Inviting e-Tender
Section II	: Invitation for Bids (IFB)
Section III	: Instruction to bidders (ITB)
Section IV	: General Conditions of Contract (GCC)
Section V	: Special Conditions of Contract (SCC)
Section VI	: General Instructions
Section VII	: Technical Specifications of Contract (TSC)
Section VIII	: Special Conditions of Contract and Technical Specification for Electrical Works
Section IX	: Annexure
Section X	: Schedule of Work/B.O.Q.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section I
NOTICE INVITING e-TENDER



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

MALDA REGIONAL OFFICE

Administrative Building,
WBSEDCL 1st Floor,
Rabindra Avenue,
Malda – 742101.
E-mail: rm.malda@wbasedcl.in

Regd. Office of WBSEDCL:
VidyutBhavan,
Block-DJ, Sector – II,
Bidhannagar,
Kolkata – 700 091.
Website-www.wbasedcl.in

NOTICE INVITING e-TENDER

N.I.T. NO.: RM/MRO/ CIVIL/ e-TENDER/ 2022-23/ 13 Dt.16.02.2023

E-tender in two parts is invited from bonafide, experienced and resourceful contractors of WBSEDCL, WBSETCL, DPL, PGCIL, NTPC and other Central Government / State Government / Semi Government undertaking for the following works :-

- **Name of the work:** Construction of Three storied Administrative Building for North Malda Division Office And Chanchal CCC at Existing Chanchal 33/11 kV Sub-Station premises including Sanitary & plumbing works, construction of RCC approach road, Boundary wall & other ancillary civil works and electrical & LAN wiring works under North Malda Division, Dist- Malda (2nd Call)
- **Estimated Amount:** Rs. 1,88,82,657.51/
- **Earnest Money Deposit:** Rs. 3,77,700/-
- **Completion Time:** 420 (Four Hundred and Twenty) Days
- **Cost of Bid Documents :** NA

Intending bidders desirous of participating in the tender are to log on to the website <https://wbtenders.gov.in> for the tender. The tender can be searched by typing WBSEDCL in the search engine provided in the website. Further other details including qualifying requirements please visit www.wbasedcl.in or office notice board of the above office.

KEY DATES

1.	Date of uploading of NIT & other Documents (Publishing Date)	24.02.2023 AFTER 11:00 hrs
2.	Documents download/sell start date (online)	24.02.2023 AFTER 11:00 hrs
3.	Bid submission starting date (online)	24.02.2023 AFTER 11:00 hrs
4.	Pre Bid Meeting	27.02.2023 AFTER 15:00 hrs
5.	Document download end/Bid submission closing date (online)	17.03.2023 UP TO 15:00 hrs
6.	End Date of submission of EMD (Online)	17.03.2023 UP TO 15:00 hrs
7.	End Date of physical submission of EMD (Offline) NB-if EMD is submitted through BG	20.03.2023 UP TO 14:00 hrs
8.	Techno-commercial bid opening date	22.03.2023 AFTER 11:00 hrs
9.	Techno-commercially qualified bidders' list uploading date	To be notified later
10.	Price bid opening date	To be notified later

- If a Holiday falls on any of the schedule date then schedule date shall be considered on next working day.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section II
INVITATION OF BID



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

INVITATION OF BID

1. SCOPE OF WORK:-

Construction of Three storied Administrative Building for North Malda Division Office And Chanchal CCC at Existing Chanchal 33/11 kV Sub-Station premises including Sanitary & plumbing works, construction of RCC approach road, Boundary wall & other ancillary civil works and electrical & LAN wiring works under North Malda Division, Dist- Malda.(2nd Call)

TECHNICAL ELIGIBILITY CRITERIA OF THE BIDDER:-

The bidder must have successfully completed similar nature of works **(comprising of civil and electrical works combined)** during last seven years (date of completion of work should be on or after 15.02.2016) subject to fulfillment of the following criteria:

- a) **Three similar completed works (each of the contracts comprising of civil and electrical works combined) of executed value not less than the amount equal to 40 % of the estimated cost i.e. Rs.75,53,063.00/- (minimum G+1 Storied Building)**
Or
- b) **Two similar completed works (each of the contracts comprising of civil and electrical works combined) of executed value not less than the amount equal to 50 % of the estimated cost i.e. Rs.94,41,328.76/- (minimum G+1 Storied Building)**
Or
- c) **One similar completed work (comprising of civil and electrical works combined) of executed value not less than the amount equal to 80 % of the estimated cost i.e. Rs. 1,51,06,126.01/- (minimum G+1 Storied Building)**

N.B.-Completion Certificates indicating Name of the Work, Ordered Amount, Executed Amount, Date of commencement and completion of the work and detail communicational address along with contact number of the Client should be submitted by the Bidder. Completion Certificate from the concerned Executive Engineer/District Engineer/Divisional Engineer/Assistant Engineer or equivalent rank and above will be treated as valid credential. Also uploading of copy of work order and schedule of work as supporting documents of completion certificate is mandatory.

2. COMMERCIAL ELIGIBILITY CRITERIA OF THE BIDDER:-

- a) Average annual turnover during last three financial years (i.e. 2019-20, 2021-21 and 2021-22) shall not be less than 30% of the estimated cost.
- b) Working capital in the year, preceding the year of bid submission shall not be less than 30% of the estimated cost.
- c) In case documents certifying credit facility (**Refer Annexure VI**) from a scheduled Bank is submitted, the requirement given in clause no (b) shall be judged by adding available credit facility and working capital taken together.
- d) Annual audited Financial Report for last three financial years to be submitted for verification in respect of bidders for whom audit of account is mandatory. For those whose audit of accounts is not mandatory they shall submit copy of IT returns along with related enclosures (**Form3CA/3CB and particulars are reported in the Form 3CD u/s 44AB of Income Tax Act'1961**) for last five financial years (ie. 2017-18, 2018-19, 2019-20, 2020-21 and 2021-22).

Necessary documentary evidence as detailed herein above shall have to be uploaded by the bidder to ascertain the commercial eligibility criteria.

3. OTHER STATUTORY REQUIREMENTS :-

The Bidder shall furnish the following documents-

- (i) EPF Registration Certificate and Challan for the month of December 2022 or onwards.
- (ii) I.T Return for last three financial years (ie 2019-20, 2020-21 & 2021-22) & PAN Card.
- (iii) GST Registration No. Certificate.
- (iv) Professional Tax Paid Certificate for the year 2022-23
- (v) ESI Registration Certificate and Challan for the month of December 2022 or onwards.
- (vi) Trade License in respect of the prospective Bidder, Proprietorship Firm (Valid Trade License), Partnership Firm (Partnership Deed, Valid Trade License, Power of Attorney), Ltd Company (Incorporation certificate i.e. MOA and AOA, Valid Trade License, Power of Attorney), Co-operative Society (Society Registration Copy, Valid Trade License, Power of Attorney).



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

NB: Any MOU/Temporary arrangement to constitute an Entity having no statutory Registration Certificates (Non Permanent Establishment) beyond the above entities mentioned in 3(vi) for the purpose of applying as prospective bidder will not be considered as valid document.

(vii) Copy of Electrical Contractor's License with validity in the name of bidder.

(viii) Attested copy of Electrical Supervisor's Certificate (with necessary parts) of competency issued by the Licensing

Board, Government of West Bengal/India (Current engagement of Electrical Supervisor at prospective bidder's firm needs to be established through notary attested contract agreement on Non-Judicial Stamp Paper).

(ix) Information regarding any past and current litigation with WBSEDCL/WBSETCL/Govt /PSU in which the bidder is involved the party's concerned and disputed amount.

(x) List of Machinery and key personnel.

4. Bidders willing to take part in the process of e-tendering are required to obtain Digital Signature Certificate (DSC) in the name of person who will sign the tender, from any authorized Certifying Authority (CA) under CCA, Govt of India (viz. nCode Solution, Safescrypt, e-Mudhra). DSC is given as a USB e-Token. After obtaining the Digital Signature Certificate (DSC) from the approved Certifying Authority they are required to register the fact of possessing the Digital Signature Certificates through the registration system available in the website.
5. **EMD can be deposited in the online mode only.**
6. **A) For deposition of EMD through online mode (Bank Name-ICICI Bank Ltd., A/C No.-193405000657, Account Title- West Bengal State Electricity Distribution Company Ltd., Account Type –Current, IFSC Code-ICIC0001934, MICR Code-700229096, ICICI BANK LTD., BLOCK-A, ECOSPACE BUSINESS PARK, RAJARHAT, KOLKATA-700156.) following options are available for payment of EMD for the intending bidders-**
 - i. **Net-banking through Payment Gateway.**
 - ii. **RTGS/NEFT Payment: On selection of RTGS/NEFT as the payment mode, the e-procurement portal will show a pre-filled challan having the details to process RTGS/NEFT transaction. The bidder will print the challan and use the pre-filled information to make RTGS/NEFT payment using his bank account. Once the payment is made, the bidder will come back to e-procurement portal to continue the bidding process after expiry of a reasonable time to enable the RTGS/NEFT process to be completed. Bidders are also advised to submit EMD of their bid, at least 1 working day before the bid submission closing date as it requires time for processing of Payment of EMD.****B) If Earnest money is deposited through BG then the bidder shall have to deposit EMD physically in the Accounts Section of Malda Regional Office, WBSEDCL in the form of Bank Guarantee Only (Refer Annexure I) drawn on any Scheduled Bank approved by Reserve Bank of India with validity of 3 (three) months drawn in favour of "The Regional Manager, Malda Regional Office, West Bengal State Electricity Distribution Company Limited".**
7. **Earnest Money Deposit amounting to Rs.3,77,700/- (Rupees Three Lac and Seventy Seven Thousand Seven Hundred Only) shall be submitted in online mode (refer point no 6 A and B). Earnest Money Deposit in any other form or amount will not be accepted.**
8. Exemption from deposition of earnest money deposit (EMD) shall not be allowed under any circumstances.
9. The bidder shall submit along with the offer necessary documents in support of credential (related to the tender) to WBSEDCL/Other Power Utilities/Other Govt. Departments in earlier occasions towards financial capabilities to the extent of the estimated financial capacity of the tenderer.
10. WBSEDCL reserves its right to take decision keeping its financial interest. The provisions of Purchase Policy along with the Civil Works Policy of WBSEDCL with subsequent amendment will be applicable.
11. If the offer is submitted without or inadequate Earnest Money, the bid will not be opened. In case of incomplete offer, the tender will be liable for rejection and Earnest Money Deposit will be forfeited.
12. The offer against tender should remain valid for a minimum period of 180 days from the date of opening of the Price bid. However, WBSEDCL may, on the merit of case, request for extension of validity of the offer for a further suitable period without any change in terms & conditions of the offer.

West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

13. Any evidence of unfair Trade Practices including over charging, price fixing, cartel etc. as defined in various statutes, will automatically disqualify the bidders.
14. WBSEDCL is not bound to accept the lowest tender and reserves the right to cancel any or all the tenders unilaterally.
15. Any bidder against whom FIR/Complaint is lodged with Police by WBSEDCL shall not be eligible to participate in the bidding process.
16. Other information as well as terms and conditions, which are not covered above, will be available in Instructions to Bidders, General Conditions of Contract of this tender along with the Revised Purchase Policy and Civil Works Policy of WBSEDCL.
17. Price Bid of a bidder will be considered only if his Techno-commercial Bid is found acceptable by WBSEDCL. Decision of WBSEDCL will be final and absolute/binding in this respect. The list of techno-commercially qualified bidders will be displayed in the said website in due course.
18. Conditional / Incomplete tender will not be accepted under any circumstances.
19. Labour Welfare Cess @ 1% (one percent) of bill value will be deducted from every bill.

NOTE:

1. WBSEDCL reserves the right to reject or accept any Bid or part thereof or all Bids received at its sole discretion without assigning any reason (s) whatsoever.
2. WBSEDCL reserves the right to go to divisible contract, if necessary.
3. WBSEDCL is not necessarily bound to accept the lowest offer.
4. Submission of Bidding Documents will not be construed to mean that such bidder is automatically considered qualified.
5. Tender submitted after expiry of scheduled date and time shall not be considered.
6. The Bidding Documents are not transferable under any circumstances.
7. No interest shall be payable for Bid Guarantee.
8. Any extraneous conditions will be treated as non-responsive.
9. The Bids must be submitted in prescribed proforma only.
10. Formation of any Cartel, may lead to the cancellation of tenders with period measures as necessary and WBSEDCL reserves the right to take such unilateral decisions without further notice to anyone.
11. Bidders shall ensure that all pre-requisites are duly fulfilled by them and if there be any dispute regarding non-submission of any document, WBSEDCL reserves the right to cancel the Bid unilaterally without assigning any reasons whatsoever.
12. The bidder is expected to examine carefully all instruction, conditions, forms, schedules terms, annexure, specifications and drawings of the bidding document. Bids, which are determined to be not substantially responsive to the requirement of the bidding document, may lead to rejection.
13. **The document uploaded by the bidders should be legible otherwise the bid will be rejected without any prejudice.**
14. **In case the quoted rate by the bidders is in the range of (-) 20% to (-) 80% of the estimated amount, the contractor shall furnish an Additional Performance Security in the format given in Annexure – "XII" which shall be equal to 10 % of the tendered amount. (As per memo no: 82(5)-POW-13099/3/2018-SECTIONS (POWER) dated 05.07.2021 of Govt. of West Bengal, Department of Power). The Additional Performance Security shall be submitted in the form of Bank Guarantee issued by any Scheduled Commercial Bank as per enclosed format before placement of award of contract.**

Signature
16/02/2023

Signature
16/02/23

Signature
16.02.2023

Signature
16/02/23

Signature
16/02/2023
Regional Manager
Malda Regional Office



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section III
INSTRUCTION TO BIDDERS



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

INSTRUCTION TO BIDDERS

1. General guidance for Tendering:

Instructions / Guidelines for electronic submission of the tenders online have been annexed for assisting the contractors to participate in e-Tendering.

2. Registration of Contractor:

Any contractor willing to take part in the process of e-Tendering will have to be enrolled & registered with the Government e-Procurement System of West Bengal, through logging onto <http://www.wbtenders.gov.in> (the web portal) the contractor is to click on the link for e-Tendering site as given on the web portal.

3. Digital Signature certificate (DSC):

Each contractor is required to obtain a Class-II or Class-III Digital Signature Certificate (DSC) for submission of tenders from the approved service provider of the National Informatics Centre (NIC) on payment of requisite amount. Details are available at the Web Site stated in Clause 4 above. DSC is given as a USB e-Token.

4. Downloading of Tender documents:

The contractor can search & download N.I.T. & Tender Document(s) electronically from computer once he logs on to the website mentioned in clause 4 using the Digital Signature Certificate. This is the only mode of collection of Tender Documents.

5. Participation in more than one work:

A prospective bidder shall be allowed to participate in the job either in the capacity of individual or as a partner of a firm, Society, Company, Ltd Company (Incorporation certificate i.e. MOA and AOA, Valid Trade License), Co-operative Society (Society Registration copy, valid Trade License). If found applied severally in a single job, all his offers will be rejected for that job.

6. Submission of Tenders:

General process of submission: Tenders are to be submitted online to the website stated in Cl.4 above, in two folders at a time, one in Technical Proposal & the others Financial Proposal before the prescribed date & time using Digital Signature Certificate (DSC). The documents are to be uploaded in the form of virus scanned copy duly Digitally Signed. The uploaded Documents will get encrypted (transformed into non readable formats).

A. Technical proposal

The Technical proposal should contain scanned copies of the following in three covers (folders)-

A-1. Statutory Cover Containing three covers (folders)-(a) Tender Documents (b) Earnest Money &(c)Annexure/Forms

(a) NIT folder containing Downloaded and uploaded copies (Digitally Signed) of the following: -

- i. NIT.
- ii. General conditions of contract and specification for works
- iii. Addenda/Corrigenda: if published (**Note: Bidders are to keep track of all the Addendum/Corrigendum issued with a particular tender and upload all the above duly digitally signed along with the NIT. Tenders submitted without the Addendum/Corrigendum will be treated as informal and liable to be rejected**)

(b) Earnest Money folder containing-

- i. EMD to be submitted via payment instruments as mentioned in Clause No 6 of Pg No 7 of NIT (Documentary evidence of online submission of EMD should be uploaded in draft folder during bid submission)

(c) Annexure/Forms Folder containing-

- i. Undertaking by the bidder (Annexure-II)
- ii. Letter of Bid for the work (Annexure-VII)
- iii. Declaration by the bidder (Annexure-X).
- iv. Proforma of declaration of black listing/ holiday listing (Annexure-XI)

A-2. Non statutory cover containing

i.EPF Registration Certificate along with challan for the month of **December 2022 or onwards**, I.T Return for Financial Years 2019-20,2021-21 and 2021-22, PAN Card, Profession Tax Paid Certificate for the year **2022-23**, E.S.I. Registration Certificate along with challan for the month of **December 2022 or onwards** and GST Registration No. Certificate.ii.Trade License in respect of the prospective Bidder, Proprietorship Firm (Valid Trade License), Partnership Firm (Partnership Deed, Valid Trade License, Power of Attorney), Ltd Company (Incorporation certificate ie MOA and AOA, Valid Trade License, Power of Attorney), Co-operative Society (Society Registration copy, Valid Trade License, Power of Attorney,Current Year No Objection Certificate issued by the Assistant Register of Co-Op(S)(ARCS),Valid bye laws are to be submitted by the Registered Labour Co-Op(S), Engineers "Co.- Opt. (S)).

NB: Any MOU/Temporary arrangement to constitute an Entity having no statutory Registration Certificates (Non Permanent Establishment) beyond the above entities mentioned in 3(vi) of Pg no. 6 of NIT for the purpose of applying as prospective bidder will not be considered as valid document.

- iii. Copy of Electrical Contractor's License with validity in the name of bidder.
- iv. Attested copy of Electrical Supervisor's Certificate (with necessary parts) of competency issued by the Licensing Board, Government of West Bengal/India (Current engagement of Electrical Supervisor at prospective bidder's firm needs to be established through notary attested contract agreement on Non-Judicial Stamp Paper).
- v. The bidder shall submit reports on the financial standing i. r. o. solvency of Bidder (Company/ Firm) as certified by bankers, audited annual reports on accounts with auditors' certificate for companies registered under Companies



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Act and Tax Audit Report for Partnership Firms for Financial Years 2019-20, 2021-21 and 2021-22.

vi. The bidder's Minimum Average Annual Turnover (MAAT) for last 03 (three) Financial Years (2019-20, 2021-21 and 2021-22) shall not be less than 30% of the estimated cost.

vii. The working capital of the bidder in the preceding year of bid submission shall not be less than 30% of the estimated cost. In case documents certifying credit facility from a scheduled bank is submitted, the requirement shall be judged by adding available credit facility (Refer **Annexure –VI**) and working capital taken together.

viii. Annual Audited Financial Report for last 3 (three) years to be submitted for verification in respect of bidders for whom audit of accounts is mandatory. For those whose audit of accounts is not mandatory, they shall submit copy of IT returns along with related enclosures (Form 3CA/3CB and particulars are reported in the Form 3CD u/s 44AB of Income Tax Act'1961) for last 5 (five) years (i.e. financial years 2017-18, 2018-19, 2019-20, 2020-21 and 2021-22).

ix. List of Machinery and key personnel.

x. Credential of completed works as mentioned here are

The bidder must have successfully completed similar nature of works (**comprising of civil and electrical works combined**) during last seven years (date of completion of work should be on or after 15.02.2016) subject to fulfillment of the following criteria:

d) Three similar completed works (each of the contracts comprising of civil and electrical works combined) of executed value not less than the amount equal to 40 % of the estimated cost i.e. Rs.75,53,063.00/- (minimum G+1 Storied Building)

Or

e) Two similar completed works (each of the contracts comprising of civil and electrical works combined) of executed value not less than the amount equal to 50 % of the estimated cost i.e. Rs.94,41,328.76/- (minimum G+1 Storied Building)

Or

f) One similar completed work (comprising of civil and electrical works combined) of executed value not less than the amount equal to 80 % of the estimated cost i.e. Rs. 1,51,06,126.01/- (minimum G+1 Storied Building)

N.B.-Completion Certificates indicating Name of the Work, Ordered Amount, Executed Amount, Date of commencement and completion of the work and detail communicational address along with contact number of the Client should be submitted by the Bidder. Completion Certificate from the concerned Executive Engineer/District Engineer/Divisional Engineer/Assistant Engineer or equivalent rank and above will be treated as valid credential. Also uploading of copy of work order and schedule of work as supporting documents of completion certificate is mandatory.

B. Financial Proposal (in one cover/folder)

It contains Bill of Quantities (BOQ). The rate to be quoted in the BOQ on "percentage basis" in the space marked for quoting rate (either excess, less or at par i.e. 0.00%). Quoted rate will be encrypted in the B.O.Q. under Financial Bid (**Only downloaded copies of the above documents are to be uploaded, virus scanned and digitally signed by the bidder**).

Note: - Failure of submission of any of the above mentioned documents (as stated in A1 and A2) will render the tender liable to summarily rejected for both statutory & non statutory cover.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

THE ABOVE STATED STATUTORY/NON-STATUTORY/TECHNICAL DOCUMENTS SHOULD BE ARRANGED IN THE FOLLOWING MANNER

“Click” the check boxes beside the necessary documents in the My Document” list and then “click” the tab “Submit Non-Statutory Documents” to send the selected documents to Non- Statutory folder. Next Click the tab “Click to Encrypt and upload” and then click the “Technical” Folder to upload the Technical Documents (Statutory documents).

Sl.No.	Category Name	Sub-category Description	Details
A.	EMD	EMD	Scanned copy of documents regarding online submission of EMD. If EMD is submitted through BG, then scanned copy of BG is to be uploaded.
B.	Declarations	Declarations	a) Undertaking by the bidder (Annexure-II) b) Letter of Bid for the work (Annexure-VII) c) Declaration by the bidder (Annexure-X). d) Proforma of declaration of black listing/ holiday listing (Annexure-XI)
C.	Certificates	Certificates	a) PAN Card. b) Copy of I.T. return for last 3 (three) financial years (2019-20,2020-21 and 2021-22). c) GST Registration No. Certificate d) Professional Tax Paid Certificate for the year 2022-23 e) EPF Registration Certificate and challan for the month of December 2022 or onwards f) E.S.I Registration Certificate and challan for the month of December 2022 or onwards
D.	Company Detail(s)	Company Detail	1. Proprietorship Firm (Valid Trade License). 2. Partnership Firm (Valid Partnership Deed, Valid Trade License and Power of Attorney) 3. Ltd Company (Incorporation certificate i.e. MOA and AOA, Valid Trade License and Power of Attorney). 4. Co-operative Society (Society Registration copy, Valid Trade License, Current Year No Objection Certificate issued by the Assistant Register of Co-Op(S)(ARCS), Valid bye laws and Power of Attorney). 5. Copy of Electrical Contractor's License with validity in the name of bidder. 6. Attested copy of Electrical Supervisor's Certificate (with necessary parts) of competency issued by the Licensing Board, Government of West Bengal/India (Current engagement of Electrical Supervisor at prospective bidder's firm needs to be established through notary attested contract agreement on Non-Judicial Stamp Paper). NB-Any MOU/Temporary Agreement/Joint Ventures/Consortium/Any other arrangement to constitute an Entity having no statutory Registration Certificates (Non Permanent Establishment) beyond the above entities (mentioned in point no 6) for the purpose of applying as prospective bidder will not be considered as valid document. 7. List of Machinery and key personnel.
E.	Credentials	Credential	Necessary documents regarding similar nature of work done which is applicable for eligibility in this tender (As per Clause no.1 of Pg No 6 of NIT)
F.	Financial Information	Financial Information	a) Annual Audited Financial Report for last 3 financial years (2019-20,2020-21 and 2021-22) to be submitted for verification in respect of bidders for whom Audit of Accounts is mandatory. For whose Audits of accounts is not mandatory, they shall submit copy of IT returns along with related enclosures (Form 3CA/3CB and particulars are reported in the Form 3CD u/s 44AB of Income Tax Act'1961) for last 5 financial years (2017-18, 2018-19, 2019-20, 2020-21 and 2021-22) b) In case documents certifying credit facility from a scheduled bank is submitted, the requirement shall be judged by adding available credit facility and working capital taken together. (Annexure –VI)



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

- The bidder shall have to go through all the "Annexure" enclosed in this bid document and submit the filled in Proforma of the appropriate/relevant Annexure with the bid document putting the signature with seal of the Company before uploading the tender viz. Annexure-II(Proforma of letter of undertakings), Annexure-VII(Bid Proposal),(Annexure-X)Declaration by the bidder, Annexure-XI(Proforma of declaration of Black Listing/Holiday Listing) etc.
- Price bid should contain the priced "Bill of Quantities" (BOQ) in one cover (folder). Bidder is to quote the rate on 'Percentage quotation basis in the space marked for quoting rate in the BOQ.

7. VALIDITY OF BIDS:

Price bid of the tender shall be opened within a stipulated time limit from the date of opening of Part-I preferably within 30 (thirty) days. Bids shall remain valid for a period of **180 (one hundred & eighty) days** from the day of opening of financial bid of the tender. However, prior to expiry of the original validity period, WBSEDCL may, on the merit of case, request for extension of validity of the offer for a further period of maximum 90 (ninety) days without any change in terms & conditions of the offer. The bidder may refuse the request without forfeiting his Bid Security / EMD.

8. BID GUARANTEE /EARNEST MONEY DEPOSIT (EMD):

A) For deposition of EMD through online mode (Bank Name-ICICI Bank Ltd., A/C No.-193405000657, Account Title- West Bengal State Electricity Distribution Company Ltd., Account Type –Current, IFSC Code-ICIC0001934, MICR Code-700229096, ICICI BANK LTD., BLOCK-A, ECOSPACE BUSINESS PARK, RAJARHAT, KOLKATA-700156.)

Following payment options are available for online payment of EMD, for the intending bidders-

- i. Net-banking through Payment Gateway.
- ii. RTGS/NEFT Payment: On selection of RTGS/NEFT as the payment mode, the e-procurement portal will show a pre-filled challan having the details to process RTGS/NEFT transaction. The bidder will print the challan and use the pre-filled information to make RTGS/NEFT payment using his bank account. Once the payment is made, the bidder will come back to e-procurement portal to continue the bidding process after expiry of a reasonable time to enable the RTGS/NEFT process to be completed.

B) If Earnest money is deposited through BG then the bidder shall have to deposit physically at the Accounts Section of Malda Regional Office, WBSEDCL in the form of Bank Guarantee Only(Refer Annexure I) drawn on any Scheduled Bank approved by Reserve Bank of India with validity of 3 (three) months drawn in favour of "The Regional Manager, Malda Regional Office, West Bengal State Electricity Distribution Company Limited".

9. GENERAL INSTRUCTIONS FOR ONLINE PAYMENT OF EMD:

- i. The bidder will have to mandatorily pay through Net-banking facility once Net-banking mode is opted for payment.
- ii. Status of NEFT/RTGS payment through Challan for a bid may take time for bank settlement which is updated in 24 Hrs. (approx). As such bidders opting to pay through NEFT/RTGS mode shall make payment well before 24 Hrs. to avoid any complicity.
- iii. In case actual EMD as per NIT is more than the one shown in E-tender Portal, bidders will have to opt for NEFT/RTGS mode (challan mode). In that case the total actual EMD amount is to be paid only through NEFT/RTGS mode (challan mode).
- iv. The bank account used for payment of EMD by the bidders shall be maintained operative until the completion of tendering process. All refunds will be made mandatorily to the Bank A/c from which the payment of EMD has been initiated.

10. REFUND/SETTLEMENT OF EMD AMOUNT:

10.1 If Mode of Payment is Online:

- a) For unsuccessful bidders, EMD amount submitted against the tender shall be refunded automatically, through an automated process, by NIC portal on receipt of updated status of any bid.
- b) For successful bid(s), EMD will be refunded from WBSEDCL authority after completion of tendering process and following due procedures. **Successful bidder(s) shall have to mandatorily create vendor id through WBSEDCL Web Portal Vendor Corner if not created earlier.**
- c) The bank account used for payment of EMD by the bidders shall be maintained operative until the completion of tendering process. All refunds will be made mandatorily to the Bank A/c from which the payment of EMD has been initiated.
- d) For any queries related to payments and refunds, bidders will have to communicate with ICICI Customer Support, viz. 033-40267512/13 since payment gateway facility used by E-tender portal is maintained by ICICI.**

10.2 If Mode of Payment is through BG:

Earnest money submitted in the form of BG will be refunded to the unsuccessful Tenders after finalization of the tender but not later than 60(sixty) days after the expiry of the period of bid validity prescribed by WBSEDCL. In case of successful Tenderers, EMD will be refunded only after submission of the Performance Bond / Guarantee as per terms of contract.

The bid guarantee/EMD shall be forfeited:

- 10.2.1 If during the period of validity specified by the bidder, the bidder withdraws/modifies its bid as a whole or part.
- 10.2.2 If bidder deviates from any clarification/confirmation given by him subsequent to submission of his bid.
- 10.2.3 In case of successful bidder, if bidder fails-
 - 10.2.3.1 To accept LOI/Order unconditionally and sign contract.
 - 10.2.3.2 To furnish the contract performance bond as per enclosed Proforma.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

11. PRE BID MEETING:

- a) A pre bid meeting shall be arranged by WBSEDCL in which all the bidders will be requested to attend.
- b) If there be any discrepancy or obscurity in the meaning of any clauses of the bid document or if there be any query of the intending bidder, the bidder may submit their queries to the tendering authority before specified date. Any change in date shall be intimated to the bidders through e-mail or fax, telephone.
- c) Non attendance at the pre-bid discussion will not be a cause for disqualification of bidders.
- d) The clarification given in the pre bid discussion shall be final and binding on the bidder, being a part of the original Bid Document.
- e) Pre-bid proceedings shall be circulated among all bidders by email.

12. BID SUBMISSION:

Bids shall be submitted online within the stipulated deadline. WBSEDCL may at its discretion, extend the deadline of bid submission by issuing an amendment. In that case all rights and obligations of WBSEDCL and the bidders previously subject to the original deadline shall thereafter be subject to the new deadline as extended.

13. BID WITHDRAWAL/MODIFICATION:

The bidder may modify or withdraw his bid after submission but within the deadline of bid submission, provided written notice of the modification/withdrawal is received by WBSEDCL prior to the deadline for bid submission. No bid shall be modified/ withdrawn after the deadline of bid submission. Modification /withdrawal of bid by any bidder after the deadline of bid submission shall result into forfeiture of EMD.

14. BID OPENING:

- a) Bid Guarantee/EMD shall be opened by WBSEDCL online/offline on the stipulated date of its submission and will be scrutinized.
- b) Techno-commercial bids shall be opened only for those bidders whose EMD has been found in order. Bidder's representatives with written authorization (max. 2 persons per bidder) may attend bid opening. No electronic recording shall be permitted during bid opening.
- c) WBSEDCL will scrutinize and evaluate techno-commercial bid. After that, the list of techno-commercially qualified bidders and date & time of price bid opening will be notified in the web portal.
- d) WBSEDCL may, at its discretion, extend the key dates of the bid or cancel the entire bidding process.
- e) WBSEDCL reserves to instruct the bidders to submit hard copy of any relevant document (and to produce the original documents for verification) during scrutiny & evaluation of bids. Bidders' failure to comply to such instruction may lead to rejection of bid.

15. PROCESS TO BE CONFIDENTIAL:

- a) After the opening of bids, information relating to the examination, clarification, evaluation and comparison of bids, and recommendations concerning the award of contract shall not be disclosed to bidders or other persons not officially concerned with such process.
- b) Any effort by a bidder to influence WBSEDCL or other connected in the process of examination, clarification, evaluation and comparison of bids, and in decisions concerning the award of contract, may result in the rejection of his/their bid.
- c) Formation of any Cartel, may lead to the cancellation of tenders with penal measures as necessary and WBSEDCL reserves the right to take such unilateral decisions without further notice to anymore.

16. RIGHT TO REJECT BIDS:

WBSEDCL reserves the right to accept or reject the bid, wholly or partly, or to split the work in parts and to add/delete any of the items, without assigning any reason whatsoever.

17. BIDDER'S SITE VISIT:

Before submitting the bid, the bidder is encouraged to visit and examine the site and its surroundings and obtain all information that may be necessary for preparing the bid and entering into a contract for the work. Such site visit shall be at the contractor's own expense, risk and responsibility.

18. COST OF BIDDING:

The bidder shall bear all costs associated with the preparation and submission of his bid and WBSEDCL in no case shall be responsible or liable for these costs, regardless of the conduct or outcome of the bidding process.

19. DETERMINATION OF RESPONSIVENESS:

19.1 Prior to the detailed evaluation of bids, WBSEDCL will determine whether the bid is substantially responsive to the requirement of the bidding document.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

19.2 For the purpose of this clause a substantially responsive bid is one which conforms to all the terms, conditions and specification of the bidding document, without material deviation, or reservations. WBSEDCL's determination of bid's responsiveness shall be based on the contents of the bid itself without recourse to extrinsic evidence.

19.3 If a bid is not substantially responsive to the requirements of the bidding document, it may be rejected by WBSEDCL and the same cannot subsequently be made responsive by the bidder by correction.

20. CORRECTION OF ERRORS:

20.1 If there be a discrepancy between the unit price and the total price that is obtained by multiplying the unit price & quantity, the unit price shall prevail and total price shall be corrected.

20.2 If there be a discrepancy in figure and word the total amount stated in word shall prevail.

20.3 The bidder should strike out clearly the portion which is not applicable i.e above/at par/ below in the price sheet. If the same is not followed, the corresponding part(s) shall be considered below the estimated price and evaluation of tender shall be made accordingly.

20.4 If the percentage rate column is left blank, the bid shall be rejected.

21. TIME SCHEDULE:

The basic consideration and the essence of the contract shall be the strict adherence to the time schedule specified in the bidding document.

22. EVALUATION AND COMPARISON OF BIDS:

22.1 On examination of documents submitted under different covers, WBSEDCL will evaluate and compare the bid, determined to be substantially responsive at each step.

22.2 Evaluation of bid will include and will take into account:

22.2.1 WBSEDCL shall evaluate and compare only the bids determined to be substantially responsive.

22.2.2 The bids shall be evaluated on the basis of total price for the entire scope of work covered under this bid document.

22.2.3 Evaluated bid-price of all bidders shall be compared among themselves to determine the lowest evaluated bid and as a result of this comparison, the lowest bid will be selected for award of contract.

22.2.4 Conditional rebate, if any, offered by any bidder shall not be considered in Bid evaluation.

23. PROCEDURE OF EVALUATION:

Evaluation of tenders will be done in the following steps:

Step-1 The Bid Guarantee will be examined. The mode and amount of deposit must be in conformity with requirements set forth in the "Bid Guarantee" clause, failing which the bid is liable for rejection without opening other covers.

Step-2 Techno-Commercial Evaluation for two part bidding:

Only those bids meeting the requirements of previous step will be examined and assessed. The bidders will be intimated about the non-compliance of various techno commercial requirements and asked for conforming compliance with the condition of bidding document, if allowed by the authority. In case, it is felt necessary by WBSEDCL that post bid discussion are required, the same will be carried out individually with each bidder. The bidders will be required to confirm compliance with all the conditions of bidding document. Bids, which do not satisfy the 'Must Conditions' will not be considered for technical evaluation. 'Must Conditions' are to be submitted as per format enclosed with this section. No clarification will be asked from the bidder in this regard.

Step-3 Opening of price part and financial evaluation on completion of techno-commercial evaluation:

Cover-3 containing price offer of the bidders who have successfully made the requirements of previous steps will be opened in presence of the bidder's representative (maximum two) on subsequent pre-intimated date. Price bid of the bidders who do not fulfill the Techno-Commercial requirements shall not be opened.

24. AWARD OF CONTRACT

24.1 Award of Contract

WBSEDCL will award the contract to the successful bidder whose bid has been determined to be substantially responsive, qualified to satisfactorily perform the contract and evaluated as the lowest bidder.

24.2 WBSEDCL's Right to accept or reject Bids

24.2.1 The right to accept the tender will rest with the Owner. The Owner, however, does not bind himself to accept the lowest bid, and reserves to itself the authority to reject any or all the bids received without assigning any reason whatsoever. At the option of the Owner, the work for which bids have been invited, may be awarded to one Contractor or may be split between more than one bidders, in which case the award will be made for only that part of the work, in respect of which the bid has been accepted. The quoted rate of the bidder should hold good for such eventualities.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

24.2.2 Tenders in which any of the particulars and prescribed information are missing or are incomplete in any respect and/or the prescribed conditions are not fulfilled are liable to be rejected. The Tender containing uncalled for remarks or any additional conditions are liable to be rejected.

24.2.3 Canvassing in connection with tenders is strictly prohibited and tenders submitted by the Tenderers who resort to canvassing will be liable to rejection.

24.2.4 WBSEDCL reserves the right to accept or reject any bid, and to annul the bid process and reject any or all the bids at any time prior to award of contract, without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidders or bidder of the grounds for WBSEDCL's action.

24.3 Placement of Letter of Award/Order

After approval of bid evaluation by WBSEDCL, WBSEDCL may, at its sole discretion, invite the successful bidder for a pre-award discussion. After such pre-award discussion and prior to the expiry of validity of bid of the successful bidder, WBSEDCL will notify the successful bidder of acceptance of their bid in writing by issuing a detailed Letter of Award (L.O.A.)/Order (mentioned as L.O.A./Order hereinafter and elsewhere in this bid document) in duplicate. The successful bidder sign and return one copy of the L.O.A./Order to WBSEDCL as an acknowledgement of unconditional acceptance of the same within 7 (seven) days of issue of L.O.A./Order.

25. TAXES, DUTIES AND OTHER LEVIES:

25.1 The contractor shall be solely responsible for the taxes that may be levied on the contractor's persons or on earnings of any office employee and shall hold the purchaser indemnified and harmless against any claims that may be made against the purchaser. The WBSEDCL does not take any responsibility what-so-ever regarding taxes under Income Tax Act, for the contractor or his personnel. If it is obligatory under the provisions of Income Tax Act, deduction of Income Tax at source shall be made by WBSEDCL.

25.2 All other duties / levies payable (excluding GST) by the bidder shall be included in the bid price and no claim on this behalf will be entertained by WBSEDCL.

25.3 GST at specified rate shall be payable / allowable over & above the contract price to the selected bidder having GST registration, GSTIN.

26. RIGHT TO REJECT BIDS:

WBSEDCL reserves the right to accept or reject any bid and to annul the bidding process and reject all bids at any time prior to award of contract without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders the reason for WBSEDCL's action.

27. LAWS GOVERNING CONTRACT:

The contract shall be binding according to Acts/Laws in force in the country and shall be under the jurisdiction of Calcutta High Court.

28. LANGUAGE AND MEASURES:

All documents pertain to the contract including specifications, schedule, notice, correspondences, operating and maintenance instructions, drawings or any other writings be written in English language. The metric system of measurement shall be used exclusively in this contract.

29. CORRESPONDENCE:

Any notice to the contractor under terms of the contract shall be served by register mail or by hand at the contractor's principal place of business. Any notice to the owner shall be served at the owner's principal office in the same manner.

30. CORRUPT OR FRAUDULENT PRACTICE:

WBSEDCL expects that bidders/suppliers/contractors observe the highest standard of ethics during the procurement and execution of such contracts. In pursuance of this policy, the owner defines for the purpose of this provision, the terms set forth below as follows:

30.1 "Corrupt Practice" means the offering giving, receiving or soliciting of anything of value to influence the action of a public official in the procurement process or in contract execution, and

30.2 "Fraudulent Practice" means misrepresentation of facts in order to influence the procurement process of the execution of a contract to the detriment of WBSEDCL and includes collusive practice among bidders (Prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive WBSEDCL of the benefits of free and open competition.

30.3 Will reject a proposal for award if WBSEDCL determines that the bidder recommended for award has engaged in corrupt or fraudulent practice in competing for the contract in question.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

30.4 Will declare a Firm ineligible either indefinitely or for a stated period of time if WBSEDCL determines any time that the firm has engaged in corrupt or fraudulent practices in competition for, or in executing the contract.

31. INSURANCE:

The bidder on awarding of contract shall arrange, secure and maintain all insurance as may be pertinent to the work and obligatory in terms of law in force to protect the interests of WBSEDCL against all perils. The form & the limit of such insurance together with underwriting in each case shall be acceptable to WBSEDCL. However, irrespective of such acceptance the responsibility to maintain adequate insurance coverage at all times during the period of contract shall be contractor's alone.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section IV

GENERAL CONDITIONS OF CONTRACT



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

GENERAL CONDITIONS OF CONTRACT

1. Definition of Terms:

- In writing these General Conditions of Contract, one specification and Bill of quantity/bidding schedule (schedule of work) the following words shall have normally the meanings here-in-after indicated unless there is something in the subject matter of content inconsistent with such construction.
- The Board/purchaser/Owner/Department shall mean the WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LTD, having its Office at Vidyut Bhavan, Block-DJ, Sector-II, Kolkata-700091
- The Engineer-in-Charge/Controlling Officer shall mean the Engineer designated by the Company for the purpose of this contract.
- Company's representative shall mean any person or persons of consulting firm appointed and remunerated by the Company to supervise, inspect, test and examine workmanship and materials of the work under this scope.
- The Contractor shall mean the Bidder who will be awarded with the Contract by the Company and shall include the contractor's executors administrators, successors and permitted assignees.
- The 'Sub-Contractor' shall mean the person named in the Contract for any part of the works or any person to whom any part of the contract has been sublet by the contractor with the consent in writing of the Engineer and will include the legal representatives, successors and permitted assigns of such persons.
- Equipment/materials shall mean and include all type of construction equipment & materials etc. required for true and satisfactory completion of the work under this contract.
- Workmanship shall mean the method/manner in which the jobs of the different items, whether included in the schedule or not but are required for true & satisfactory completion of the work under this contract, are executed.
- General Conditions shall mean all the clauses of General Conditions of the proposed contract stated hereinafter. The specification shall mean the specification annexed to or issued with the General Conditions and shall include the schedule and drawings attached thereto.
- The terms Services shall mean all works to be undertaken by the contractor as laid down under the head "scope of contract" or elsewhere in the specification enclosed. When the words "approved", "subject to Approval", "As directed", "Accepted", "Permitted" etc. are used, the approval, judgment, direction etc. are understood to be a function of Company.
- Month shall mean calendar month.
- "Writing" shall include any manuscript, type written, printed or other statement reproduced in any visible form.
- The work 'Site' shall mean the site of proposed work as detailed in the specification or any other place where the work is to be executed under the contract.
- 'Date of Contract' shall mean the date on which notification of award of contract/ letter of award/telex award has been issued.
- 'Zero Date' will be started from the date of issuance of order/date of handing over of site.

2. Scope of Work:

The contract comprises of construction, completion and maintenance of the work, as required including provision of all labour, material, constructional plant, temporary work and everything whether of a temporary or permanent nature required for such construction, completion and maintenance so far as the necessity of providing the same is specified in or responsible to be inferred from the contract.

The scope of work under this contract shall also include all such works which are not specially mentioned in the Bid Document, as a hole, but are necessary for completion of work in all respects for purposeful functioning of the works, built and/ or renovated under this contract.

3. Submission of Tender:

3.1 Any contractor willing to take part in the process of e-tendering will have to be enrolled & registered with the Government e-Procurement System, through logging on to <http://www.wbtenders.gov.in> (the web portal) the contractor is to click on the link for e-tendering site as given on the web portal.

3.2. The bidders will have to quote their rates against all the items in the BOQ.

3.3. The quoted price should be firm. There will be no price variation during the pendency of the contract period or thereafter. Bidders are in no way allowed to get any escalation of price against this contract.

3.4. Prices indicated in the schedule of prices deemed to include all the levies/duties/taxes/cess& all other incidentals payable as per statute excluding GST. Relevant GST rule is applicable for the work and shall be paid extra.

3.5. WBSEDCL, who do not bind itself to accept the lowest tender, reserves the right to accept or reject any bid and to annul the bidding process and reject all bids at any time prior to award of contract without thereby incurring any liability to the affected bidder or bidders or any obligation to inform the affected bidder or bidders the reason for WBSEDCL's action.

3.6. Canvassing in connection with tenders is strictly prohibited and the tenders submitted by the contractors, who resort to canvassing, will be liable to rejection.

3.7. The tender shall remain valid for a period of 180 (One hundred and eighty) days from the date of opening of the financial bid. However, WBSEDCL may, on the merit of case, request for extension of validity of the offer for a further period of maximum 90 (ninety) days without any change in terms & conditions of the offer.

3.8. EMD can be submitted in online/offline mode as mentioned in Clause No 4 of Pg No 13 of NIT.

3.9. In case of tenders, invited on percentage basis, if the percentage rate column is left blank, the bid shall be rejected.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

3.10. In case of tenders, invited on item rate basis, if the rate is not quoted against any particular item of work, it will be construed that the item would be executed free of cost and the rates for other items of work are deemed to include its cost. Further if any error is found in multiplication of quoted unit rate with respective quantities and/or to derive any rate component and/or in summation to arrive at the total quoted price, the same shall be recalculated to arrive at the evaluated price by considering the quoted unit rate as firm. Bidders are in no way allowed to get any escalation of price against this contract.

3.11. Self-attested copies of PAN card, GST registration No. Certificate Professional Tax Paid Certificate, EPF registration Certificate, I.T Return, ESI if and documents in support of required credential as specified in the NIT will have to be submitted along with the application for purchase of tender documents.

3.12. The tender by a partnership firm must be furnished with full names of all partners and be signed with partnership name, followed by the signature (s), designation(s) of the authorized partner(s) or other authorized representative(s).

3.13. Before the deadline for submission of tenders, WBSEDCL may modify the bidding documents by issuing addenda. Any addendum thus issued shall be part of the bidding documents and shall be communicated through respective website.

3.14. The owner may extend the deadline for submission of tender by issuing an amendment in accordance with clause no 3.13 in which case all rights and obligations of the owner and the bidders previously subject to the original deadline will then be subject to the new deadline.

3.15. Tender shall not be allowed to be submitted after the deadline given in the NIT due to any reason whatsoever.

3.16. Formation of any Cartel, may lead to the cancellation of tenders with penal measures as necessary and WBSEDCL reserves the right to take such unilateral decisions without further notice to anyone.

4 Earnest Money for Open Tender

4.1 Earnest money/bid guarantees amounting to **Rs.3,77,700/- (Rupees Three Lac and Seventy Seven Thousand Seven Hundred Only)**, shall have to be deposited.

4.2 Exemption from deposition of earnest money/bid guarantee shall not be allowed under any circumstances.

4.3 Earnest money shall have to be deposited in online mode as mentioned in Clause No 8 of Pg No 13 of NIT.

4.4 Bid guarantee/earnest money shall be submitted in a separate cover. The mode and amount must be in conformity with requirements set forth in the 'Bid Guarantee' clause, failing which the bid is liable for rejection without opening other covers.

4.5. The earnest Money/Bid Guarantee shall be refunded to the successful bidder by the ordering authority after getting confirmation from the Controlling Officer that Performance Bond has duly been submitted and accepted.

5. Performance Bond/Security Deposit/Additional Performance Guarantee:

As a contract security the contractor shall have to furnish Performance Bond in the form of Bank Guarantee amounting to 3% (three percent) of the contract price (to be mentioned in the LOI/Order) to guarantee the faithful performance and security of the contract in accordance with all the conditions and terms stipulated herein. Performance Bond will also have the guarantee for successful and satisfactory performance of the materials supplied/works done under the contract till the expiry of the guarantee period. The Performance guarantee is to be submitted to the Controlling Officer of the work immediately on receipt of the Order. The WBSEDCL reserves the right to ask for Performance Guarantee up-to 10% of the tendered amount from the successful bidder.

In case the quoted rate by the bidders is in the range of (-)20% to (-) 80% of the estimated amount, the contractor shall furnish an Additional Performance Security in the format given in Annexure – "XII" which shall be equal to 10 % of the tendered amount. (As per memo no: 82(5)-POW-13099/3/2018-SECTIONS (POWER) dated 05.07.2021 of Govt. of West Bengal, Department of Power). The Additional Performance Security shall be submitted in the form of Bank Guarantee issued by any Scheduled Commercial Bank as per enclosed format before placement of award of contract.

6. Refund of Performance Bond / Security Deposit:

Refund of Security deposit shall be subject to Company's right to deduct/appropriate its dues against the contractor under this contract or any other contract. The Security Deposit for all type of bids shall be released only after satisfactory expiry of the guarantee period and certified as such by the Controlling Officer of the work upon written request by the contractor under following conditions:

6.1 In case of all Civil works the defect liability period shall be considered six month or expiry of one full monsoon period, i.e. from June to September whichever is later and any defects such as leakages in walls, dampness, defects in drainage etc. should be rectified to the satisfaction of the Engineer-in-Charge.

6.2 All types of Manufacturer's guarantee/warranty wherever applicable are to be issued/revalidated in the name of the owner by the contractual agency. In the case of all Civil works the defect liability period shall be considered six month or expiry of one full monsoon period, i.e. from June to September whichever is later.

7. Refund of Earnest Money:

For refund/settlement of EMD Amount please refer Clause No 10 of Pg No 13 of NIT.

8. Forfeiture of Earnest Money/Bid Guarantee:

Earnest money/bid guarantee shall be forfeited in case of following:

8.1 If during the period of validity, the bidder withdraws/modifies its bid as a whole or in part.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

8.2 If the bidder deviates from any clarification/confirmation given by him subsequent to submission of his bid.

8.3 In the case of successful bidder, if the bidder fails:

8.3.1 To accept LOI/Order conditionally and sign contract.

8.3.2 To furnish contract performance bond as per enclosed profoma.

9. Defect Liability Period:

9.1 The term 'defect liability period' shall mean the period of six (6) months from the Date of completion of the work. If any defect is found within the defect liability period the contractor shall be liable to rectify/replace the materials at their own cost and responsibility.

9.2 In case of all Civil works any defect in the work detected by the site in-charge within the period of six months from the date of issue of Defect Liability Certificate, the defect liability period shall continue beyond six month or till the expiry of one full monsoon period i.e. June to September.

9.3 Defects/rectification work so notified shall have to be attended and completed satisfactorily within the specified date or as deemed justified by the Controlling Officer. For faithful & due fulfillment of all obligations, this defect liability period shall be covered by the Performance Bond, already submitted by the contractor as per clause no 5 above.

9.4 After completion of defect liability period, and on completion of satisfactory rectification of defects, if any, reported within the defect liability period, and on receipt of the application from the contractor the Controlling Officer of the work shall recommend for refund of the Performance Bond.

10. Manner of Execution of Contract/Agreement

10.1 The successful bidder has to submit acceptance of the order within 10 days from the date of issue of the order. The successful bidder shall be required to execute an Agreement on a non-judicial stamp paper of Rs. 100/- with the company with all related documents for satisfactory execution of the work.

10.2 Agreement shall be signed on a date and time to be mutually agreed upon in the office of the Controlling Officer of the work and the same has to be signed by both the parties within 30 days from the date of acceptance of the order. Power of attorney of the authorized representative of the contractor who will sign the contract on behalf of the contractor is to be submitted before signing of the agreement.

10.3 The agreement shall be signed in original and five photo copies. The original agreement shall be retained by the Company and a copy will be handed over to the Contractor.

11. General Requirement:

11.1 Cost of Bidding: The bidder shall bear all cost associated with the preparation and submission of their bid and WBSEDCL in no case shall be responsible or liable for these costs, regardless of the conduct or outcome of the bidding process.

11.2 Correctness and sufficiency of rates quoted in the tender: The bidder shall be deemed to have satisfied himself before tendering as to the correctness and sufficiency of his tender for work and the rates and prices stated in the schedule of the items. The rates and prices quoted shall cover all obligation of the bidder under the contract and all materials etc. necessary for the proper completion and maintenance of the work. In this case, Rate should be quoted considering Transportation of materials by Road & River Transport (as required)

11.3 The contractor shall execute, complete and maintain the work as per direction of the Controlling Officer/Engineer-in-Charge of the work or his representative.

11.4 Contractor to submit programme: Within 14 (fourteen) days from the date of issue of Letter Of Intent/ Order the contractor shall submit a programme showing the order, procedure and method in which he proposes to carry out the work.

11.5 Contractor's staff at site: The contractor shall provide at site his authorized representative duly approved by the Controlling Officer (approval may be withdrawn for a particular person, if necessary). The contractor and/or his authorized representative is to be constantly on the work and shall give whole time supervision of the same. Such authorized agent or representative shall receive (on behalf of the contractor) direction's and instructions from the Controlling Officer/Engineer or his representative.

11.6 Removal of persons employed at site: The Controlling Officer/Engineer shall be at liberty to ask the contractor to remove from the site any person, employed by the contractor in the execution of the work, who in the opinion of the Controlling Officer/Engineer misconducts himself or is incompetent or negligent in the proper performance of his duties and such persons shall not be again employed upon the work without the permission of the Controlling Officer/Engineer.

11.7 Setting out: The contractor shall be responsible for the true and proper setting out of the work and for the correctness of the position, levels, dimensions and alignments of all parts of work. If at any time during the progress of the work any error shall appear or arise in the positions, levels, dimensions or alignments of any part of the work, the contractor on being asked to rectify by the Controlling Officer/Engineer, shall at his own expense rectify such error to the satisfaction of the Controlling Officer/Engineer.

11.8 Protection of work: The contractor shall in connection with the work provide and maintain at his own cost all lights, guards, fencing and watching when and where necessary if required by the Company or by any competent authority or statutory or other authority for the protection of the work or for the safety and convenience of the public or others.

11.9 Care of works: From the commencement to the completion of the work, the contractor shall take full responsibility for the care thereof and of all temporary work and in case of any damage, loss or injury to work or to any part thereof or to any temporary work due to any cause whatsoever shall at his own cost repair and make good the same, so that at completion the work shall be in good order and conditions and in conformity in every respect with the requirements of the contract. The



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

contractor shall take every practicable precaution not to damage or to cause injury to any adjoining or other properties or to any person. However, even if any damage or injury occurs, the contractor shall be responsible in meeting the necessary claims and demands as may be required.

11.10 Workmen's compensation for accident or injury to any workmen: The Company shall not be liable for damages or compensation payable as per provision of law in respect or consequence of any accident or injury to any workmen or other person in the employment of the contractor. The contractor shall have to pay all claims, demands, preceding costs, charges and expenses whatsoever in respect thereof or in relation thereto. Insurance Policy covering provisions for workmen's compensation for all the workmen to be engaged by the contractor is to be made by him.

11.11 Facilities for other contractors: The contractor shall afford all reasonable facilities for any other contractor employed by the company in execution on or near the site of any work not included in the contract

11.12 Clearing site on completion: On completion of the work the contractor shall clear away and remove from the site all constructional plant, surplus materials, rubbish and temporary work of every kind and leave the whole of the site and work clean and in a good and tidy condition to the satisfaction of the Engineer-in-Charge.

12. Change of Quantity:

The quantity mentioned in the schedule of work is provisional. The owner reserves the right to vary the quantities as may be necessary but such variation shall be limited to $\pm 25\%$ (plus or minus twenty five percent) of the contract price. Payment shall be made as per actual execution.

13. GST:

The bidder has to furnish his GST Registration Number.

14. Labour License:

Contractor will have to obtain Labour License in respect of the above work as per Contract Labour (Regulation & Abolition) Act, 1970 as early as possible.

15. Compliance of Labour Laws:

The contractor shall comply all statutory labour laws to protect the laborers engaged by them. In this connection the contractor will be required to execute an indemnity bond (as per specimen enclosed as Annexure-VIII) after placement of Letter of intent/order.

16. Night and Holiday Work:

If any work of permanent nature is to be carried out in three shifts and/or in Sundays & Holidays prior written permission of the Controlling Officer shall have to be obtained.

17. Deduction of Provident Fund and remittance thereof in respect of Contract Labours:

In respect of casual workers or workers engaged for any job for a very short duration or sporadic nature having no employer-employee relationship (for example soil testing, repair of transformer etc done by outer agency) and engaged in works which are neither preparatory, nor incidental nor any way connected with the main operation of the establishment, deduction of provident fund and remittance thereof in respect of the contract labors will not be applicable. However, it is further clarified that no mechanical approach should be adopted in deciding the applicability of the Act and each case should be considered on its own merits.

18. Variation, Omission, Addition & Alteration

The Contractor shall not modify the work except under direction in writing by the Company. The quantities provided in the Schedule of work are provisional only, which may vary up to any extent or may be deleted altogether. The quoted rate of each item shall remain Firm. The Company reserves the right to alter, amend, and omit or otherwise vary the quantities as may be necessary but such variation will be limited to $\pm 25\%$ (plus or minus twenty five percent) of the contract price. Payment shall be made as per actual execution.

19. Controlling Officer, Technical Controlling Officer, Nodal Officer and Paying Authority:

The Regional Manager, Malda Regional Office, WBSEDCL shall be the Controlling Officer. The Assistant Engineer (Civil) of Malda Regional Office is the Technical Controlling Officer of the work under whose guidance and direction the civil works will be executed. **The Junior Engineer (Civil) Grade-II of Malda Regional Office is the Site Supervisor (for Civil Works)**, who will supervise the work under the technical guidance of the Technical Controlling Officer (for civil works).

The **Divisional Manager of North Malda Divisional Office** is the **Technical Controlling Officer** of the work under whose guidance and direction the electrical works will be executed. **The AE (Tech) (Electrical) of North Malda Divisional Office** is the **Site Engineer-in-Charge (For Electrical Works)**, who will supervise the work under the technical guidance of the Technical Controlling Officer. **The Manager (HR &A), Malda Regional Office, WBSEDCL** shall be the Nodal Officer. Payment will be made by **The Manager (F&A) of Malda Regional Office, WBSEDCL**



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

20. Supplementary works:

Whenever supplementary work becomes unavoidable for completion of the work in all respect, the Contractor shall bring the matter to the notice of the Controlling Officer and submit their proposal. However, the controlling officers shall have the right to advise the contractor to proceed with such item (s) of work. Rates for supplementary item shall be arrived at as given hereunder:

20.1 The rates of all supplementary items shall be decided on pro-rata basis from the existing items in the contract.

20.2 When above clause no 20.1 shall not be applicable the rates shall be taken from P.W.D. (WB) schedule of rates for building works, sanitary & plumbing works & PWD(WB)(Roads) schedule prevailing at the time of submission of bids.

20.3 When clause no 20.1 & 20.2 above shall not be applicable, the rates should be analyzed, to the mutual acceptance from present market rates of different elements involved in the item, against documentary evidence, with 5% overhead, contractor's profit as 10% and 1% cess towards BOCWWC Act, 1996. In that case contractual rate of quotation will not be applicable.

Controlling Officer's decision regarding finalization of rate of non-scheduled item(s) shall be final and binding upon the contractors.

The contractor will have to submit an application for payment of executed supplementary items before finalization of revised order from WBSEDCL End. In the prayer the contractor should enclose Supplementary Schedule of Work containing Description of items, rates of items and executed quantity of Supplementary items.

21. Measurement and Terms of Payment:

21.1 All items of work carried out by the contractor in accordance with the provision of the contract having a financial value shall be entered in the Measurement book/Log book etc. as prescribed by the company so that a complete record is obtained of all works performed under the contract and the value of the work carried out can be ascertained and determined there from.

21.2 Measurement shall be taken jointly by the Supervising Officer or his authorized representative and by the contractor or his authorized representative. Every measurement thus taken shall be signed and dated by both the parties.

21.3 In the event of failure on the part of the contractor to attend or send his authorized representative after receiving the intimation or to countersign or record objection within a week from the date of measurement, the measurement taken by the Engineer-in-charge or his authorized representative shall be taken to be the correct measurement of the work done.

21.4 **Progressive R/A bills, against the prayer of the contractor, for an amount of minimum 20% of the ordered value** or as deemed justified by the Controlling Officer shall be released against certification by the Controlling Officer after deducting the amount already paid or other amounts as may be deductible. The bills shall be released within 45 (forty five) days of its submission if all formalities as per terms of contract is maintained. The final bills shall be released on completion of the work in all respect and fulfillment of all contractual obligations by the contractor.

21.5 The company reserves the right to recover/enforce recovery of any overpayments detected after payment as a result of post-payment audit or technical examination or by any other means, notwithstanding the fact that the amount of disputed claims, if any, of the contractor exceeds the amount of such overpayment and irrespective of the fact whether such disputed claims of the contractor are subject matter of arbitration or not the amount of such overpayments may be recovered from the subsequent bill, under the contract, failing that from contractor's claim under any other contract with the company or from the contractor's security deposit or from the amount retained or the contractor shall pay the amount of overpayment on demand.

22. Completion of Contract:

All works under the contract must be completed by period of completion mentioned in NIT while portions of work as per programme settled in consultation with the Controlling Officer shall be completed by the date stipulated in the said programme. It is to be noted that time is the essence of the contract and any default on the part of the contractor to complete the work within the stipulated date/dates aforesaid or within the time as may be extended in writing by the Controlling Officer subject to the payment of liquidated damages, the Company shall have the right, without prejudice to any other clauses, to terminate contract forthwith and to take possession of the balance work/materials and have the same allotted to any other agency and the contractor shall be liable to compensate the loss that may be occasioned to the Company on that account. Any letter in writing by the Controlling Officer shall be treated as conclusive on behalf of the Company.

23. Defective Materials:

If in the opinion of the Engineer-in-Charge, any of the materials brought to the site for use are not of the quality or kind specified in the contract and/or are unfit for the work, he shall be at liberty to order the removal of the said materials and the contractor shall remove the same within 24 (twenty four) hours after notice has been given to him and if he fails to remove them within the time the Engineer may cause them to be removed anywhere at the risk of the contractor and any cost incurred in so doing shall be deducted from the dues to the contractor under the contract.

24. Drawing:

The work shall be carried out as per the instruction and to the satisfaction of the Engineer-in-Charge in accordance with the signed drawing, the specification and schedule of quantities and also as per any further drawings which may be supplied, all instructions which may be given by the Engineer-in-Charge from time to time.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

25. Materials and Workmanship:

All the work shall be executed with the materials as specified and with best workmanship and/or in the best manner to the satisfaction of the Engineer-in-charge.

26. Extension of Time:

If the work is suspended due to reasons beyond the control of the contractor, the contractor shall immediately give notice in writing within 7 (seven) days to the controlling officer for each occasion. On receipt of such notice, the controlling officer may verify the matter and agree to extend the completion period as may be reasonable but without prejudice to other terms and conditions of the contract as the case may be if the reasons behind the suspension of work are found to be justified.

27. Liquidated Damage:

27.1 If the contractor fails to complete the work successfully within the time specified in the Contract or any extension thereof, the Company shall recover from the contractor as liquidated damages a sum of half percent (0.5%) of the contract value of works for each calendar week of delay or part thereof of delay subjected to the Force Majeure.

27.2 The total recovery against liquidated damage shall not exceed ten percent (10%) of the contract value of the work.

An extension of time without imposition of liquidated damage, may be granted for delay in execution of work provided there is no fault whatsoever on the part of the contractor. Such extension may only be granted on the basis of application to be submitted by the contractor who has to establish that the extension of time required by him was not due to his fault.

28. Default Risk:

In the event of the contractor's inability/non-response to accept and take up the work as per the order & contract agreement, the Owner reserves the right to terminate the contract with forfeiture of E.M.D. along with Contract Performance Guarantee and deploy any separate agency to complete residual portion of this contract. If the contract is terminated in the above manner, the Contractor shall have no claim for compensation against the Owner. the Owner shall have the right to engage any other Contractor to complete the work and any extra cost incurred by the Owner to get the work completed in all respect will be realized from the pending bill(s) and/or E.M.D. and/or Retention Money and/or Security Deposit and/or any Bank Guarantee(s) of the original Contractor for this contract or any other contract under WBSEDCL.

29. Company's Right to Terminate the Contract:

If the contractor neglects or fails to proceed with the work proportionate to the scheduled time of completion of the work or fails to complete the work within scheduled time for completion or within the extended time approved by the Company, the Company shall have right to terminate the order/letter of intent after giving notice in writing to the contractor. If the contractor fails, after 14 (fourteen) days' of such notice, to proceed with the work in the manner notified, the Company shall terminate the contract and call the contractor to take joint measurement along with the Engineer for the finished portion of work. If the contractor does not appear for a joint measurement, ex party measurement by the Company will be taken as final.

In that case the Company shall take possession of the work site and may engage other agency to complete the work. Extra cost, if incurred to get the unfinished work done through other agency, will be realized from him, from his pending bills and security money. If the contract is terminated as above, the contractor shall have no claim for compensation against the Company for any loss or deterioration of any materials that he may have collected or engaged or entered into on account of the work.

30. Mode of Measurement

30.1 Mode of Measurement:

As regards specification of materials, execution of work and the mode of measurement relevant stipulation of P.W.D. schedule of rates (applicable at site of work) in this respect will be applicable. The contractor shall arrange and provide all necessary facilities along with necessary manpower for inspection, testing and measurement of work at his own cost.

30.2 Sample Approval:

The Contractor shall get sample(s) of each & every items/materials/equipments approved as per instruction of the Controlling Officer/Engineer-In-Charge and as far as practicable prior to bringing in at site for use, well in advance. The Controlling Officer/Engineer-In-Charge shall have the every discretionary power to allow or disallow any items/materials/equipments based on submission of the sample (s) by the Contractor. If the items/materials/equipments brought at site for use at work does not match with the sample (s) thus approved beforehand by the Controlling Officer/Engineer-In-Charge, then Controlling Officer/Engineer-In-Charge shall have the discretionary power to reject those items/materials/equipments brought to site for use at work and instruct the Contractor to remove those items/materials /equipments forthwith. The decision of the Controlling Officer/Engineer-In-Charge shall be binding to the Contractor. The Contractor shall furnish to the Controlling Officer/Engineer-In-Charge for approval, when requested or if required by the specifications, adequate samples of all materials to be used in the work. Such samples shall be submitted before the work is commenced and with ample time to permit tests and examinations thereof.

30.3 Approval of materials:

The contractor shall have to follow the standard technical specification of WBSEDCL as well as of PWDSOR and National Building Code for the work. All relevant Indian Standard Code of Practice which are applicable for the work shall have to be followed. The contractor shall however, obtain approval of materials along with standard brands/manufacturer from the



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Engineer-in-Charge/Technical Controlling Officer prior to bringing in at site. No material should be brought in or used for the work without prior approval and the rejected material shall have to be removed within 24 hours from site.

30.4 Tests and test Certificate:

The Controlling Officer/ Engineer-In-Charge may ask the contractor to submit the test certificate of any material(to be used for the work) from the manufacturer(s), in conformity to the relevant Indian Standard Code of Practice. Even after submission of such test certificate, the Controlling Officer/ Engineer-In-Charge may further ask the contractor for testing of particular material, preferably from Govt. Testing Laboratory for acceptance/rejection of material, at the risk and cost of the contractor, till such particular material is allowed to be used for the work.

The "Technical Specification" of the "Bid Document" may also be referred in conjunction with this GCC for further details regarding the above.

31. Departmental Materials

Departmental material shall not be issued to the contractor for the work except under special circumstances.

32. Deductions of Taxes and Cess for BOCWWC Act 1996:

The Contractor is required to follow the Building and other Construction Worker's Welfare Act, 1996.

Registration of his establishment under section-7 of the Building and other Construction Worker's (Regulation and condition of Service) Act, 1996 is to be made after the contract is awarded. 1% cess towards BOCWWC Act, 1996 will be deducted from its total amount of each bill.

33. Force Majeure:

The Contractor shall not be liable to pay any liquidated damage for delay/failure to perform the contract for reasons of force majeure such as acts of God, acts of the public enemy, acts of Governments, fire, flood, epidemics, quarantine restriction, strikes, freight embargos and provided that the contractor shall within 10(ten) days from the beginning of such delay notify the Company in writing of the cause of delay. The Company shall verify the facts and grant such extension as found to be justified without imposing liquidated damage.

The Department shall not be responsible or liable to pay any compensation for any interruption in your work at the site due to strike, lockout, riot, earthquake, flood, cyclone or civil commotion or any other force of accident due to any reason beyond control. The Department shall not be held responsible to or liable to pay for any interruption in your work at the site arising out of resistance from the local public due to any resistance towards work.

34. Sub-letting of Contract:

The contractor shall not, without the written consent of the Company, assign or sublet his contract or any part thereof, other than for raw materials, or for any part of the work provided that any such consent shall not relieve the contractor from any obligation, duty or responsibility under the contract. In the event of sub-letting of contract or any part thereof is permitted, the fact that such permission has been accorded shall not establish any contractual relationship between the approved Sub-vendor and WBSEDCL of any of his liabilities and obligations under the contract.

35. Engineer's Decision:

Controlling Officer's decision is final in respect of all matters which are left to the decision of the Controlling Officer including the granting or with-holding of certificates.

If, in the opinion of the contractor, a decision made by the Controlling Officer is not in accordance with the meaning and intent of the contract, the contractor may file with the Controlling Officer, within 7 (seven) days after receipt of the decision, a written objection to the decision. Failure to file an objection within the allotted time will be considered as an acceptance of the Controlling Officer's decision and the decision shall become final and binding.

36. Liability of Accidents and Damage:

The Contractor shall be responsible for the loss, damage or depreciation of the Company's materials while in their custody and until the same is taken over by the Company.

Until the completed work is taken over by the Company the contractor shall also be liable for and shall indemnify the Company in respect of all injury to person or damage to property resulting from the negligence of the contractor or his workmen or sub-contractor or from defective workmanship etc.

37. Language and Measurement:

All documents pertaining to the contract including specifications, schedule notices, correspondences, operating and maintenance instruction, drawings or any other writings be written shall be in English language. The metric system measurement shall be used exclusively in this contract.

38. Settlement of Disputes:

All disputes concerning question of act arising under the contract shall be decided by the owner/company on receipt of written appeal by the contractor. Any dispute or differences arising out of or in connection with this contract shall to the extent possible be settled amicably. However, the Kolkata High Court shall have exclusive jurisdiction in all matters arising under the Contract including settlement of disputes.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

39. Completion of Work:

Completion of the work means completion of the work in totality and acceptance/takeover of the same by the Company. Partial or phase wise completion will have no bearing towards consideration of guarantee/defect liability period.

40. Idle Labour/Machinery:

Whatever the reasons may be no claim for idle labour and machinery, additional establishment cost| hire and labor charges of tools & plants would not be entertained by the Company, under any circumstances.

41. Safety Rules:

The bidder shall also provide necessary fencing and lights to protect the public from accident.

Fire extinguishers shall be kept by the bidder at the site of works where there is risk of fire hazard.

Adequate washing facilities shall be provided near the place of work.

When the work is done near any place where there is risk of drowning, all necessary equipments shall be provided and kept ready for use and all necessary steps taken for prompt rescue of any person in danger and adequate provisions shall be made for prompt first aid treatment of all injuries likely to be sustained during the course of work.

These safety provisions shall be brought to the notice of all concerned by displaying on a notice board at a prominent place at the work spot the persons responsible for compliance of code shall be named by the bidder.

To ensure effective enforcement of the rules & regulations relating to safety precautions, the arrangement made by the bidder shall be open to inspection by the employer and WBSEDCL.

Notwithstanding the above clauses there is nothing in those to exempt the bidder from the operations of any other Act or Rule in force in the Republic of India.

All storage, handling & use of flammable liquids shall be under the supervision of qualified persons.

First aid arrangements with the degree of hazard and with no. of workers employed shall be maintained in a readily accessible place throughout the whole of working hours.

i. Reporting of Accident:

All accidents, major or minor, must be reported immediately to WBSEDCL and the contractor will provide first aid to the injured person immediately. The injured person shall report to the First Aid Station along with the 'Injured on work' form as per Appropriate Proforma, duly filled in quintuplicate and submit to the Medical Officer of the First Aid Station.

ii. Serious Injuries:

In case of serious injuries, the following procedure shall be adopted by the contractor.

To provide first aid at his own First Aid Station.

To take the injured person to the hospital along with the 'Injured on work' form duly filled in.

To report the accident to WBSEDCL.

Fatal Accident-Fatal accidents must be reported immediately to WBSEDCL as well as to the Police.

iii. Penalty:

Failure to observe the Safety Rules will make the contractor liable to penalty by way of suspension of work and termination of contract Adequate arrangement for proper lighting & guarding shall be made at the work site.

42. Equipment & Machineries:

For timely completion of the work the contractor must have to deploy all necessary equipment, tools & tackles and machineries adequate shuttering to execute the work at a time to perform all works simultaneously as per requirement of WBSEDCL.-

43. Additional Conditions of Contract

1. The work shall be inspected time to time by WBSEDCL representatives. The contractor shall provide all facilities for such inspection free of cost Notwithstanding any inspection of the site, WBSEDCL shall have the right to reject any work not conforming to the specification without being liable for any explanation or compensation. The authorized representative of WBSEDCL shall have the free access to the work site, contractor site office and store.

2. During the execution of work, if any, problem arises which is not covered by the specification, the 'Contractor shall seek necessary clarification and instruction from WBSEDCL such Instruction shall be binding on the contractor and shall be observed in full.

3. The contractor shall make his own arrangement for all labour, construction equipment, tools and tackles and construction materials, construction water, office/ labour accommodation, water supply, sanitation etc.

4. Electricity for construction purpose, if supplied by WBSEDCL, the charge shall be borne by the contractor at the rate specified by the WBSEDCL. The contractor cannot claim any compensation for any failure in such supply caused due to any reason whatsoever in case of non-availability of electricity for construction purpose from WBSEDCL. The contractor will have to arrange the same at his own cost.

5. The contractor shall strictly follow the construction safety rules, regulations and instructions issued from time to time. In absence of any particular reference the contractor shall refer to relevant Indian Standard and also the State Government rules and regulations.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

6. The contractor shall take all precautions during execution, especially while excavating underground works, such as cables, pipe lines, drains etc. and provide all possible protection to these works and in case any materials got damaged, rebuilt / divert them at his own cost.
7. All guarantees and test certificates obtained by the contractor during the execution of work shall be transferred to the WBSEDCL before issue of final payment.
8. The contractor shall provide all necessary storage at the site in specified areas for all materials such as timber, cement, lime and such other materials which are likely to deteriorate by the action of sun, winds, rain or other natural cause due to exposure in the open in such manner that all such materials shall be duly protected from damage by weather or any other cause. All such stores shall be cleared after completion of the work and the entire site shall be clean and free from debris. All materials shall be stacked in such a manner as to facilitate rapid and easy checking of such materials.
9. The cost of testing of concrete and any other material shall be borne by the contractor.
10. All works are to be carried out with due regard to the convenience of the occupants of the premises or road users and with close co-ordination with other contractors who may be working in the area. All arrangements/ programmes of work must be adjusted accordingly. All precautions must be taken to guard against chances of injury or accident to the occupants, users & workers. The contractor must see that all damages to any property, which in the opinion of the Controlling Officer are due to the work of the contractor, are promptly rectified as per his direction and to his satisfaction. The construction of work must be done in such a way as not to dislocate or disturb any sewerage system and existing other structures.
11. It must be clearly understood that WBSEDCL is indemnified by the contractor against payment of any compensation or award on account of any accident, injuries, and damages and if any such payment has to be made by WBSEDCL under order of appropriate authorities, the same shall be recovered from the contractor.
12. Any services if affected by the work must be restored by the contractor on emergency basis at his own cost.
13. After completion of work, the finishes shall be of high quality and of approved standard.
14. No omission or ambiguities in the drawing or in the specifications will relieve the contractor from responsibility for material or completeness of the work.
15. The contractor shall not off-load the Contract or part thereof to any subcontractor without obtaining written permission from the Controlling Officer of the work. In the event sub-letting of contract or any part thereof is permitted the fact that such permission has been accorded shall not establish any contractual relationship between the approved Sub-contractor and WBSEDCL of any of his liabilities and obligations under the contract.
16. A complete list of execution / deviation from the tenderer's scope of work shall be clearly indicated. Similarly, if any departure, commission of substitution from stipulated specifications is made, this fact should be clearly indicated in the offer with reasons. However, WBSEDCL shall have the absolute discretion to summarily reject such offers.
17. WBSEDCL's representative may during the progress of work, order for re-execution of part or whole of the work executed, found not in accordance with the approved drawings/ specifications/instructions. No extra claims shall be entertained for re-execution or altering or such work.
18. The contractor shall provide sufficient strong and stable staging as to ensure safety of the labourers and structures.
19. The contractor shall dismantle and remove the staging and other temporary structures like stores, offices, labour camps etc. on completion of work/ clear and dean the site where such temporary facilities were built and restore the same to original condition.
20. Materials brought to the site shall not be removed from the site without the written consent of the WBSEDCL. The contractor shall submit well in advance for approval of samples, specimens as the WBSEDCL may demand from time to time. Any material brought to the site and rejected by the WBSEDCL shall be removed by the contractor from the site of work immediately.
21. All materials including reinforcing steel, cement for concrete work, sanitary, plumbing & carpentry fittings shall be procured after approval of brand and make by WBSEDCL.
22. All bricks have to be submerged in vats before put to use. Curing shall be done with proper care.
23. The contractor has to make arrangement for temporary cover to enable civil construction works to continue if interrupted due to rains during monsoon.
24. If necessary extra items beyond S.O.W. are executed the Unit Rate shall be as per rates of PWD, West Bengal Schedule of Work on the date of Bid opening. Those items which are not covered under PWD rates shall be based on analysis of rate on current market rate as applicable, on mutual agreement.
25. Bar chart showing all activities needs to be submitted before commencement of work.
26. Depth of the tube well, if any, shall be complied with Public Health Engineering Directorate recommendations.
27. All drawings supplied with the bid documents are tentative / for guidance only.
28. WBSEDCL shall not be liable under any circumstances for any accident / untoward incidents, if happened during execution of works.
29. The contractor shall submit test certificate from the appropriate authority for pot ability of drinking water indicating presence of Arsenic & other chemicals, if any.
30. If specification of any items of work is not covered in the Bid Documents the same shall be guided from PWD Schedule of Rates.
31. All dismantled departmental materials shall have to be returned to stored/ disposed and stacked in a place (within 500 m lead) provided by the Purchaser without any extra cost to WBSEDCL.
32. Mode of measurement shall be followed as described.
33. The "**Technical Specification**" shall have to be complied with along with the PWDSOR and National Building Code as well as relevant Indian Standard Code of Practice.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section V
SPECIAL CONDITIONS OF CONTRACT



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

SPECIAL TERMS AND CONDITIONS:

1. All works will have to be done according to the drawings duly approved by Engineer-in-charge before the work is taken up. Works shall have to be executed on the basis of the detailed drawings to be provided by WBSEDCL.
2. The tenderer should clearly note that all the drawings cannot be given or handed over at a time. However, WBSEDCL shall make every effort to provide the detailed drawing in time so that work does not suffer. Failure to provide drawing (s) in time shall not be cited as reason for delay in progress of work and no claim whatsoever, on any ground shall be entertained in this regard.
3. All works shall have to be carried out with due regard to the convenient to the surrounding establishments/occupants.
4. Damages to any property during execution have to be rectified as directed by Engineer-in-charge at the cost of the contractor and with the satisfaction of WBSEDCL.
5. All necessary precautions to be adopted at site by the contractor to avoid injuries to any labour or any person. Necessary signage, segregation has to be organized by the contractor at his own cost. Guarding of properties as well as materials during non-working period including at night, Sundays/holidays are also to be arranged by the Contractor, over and above general guarding during normal working hours, at his risk and cost.
6. The contractor shall save, harmless and indemnify WBSEDCL from and against any claims, demands, suits and proceedings for or on account of infringement of any patent right, design, trademark or name or other protected right like cutting of any tree, constructional plants, machine, work materials or things or process used for or in connection with the works or temporary work or any of them.
7. The contractor shall not assign or sublet or employ for any portion of the work through specialized agency/erector if intended or required without bringing it to the notice of WBSEDCL and obtain necessary approval from the above mentioned authority. The relevant clause (s) of the bid document shall be applicable also.
8. Contractor's establishment and stack yard :
Due to inadequate space available within the working site , the contractor has to arrange open area next to site at his own cost for the construction of temporary structures and other works which are essential during the complete tenure of construction period :----
 - i) Contractor' site office.
 - ii) Contractor's godown.
 - iii) Labour camp.
 - iv) Steel stack yard
 - v) Stack yard for construction materials like stone chips, sand, bricks etc.
 - vi) Stack yard for scaffolding and shuttering materials.

No separate payment will be made for hiring open area in this regard. No extra cost will be paid for double storage and carriage etc. Rate quoted by the contractor deemed to have taken care of all such factors.

9. The entire bid document including BOQ and Technical Specification should be read altogether while quoting the rate.
10. Water proofing company has to ensure minimum 10 (ten) years warranty for the water tightness of the structure.
11. For water proofing, external finishes like structural glazing , ACP cladding , warranty for a minimum period of 10 (ten) years shall have to be given by the manufacturer for the materials along with cross warranty of the work by the contractor.

In case any defect is observed during this period of warranty, the contractor shall be liable to rectify all those defect observed as intimated by WBSEDCL at the risk and cost of the contractor.

Relevant clauses of this bid document shall also be applicable. The date of warranty for the total work shall be reckoned from the date of taking over of the project by WBSEDCL. The date of warranty for the product/material as given by the manufacturer should be as per general practice as in vogue.

12. Prior to the commencement of external finishing work including painting work, the contractor has to make "mock up" sample for approval at free of cost. Relevant clause(s) of the technical specification shall also be applicable.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

13. The contractor shall obtain the clearance/approval from the Engineer-in-Charge before the commencement of any type of work.
14. During construction of the building, all necessary precautions and safety norms shall have to be strictly followed.
15. All product manuals, colour shades, descriptions, brochures, etc. for different kind of work are to be submitted with in advance (at least 15 days before) for getting approval from the Owner for actual execution. Further, supplements, requisites etc., if asked for by the Owner to arrive at a decision towards approval of a particular item/work shall have to be provided by the Contractor at his own cost and responsibility.
16. No claim shall be entertained by the Owner for sampling, testing, mock up, approval of samples, documentation, shop drawings etc.
17. WBSEDCL shall have the right to modify/change the working drawings/ construction drawings even after issue of the same to the Contractor. No claim shall be entertained in this regard.
18. The following specifications, standards and codes are made a part of this specification. All standards, tentative specifications, codes of practice referred to herein shall be the latest editions including all applicable official amendments and revisions.

Some of the IS codes that are applicable to the work are listed below:

Sl. No.	IS Code No.	Description	Last year of publication
1.	IS : 73	Specification for paving bitumen	1992
2.	IS : 101	Methods of test for ready mixed paints & enamels	1964
3.	IS : 102	Ready mixed paint, brushing, red lead, non-settling, priming	1962 (Reaffirmed 1991)
4.	IS : 110	Ready mixed paint, brushing, grey, filler, for enamels for use over primers	
5.	IS : 204 Part – 1	Tower bolts : Part - 1 Ferrous metals	1991 (Reaffirmed 1996)
6.	IS : 204 Part – 2	Tower bolts : Part - 2 Non-ferrous metals	1992 (Reaffirmed 1996)
7.	IS : 205	Specification for non-ferrous metal butt hinges	1992 (Reaffirmed 1996)
8.	IS : 206	Tee and strap hinges	1992 (Reaffirmed 1996)
9.	IS : 207	Gate & Shutter hooks & eyes	1964 (Reaffirmed 1996)
10.	IS : 208	Specification for door handles	1996
11.	IS : 269	Specification for 33 grade ordinary Portland cement	1989 (Reaffirmed 1998)
12.	IS : 280	Mild steel wire for general engineering purposes	1978 (Reaffirmed 1997)
13.	IS : 287	Recommendation for Moisture Content for Timber used for Different purposes	1993 (Reaffirmed 1998)
14.	IS : 303	Specification for plywood for general purposes	1989 (Reaffirmed 1998)
15.	IS : 348	French polish	1968 (Reaffirmed 2001)
16.	IS : 362	Specification for parliament hinges	1991 (Reaffirmed 1996)
17.	IS : 363	Specification for hasps and staples	1993 (Reaffirmed 1999)
18.	IS : 364	Specification for fanlight catch.	1993 (Reaffirmed 1999)
19.	IS : 371	Ceiling roses	
20.	IS : 383	Specification for coarse and fine aggregates from natural sources for concrete.	1999
21.	IS : 419	Putty, for use on window frames.	1967 (Reaffirmed 1998)
22.	IS : 432 Part - 1	Specification for mild steel & medium tensile steel bars & hard-drawn steel wire for concrete reinforcement : Part - 1 Mild steel & medium tensile steel bars	1982 (Reaffirmed 2000)
23.	IS : 432 Part – 2	Specification for mild steel & medium tensile steel wire for concrete reinforcement : Part - 2 Hard-drawn steel wire	1982 (Reaffirmed 2000)
24.	IS : 455	Specification for Portland slag cement	1989 (Reaffirmed 2000)
25.	IS : 456	Code of practice for plain and reinforced concrete	2000



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Sl. No.	IS Code No.	Description	Last year of publication
26.	IS : 458	Specification for precast concrete pipes (with and without reinforcement)	1988
	IS : 459	Corrugated & semi-corrugated asbestos cement sheets	1992
27.	IS : 516	Method of test of strength of concrete	1959 (Reaffirmed 1999)
28.	IS : 636	Non-percolating flexible fire fighting delivery hose (3 rd revision)	1988
29	IS : 651	Salt glazed stoneware pipes & fittings	1992 (Reaffirmed 1997)
30	IS : 694	PVC insulated cables for working voltages up to and including 1100V	
31	IS : 702	Specification for industrial bitumen	1988
32	IS : 712	Specification for building limes	1984 (Reaffirmed 1995)
33.	IS : 730	Specification for hook bolts for corrugated sheet roofing	
34.	IS : 732	Code of practice for electrical wiring installation	
35.	IS : 777	Specification for glazed earthenware wall tiles	1988
36.	IS : 778	Specification for copper alloy gate, globe and check valves for water works purposes	1984 (Reaffirmed 1995)
37.	IS : 779	Specification for water meters (domestic type)	1994 (Reaffirmed 1999)
38.	IS : 783	Code of practice for laying of concrete pipes	1985 (Reaffirmed 1996)
39.	IS : 800	Code of practice for general construction in steel	1991 (Reaffirmed 1998)
40.	IS : 802	Code of practice for use of structural steel in over head transmission line towers	1978 (Reaffirmed 1995)
41.	IS : 814	Covered electrodes for manual metal arc welding of carbon & carbon manganese steel	1991 (Reaffirmed 1998)
42.	IS : 816	Code of practice for use of metal arc welding for general construction in mild steel	1969 (Reaffirmed 1998)
43.	IS : 817	Code of practice for training and testing of metal arc welders	1966 (Reaffirmed 1997)
44.	IS : 875	Code of practices for design loads for building and structures	1987 (Reaffirmed 1997))
45.	IS : 884	First Aid hose reel for firefighting (1 st revision)	1985
46.	IS : 908	Fire hydrant, stand hose type (2 nd revision)	1975
47.	IS : 1003	Specification for timber paneled and glazed shutters	1994 (Reaffirmed 2000)
48.	IS : 1030	Carbon steel castings for general engineering purpose	1998
49.	IS : 1038	Specification for steel doors windows and ventilators	1983 (Reaffirmed 1996)
50.	IS : 1077	Common burnt clay building bricks	1992 (Reaffirmed 1997)
51.	IS : 1080	Code of Practice for design and construction of shallow foundation in soils	1985 (Reaffirmed 1997)
52.	IS : 1081	Code of Practice for fixing and glazing of metal (steel & aluminium) doors, windows and ventilators	1960
53.	IS : 1124	Method of test for determination of water absorption, apparent specific gravity and porosity of natural bldg. stones.	
54.	IS : 1130	Specification for marble (blocks, slabs & tiles)	1969 (Reaffirmed 1998)
55.	IS : 1141	Code of practice for seasoning of timber	1993 (Reaffirmed 1999)
56.	IS : 1161	Steel tubes for structural purposes	1998
57.	IS : 1172	Code of basic requirement for water supply, drainage & sanitation (4 th revision)	1993 (Reaffirmed 1998)
58.	IS : 1199	Methods of sampling and analysis of concrete	1959 (Reaffirmed 1999)
59.	IS : 1200 Part 1-28	Methods of measurement of building & Civil engineering works	Latest Publication
60	IS : 1237	Specification for Cement Concrete flooring Tiles	



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Sl. No.	IS Code No.	Description	Last year of publication
61.	IS : 1239 Part - 1	Mild steel tubes, tubulars & other wrought steel fittings : Part – 1- Mild steel tubes	Part - 1 1990 (Reaffirmed 1995)
62.	IS : 1239 Part - 2	Mild steel tubes, tubular & other wrought steel fittings : Part - 2 – Mild steel tubular & other wrought steel pipe fittings	Part - 2 - 1992
63.	IS : 1258	Bayonet lamp holder	
64.	IS : 1293	Three pin plugs and socket outlets	
65.	IS : 1322	Bitumen felt for water proofing and Damp Proofing	
66.	IS : 1341	Specification for steel butt hinges	1992 (Reaffirmed 1996)
67.	IS : 1344	Specification for calcined clay pozzolana	1981 (Reaffirmed 1999)
68.	IS : 1346	Code of practice for water proofing of roofs with bitumen felt.	
69.	IS : 1361	Specification for Steel windows for industrial Bldg.	
70.	IS : 1363 Part - 1 to 3	Hexagon head bolts, screws & nuts of product grade C.	1992 (Reaffirmed 1998)
71.	IS : 1364	Hexagonal head bolts, screws and nuts of product grades, A and B	1992 (Reaffirmed 1998)
72.	IS : 1367	Technical supply conditions for threaded steel fasteners	1980 (Reaffirmed 1996)
73.	IS : 1443	Code of practice for laying and finishing of Cement concrete flooring tiles	
74.	IS : 1489 Part - 1	Specification for Portland pozzolana cement : Part - 1 Fly ash based	1991 (Reaffirmed 2000)
75.	IS : 1489 Part - 2	Specification for Portland pozzolana cement Part-2 Calcined Clay based.	
76.	IS : 1538	Specification for cast iron fittings for pressure pipes for water, gas & sewage	1993 (Reaffirmed 1999)
77.	IS : 1542	Sand for plaster	1992 (Reaffirmed 1999)
78.	IS : 1566	Specification for hard-drawn steel wire fabric for concrete reinforcement	1982 (Reaffirmed 2000)
79.	IS : 1608	Method for tensile testing of steel products	1995
80.	IS : 1641	Code of practice for fire safety of buildings (General): General principles & fire grading and classifications (1 st revision)	1988
81.	IS : 1646	Code of practice for fire safety of buildings (General) : Electrical installations	
82.	IS : 1726	Specification for cast iron manhole covers and frames	1991
83.	IS : 1729	Sand cast iron spigot and socket soil waste & ventilating pipes, fittings and accessories	1979 (Reaffirmed 1996)
84.	IS : 1742	Code of practice for building drainage	1983 (Reaffirmed 1996)
85.	IS : 1786 (1139 Superseded)	Specification for high strength deformed steel bars and wires for concrete reinforcement	1985 (Reaffirmed 2000)
86.	IS : 1834	Specification for hot applied scaling compound for joint in concrete.	
87.	IS : 1837	Specification for fanlight pivots	1966 (Reaffirmed 1996)
88.	IS : 1838	Specification for preformed fillers for expansion joint in concrete pavements and structures: Part-I: Bitumen impregnated fibre.	
89.	IS : 1868	Anodic coatings on aluminium and its alloys	1996
90.	IS : 1904	Code of practice for design and construction of foundation in soils : general requirements	1986 (Reaffirmed 1995)
91.	IS : 1905	Code of practice for Structural use of un-reinforced masonry	1987 (Reaffirmed 1998)
92.	IS : 1948	Specification for aluminium doors, windows and ventilators	
93.	IS : 1949	Specification for aluminium windows for Industrial buildings.	



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Sl. No.	IS Code No.	Description	Last year of publication
94	IS : 2016	Plain washers	1967 (Reaffirmed 1996)
95	IS : 2062 (226 Superseded)	Steel for structural purpose	1999
96	IS : 2065	Code of practice for water supply in buildings	1983 (Reaffirmed 1990)
97	IS : 2074	Ready mixed paint, air drying, red oxide - zinc chrome, priming specification	1992 (Reaffirmed 1998)
98.	IS : 2096	Asbestos cement flat sheets	1992
99	IS : 2098	Specification for asbestos cement building boards	1997
100	IS : 2114	Code of practice for laying in-situ terrazzo floor finish	1984 (Reaffirmed 1996)
101	IS : 2116	Specification for sand for masonry mortars	1980 (Reaffirmed 1998)
102	IS : 2147	Degree of protection provided by enclosure for low voltage switchgear and control gears	
103	IS :2171	Portable chemical fire extinguishers, dry powder (cartridge type)	
104	IS :2175	Heat detectors	1988
105	IS : 2185 (P-1)	Specification for concrete masonry units – P-1 Hollow & Solid Concrete Blocks	1979 (Reaffirmed 1998)
106	IS : 2189	Code of practice for selection, installation, maintenance of automatic fire detection & alarm (2 nd revision)	1988
107	IS : 2190	Selection, installation, maintenance of first aid fire extinguisher (Code of practice)	
108	IS : 2191 Part - 1	Specification for wooden flush door shutters (cellular and hollow core type) : Part - 1 Plywood face panels	1983 (Reaffirmed 1996)
109	IS : 2191 Part - 2	Specification for wooden flush door shutters (cellular and hollow core type) : Part - 2 Particle board and hardboard face panels	1983 (Reaffirmed 1996)
110	IS : 2202	Specification for wooden flush door shutters (solid core type)	1999
111	IS : 2209	Specification for mortice locks (Vertical type)	1976 (Reaffirmed 1996)
112	IS : 2212	Code of practice for brickwork	1991 (Reaffirmed 2000)
113	IS : 2215	Starters for fluorescent lamps	
114	IS : 2250	Code of practice for preparation and use of masonry mortars	1981 (Reaffirmed 1995)
115	IS : 2268	Electric call bells and buzzers	
116	IS : 2309	Code of practice for protection of building and allied structures against lightning	
117	IS : 2339	Aluminium paint for General Purposes	
118	IS : 2386 Part - 1	Methods of test for aggregates for concrete : Part - 1 - Particle size and shape	1963 (Reaffirmed 1997)
119	IS : 2386 Part - 3	Methods of test for aggregates for concrete : Part - 3 - Specific gravity, density, voids, absorption and bulking	1963 (Reaffirmed 1997)
120	IS : 2386 Part - 4	Methods of test for aggregates for concrete : Part - 4 Mechanical properties	1963 (Reaffirmed 1997)
121	IS : 2395	Code of Practice for painting concrete, masonry and plaster surfaces (Part 1 & 2)	
122	IS : 2418	Tubular fluorescent lamps for general lighting service	
123	IS : 2502	Code of practice for bending & fixing of bars for concrete reinforcement	1963 (Reaffirmed 1999)
124	IS : 2551	Danger notice board	
125	IS : 2645	Specification for integral cement waterproofing compounds	1975 (Reaffirmed 1999)
126	IS : 2667	Fittings rigid steel conduits for electrical wiring	



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Sl. No.	IS Code No.	Description	Last year of publication
127	IS : 2681	Specification for non-ferrous metal sliding door bolts for use with padlocks	1993 (Reaffirmed 1999)
128	IS : 2690	Specification for burnt clay flat terracing tiles: Part 1 – Machine made.	
129	IS : 2750	Specification for Steel Scaffoldings.	
130	IS : 2751	Recommended practice for welding of mild steel plain and deformed bars for reinforced construction	1979 (Reaffirmed 1998)
131	IS : 2835 (1761 Superseded)	Flat transparent sheet glass	1987
132	IS : 2878	Specification for fire extinguishers, CO2 type, portable trolley mount	2004
133	IS : 2911 (Part-I/Sec.2)	Code of practice for design and construction of pile foundations	1979
134	IS : 2911 (Part IV)	Code of practice for design and construction of pile foundations Part IV – Load test on piles	1979
135	IS : 2932	Specification for enamel, synthetic, exterior type (a) undercoating (b) finishing	
136	IS : 3007	Code of practice for laying of asbestos cement sheets - corrugated and semi-corrugated sheets (Part – 1 & 2)	
137	IS : 3036	Code of Practice for Laying Lime Concrete for a Water – Proofed roof finish.	1992
138	IS : 3043	Code of practice for earthing	
139	IS : 3063	Fasteners – single coil rectangular section spring lock washers – specification.	1994 (Reaffirmed 1999)
140	IS : 3067	Code of Practice of General design details and preparatory work for dump proofing and water – proofing of Building	1988
141	IS : 3068	Specification for broken Brick (burnt clay coarse aggregates for use in lime concrete)	1986
142	IS : 3087	Specification for wood particle boards (medium density) for general purposes	1985 (Reaffirmed 1996)
143	IS : 3097	Specification for veneered particle boards	1980 (Reaffirmed 1996)
144	IS : 3114	Code of practice for laying of cast iron pipes	1994 (Reaffirmed 2000)
145	IS : 3370 (Part 1 & 2)	Code of practice for concrete structures for the storage of liquids : requirements Part - 1 - General requirements Part - 2 - Reinforced concrete structures	1965 (Reaffirmed 1999)
146	IS : 3384	Specification for bitumen primer for use in waterproofing and damp-proofing	1986 (Reaffirmed 1996)
147	IS : 3419	Fittings for rigid non-metallic conduits	1989 (Reaffirmed 2001)
148	IS : 3478	Specification for high density wood particle boards	1966 (Reaffirmed 1998)
149	IS : 3480	Flexible steel conduits for electrical wiring	
150	IS : 3495 (P 1, 2 & 3)	Method of test for burnt clay building bricks	1992 (Reaffirmed 1997)
151	IS : 3536	Specification for ready mixed paint, brushing, wood primer etc.	1999
152	IS : 3564	Specification for door closers	1996
153	IS : 3646	Code of practice for interior illumination	



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Sl. No.	IS Code No.	Description	Last year of publication
154	IS : 3696 Part - 1 Part - 2	Safety code of scaffolds and ladders : Scaffolds Ladders	1987 (Reaffirmed 1996) 1991 (Reaffirmed 1996)
155	IS : 3764	Excavation work - Code of safety	1992 (Reaffirmed 1996)
156	IS : 3837	Accessories for rigid steel conduits for electrical wiring	
157	IS : 3844	Code of practice for installation of internal fire hydrants in multistoried buildings	1989 (Reaffirmed 2010)
158	IS : 3854	Switches for domestic and similar purposes	
159	IS : 4014 Part - 2	Code of practice for steel tabular scaffolding : Part - 2 Safety regulations for scaffolding	1967 (Reaffirmed 1995)
160	IS : 4130	Demolition of buildings - code of safety	1991 (Reaffirmed 1996)
161	IS : 4160	Interlocking switch socket outlets	
162	IS : 4308	Dry powder fire fighting (1 st revision)	1982
163	IS : 4351	Specification for Steel door Frames	1976
164	IS : 4457	Specification for ceramic unglazed Vitreous acid resisting files	1982
165	IS : 4615	Switch socket outlets (non-interlocking type)	
166	IS : 4648	Guide for electrical layout in residential buildings	
167	IS : 4948	Specification for welded steel wire fabric for general use	1974
168	IS : 4984	Specification for high density polyethylene pipes for potable water supplies : sewage and industrial effluents	1995
169	IS : 4985	Specification for unplasticised PVC pipes for potable water supplies	2000
170	IS : 5039	Specification for distribution box for voltages not exceeding 1000V	
171	IS : 5133	Boxes for enclosure of electrical accessories Part-1 : Steel & cast iron boxes	
172	IS : 5216	Recommendation safety procedures and practices in electrical works	
173	IS : 5372	Taper washers for channels (ISMC)	1975 (Reaffirmed 1996)
174	IS : 5374	Taper washers for I – Beams (ISMB)	1975 (Reaffirmed 1996)
175	IS : 5410	Cement Paint, Colour as required	1992
176	IS : 5411 Part - 1	Plastic emulsion paint for interior use.	1974 (Reaffirmed 1993)
177	IS : 5491	Code of practice for laying of in-situ granolithic concrete flooring topping	1969 (Reaffirmed 1996)
178	IS : 5523	Method of testing anodic coating on aluminium & its alloys	1983 (Reaffirmed 1999)
179	IS : 5624	Foundation Bolts	1993
180	IS : 5913	Methods of test for asbestos cement products	1989 (Reaffirmed 1998)
181	IS : 6234	Specification for portable fire extinguishers, water type	1986
182	IS : 6248	Specification for metal rolling shutters & rolling grills	1979 (Reaffirmed 1996)
183	IS : 6313 Part - 1	Code of practice for anti-termite measures in buildings Constructional measures	1981 (Reaffirmed 1995)
184	IS : 6313 Part - 2	Code of practice for anti-termite measures in buildings Pre-constructional chemical treatment measures	1981 (Reaffirmed 1998)
185	IS : 6313 Part - 3	Code of practice for anti-termite measures in buildings Treatment for existing buildings	1981 (Reaffirmed 1998)
186	IS : 6403	Code of practice for determination of bearing capacity shallow foundations.	1981 (Reaffirmed 1997)
187	IS : 6639	Specification for Hexagonal Bolts for Steel Structures	1972 (Reaffirmed 1995)
188	IS : 6946	Flexible (pliable) non-metallic conduits for electrical installations	1973 (Reaffirmed 1990)



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Sl. No.	IS Code No.	Description	Last year of publication
189	IS : 7215	Tolerances for fabrication of steel structures	1974 (Reaffirmed 1995)
190	IS : 7452	Specification for hot rolled steel sections for doors, windows and ventilators	1990
191	IS : 7676	Glossary of terms for firefighting equipments	1985
192	IS : 8041	Specification for rapid hardening Portland cement	1990 (Reaffirmed 2000)
193	IS : 8042	White Portland Cement	1989
194	IS : 8112	Specification for 43 grade ordinary Portland cement	1989 (Reaffirmed 2000)
195	IS : 8442	Functional requirements for stand part type water for firefighting	1972
196	IS : 8828	Electrical accessories – circuit breakers for house hold and similar application (MCB)	
197	IS : 8869	Specification for washers for corrugated sheet roofing	1978
198	IS : 8963	Chloropyrifos, technical	1978 (Reaffirmed 2001)
199	IS : 9537 (P3) (2509 Superseded)	Conduits for electrical installations : Part - 3 Rigid plain conduits of insulating materials	1983 (Reaffirmed 2001)
200	IS : 9595 (Superseding IS:6227)	Metal arc welding of carbon and carbon manganese steel - recommendation	1996
201	IS : 9862	Ready mixed paint, brushing, bituminous, black, lead-free, acid, alkali, water and chlorine resisting	1981 (Reaffirmed 1999)
202	IS : 9972	Automatic sprinkler hoses	1981
203	IS : 10118	Code of practice for selection, installation and maintenance of switchgear and control gears	
204	IS : 11353	Guide for uniform system of marking and identification of conductors and apparatus	
205	IS : 11360	Specification for portable fire extinguishers, water type	1986
206	IS : 12456	Fire protection of electronic data processing installations	
207	IS : 12866	Specification for plastic transparent made from thermosetting polyester resin	1989
208	IS : 13947	Specification for low voltage switchgear and control gears	
209	IS : 14609	Specification for dry powder for firefighting – Class ABC fires	2001
210	IS : 15301	Installation & maintenance of fire fighting pumps – Code of practice	2003

In addition to the above IS codes, all other IS codes that are applicable to the work should also be followed and provided to WBSEDCL, if asked for, at the risk and cost of the Contractor. Moreover, the relevant schedule of specifications (of PWD) with names of codes and detail specifications shall also be applicable. In case of any dispute, ambiguity etc. the decision of WBSEDCL shall be final and binding to the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section VI

GENERAL INSTRUCTIONS



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

General Instructions

1. All relevant IS Codes or specifications along with PWD specifications shall be applicable in general.
2. In all possible cases sample approval from WBSEDCL is necessary prior to bulk procurement by the Contractor.
3. All approved samples shall be kept at site at the risk and cost of the Contractor for the entire period of Contract.
4. In case of mismatch/difference between approved sample and bulk procured item, the Contractor shall remove the materials within 24 hours of bringing in the materials at site at his risk and cost.
5. Test certificates for materials brought and used at site shall have to be submitted to WBSEDCL, in all possible cases including steel and cement.
6. Over and above, WBSEDCL may instruct the Contractor for further testing of materials at the risk and cost of the Contractor from Government Test Houses/ Laboratories.
7. The "Warranty"/"Guarantee" from the manufacturer shall have to be submitted by the Contractor in the name of WBSEDCL, in all possible cases with cross warranty of installation and/or workmanship by the Contractor. The Decision of WBSEDCL shall be final and binding on the Contractor.
8. Specialized work shall have to be carried out with specialized persons/agency/ authorized applicator etc., as the case may be.
9. No work shall be carried out without the knowledge/prior intimation/approval/ checking etc. by WBSEDCL. If such a case arises, WBSEDCL may not accept the work and WBSEDCL shall have the right to accept such work/part of work with no admissibility of payment. Recurrence of such incident may attract penal measures on the Contractor as may be decided by WBSEDCL.
10. Work beyond normal working hours and on Sundays/Holidays shall be executed with prior intimation and permission thereof by the Controlling Officer/Engineer-In-Charge.
11. Unless otherwise specified elsewhere in this Contract, all work under this Contract shall be carried out in accordance with the technical specification and the latest issue of the Indian Standard Specification applicable to the particular class of work. If Indian Standards are not formulated for any particular material of work, the relevant British Standard Specification shall apply.
12. Relevant issues of I.S. Specifications, applicable to the particular work have been described along with the Specification for respective works as far as possible. In case of any confusion/ambiguity/dispute etc. regarding the meaning and interpretation of any Specification for the respective works, the decision of WBSEDCL shall be final and binding on the Contractor.
13. All in-situ tests shall have to be carried out in presence of the authorized representative(s) of WBSEDCL at site with prior intimation (at least 72 hours before) to the satisfaction and acceptance of the Owner with attaining the applicability/functionality of the works/materials/equipments etc., as the case may be.
14. All test reports, in-situ as well as tests at site and/or laboratory tests shall form the part of the Contract for acceptance of the work in part and/or whole and the Contractor shall submit the reports/results duly authenticated by him and/or WBSEDCL's representative at site present during the test/authorised signatory of the testing house/ laboratory (for testing at Govt. Test Houses/laboratory) within 15 (Fifteen) days from the actual date of testing or as directed by WBSEDCL specifically.
15. The relevant clauses of G.C.C. and S.C.C. shall also be applicable and should be read in conjunction with this "Technical Specification". In case of any anomaly/dispute, decision of WBSEDCL shall be final and binding on the Contractor.
16. No extra claim for any test, re-test including the tests for pre-commissioning as well as commissioning whatsoever, shall be entertained by WBSEDCL.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

17. All the relevant I.S Codes, specifications etc. shall be made available to WBSEDCL by the Contractor against the work during the entire period of Contract.
18. All manuals, brochures etc. shall be handed over to WBSEDCL immediately after execution and testing of each part of the relevant work.
19. The list of approved materials mentioned in the B.O.Q. and/or Technical specification is a guideline to the Contractor only. WBSEDCL reserves the right to instruct the Contractor to procure materials, equipments etc. beyond the list of approved materials mentioned in the B.O.Q. as well as in Technical specifications of equivalent quality.
20. All registers, reports, drawings, diagrams, warranties etc. shall be property of WBSEDCL and the Contractor shall have to submit to WBSEDCL as per terms of the Contract.
21. Any revision of work, drawings etc. shall have to be accepted by the Contractor during execution of the work within the purview of the Contract, as a whole.
22. The following "Order of Preference" shall prevail in case of any ambiguity between specifications, drawings and Bill of Quantities (BOQ).
 - i) The Bill of Quantities (BOQ)
 - ii) Technical Specification as well as Special Conditions of Contract.
 - iii) Execution drawings.

If no solution can be made by the above "Order of Preference", then the decision of WBSEDCL shall be final and binding.

23. Notwithstanding above or any of the clauses contained in the bid document, decision of WBSEDCL on any clause or for any case shall be final and binding on the Contractor.
24. Whatsoever the case may be, compliance of all the clauses for execution of the entire contract, it shall not relieve the Contractor from any of his obligations under the contract and the Contractor shall remain fully responsible for completeness, accuracy & correctness of all the documents & drawings & works till completion of the contract with the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section VII
TECHNICAL SPECIFICATIONS OF CONTRACT



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

TECHNICAL SPECIFICATION FOR GENERAL CIVIL WORK

1. GENERAL

1.1. Scope of work

This technical specification is general in nature & description. The relevant description of a particular item shall be guided by the item description in the Schedule of Rates of this Bid Document. THE PWDSOR along with relevant IS Specifications and the National Building Code shall have to be followed as a general guideline. In case of any dispute/discrepancy, the decision of the Engineer-In-Charge and/or Technical Controlling Officer shall be final & binding on the bidder.

The work contemplated under this contract includes General Construction for the aforesaid project, all as detailed in the Bill of Quantities, Specifications and Drawings.

Such other works which are not included in the aforesaid Bill of Quantities are generally intended to be executed through a separate agency. Notwithstanding the above, the WBSEDCL (West Bengal State Electricity Distribution Company Limited) reserve the right to order additional works under the same Contract. The WBSEDCL also reserve the right to omit any item of work included in the aforesaid Bill of Quantities and award the same to any other Contractor or not perform it at all at their discretion and the Contractor shall not have any claim because of the same.

The Contractor for this work shall be required to work in co-operation and co-ordination with other agencies on site and give them all reasonable assistance and help for the execution of the work in an efficient manner all as directed. The words "approved" or "as directed" shall be deemed to convey approval or the discretions of WBSEDCL.

1.2 Indian Standard Specifications

The particular Specifications for the work is as detailed hereinafter. These specifications shall be read in conjunction with the relevant Indian Standard Specifications and the obtainable local practice as detailed in various regional handbooks of practice and the work shall be executed accordingly. Where the specifications in any of the standards are at variance with the specifications detailed herein, the specifications herein shall govern.

In case of any ambiguity/contradiction among different specification, the decision of WBSEDCL shall be final and binding on the Contractor.

1.3 Quality of materials & General Standards of work

The Contractor under this contract commits himself to use first class materials and assumes full responsibility for the quality of all material incorporated or brought for incorporation in the work. The work shall be executed in accordance with best engineering practice and as per direction of WBSEDCL.

In all possible cases, sample approved shall be done by the Contractor from WBSEDCL before bringing in the materials in bulk at site and the approved sample shall be well preserved at site at the risk and cost of the Contractor as a ready reference. Over and above, the submission of test certificate by the manufacturer, WBSEDCL may instruct further sample testing from Govt. Laboratories/ testing houses at the risk and cost of the Contractor for submission of test reports to become eligible for payment for those particular items used at work.

In all possible cases, where the warranty of manufacturers are sought for by WBSEDCL, the Contractor shall submit the cross warranty in the form and manner as directed by WBSEDCL including workmanship etc. along with the manufacturer's warranty certificate.

The relevant IS and PWD specification shall have to be complied with for all possible cases. The relevant clauses of GCC shall also be applicable and should be read in conjunction with technical specification of this contract

1. In case of any anomaly / contradiction, decision of WBSEDCL shall be final and binding on Contractor.

2. No extra claim shall be admissible for sample testing, sample approval, testing of sample at site etc to the Contractor and shall be considered as deemed to have been included in the rates quoted by the Contractor.

1.4 Power for construction

Construction power may be provided by WBSEDCL, if applied for by the Contractor as per prevailing rules and regulations of WBSEDCL. However, all charges for the construction power shall have to be borne by the Contractor. The relevant clause may also be referred to GCC in this regard.

Alternatively, the Contractor shall have to arrange required capacity D.G. set at his own cost, risk and responsibility to work. Necessary permission to operate DG set to be obtained from the concerned authority by the Contractor.

Arrangement of DG may also be kept for exigencies or power failure.

1.5 Scaffolding

All scaffolding and ladders required for the proper execution of the work shall be provided by the Contractor. The scaffolding should be stout and strong to prevent any collapse or displacement. Proper measure for safety of workmen working on scaffolding should be taken by the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

1.6. Measurements

The mode of measurements, wherever possible is specifically mentioned in these documents, where it has not been mentioned, it shall be as per provision of the PWDSOR and relevant Indian Standards IS 1200 . All the measuring equipments , labour , manpower and other accessories necessary, shall be provided by the Contractor at his own risk and cost .

1.7 Tools and plant

The bidder along with his bid furnish a list of tools, plant and machinery which he intends to use for the works (as per proforma, if enclosed with the bid document). The list should indicate the exact type of machine, its capacity, and year of manufacture, kind and capacity of propelling force, spare parts readily available and all other pertinent information. The Contractor is obliged to use all the machinery mentioned in his list mentioned or others as required and instructed if WBSEDCL considers it necessary.

1.8 Setting out

The Contractor shall set out the building or other involved works after clearing the site and get the same approved by the owner. It shall be the responsibility of the Contractor to install substantial reference marks, bench marks etc. and maintain them as long as required by the owner . The Contractor shall assume the full responsibility for proper setting out , alignment , elevation and dimension of each and all parts of the work .

1.9 Surveying and Staking

It is the express responsibility of the Contractor to bring to site all surveying instruments necessary for the marking out, fixation of levels, etc. and conduct these survey operations himself with utmost accuracy. The Contractor shall put-up stable bench marks etc. as necessary for the work. Representative (s) of WBSEDCL may become present when this work is being carried out and will inspect all these operations with the Contractor's assistance. The Contractor shall be entirely responsible for accurate setting out of the work and he shall at his own expense make good any defects arising from errors in line and levels.

Before commencement of excavation, spot levels on an approved grid covering the entire plot shall be taken by the Contractor in consultation with the owner and a proper record of these levels shall be kept jointly signed by the Contractor and the owner.

1.10 Dewatering

Dewatering of accumulated water in all locations on jobsite from whatever source or cause until the virtual completion of the entire work shall be done by the Contractor at his own expense and shall not be separately paid for. The rate quoted by the Contractor shall be deemed to be inclusive of this.

1.1.11. Access to site, approach roads and roads within the premises

The Contractor shall at his own cost provide all approach roads required for the purpose of carrying out the work in the most expeditious and efficient manner and shall remove the temporary roads on completion. He shall acquaint himself thoroughly regarding condition and suitability of public roads leading upto the limits of the premises and will provide vehicles for transportation of materials which meet the requirements of these road conditions. It shall also be responsibility of the Contractor to maintain at his own cost these roads till the construction is completed. The tenderer shall also acquaint himself with local laws and By laws and complying with all police and traffic requirements.

2. EARTH WORK

2.1 Excavation

Excavation for trenches over areas and for pits, etc. shall be done to widths, lines and levels as shown in drawings or to such lesser or greater widths lines and levels as directed. The bottom and side of excavation shall be trimmed to required levels, profile, etc. watered and thoroughly rammed. Where the Contractor excavated below required level in good ground inadvertently or carelessly they shall make up the void in concrete (1:5:10) at his own expense. In general, during excavation the Contractor shall take necessary precaution to retain earth (vissalballah piling, shoring etc) so that the earth will not slide or fall down to avoid any accident and hamper the progress of work at his own risk & responsibilities. They will take necessary step to prevent the damage the adjacent structure or existing services. They shall repair and make good any such damage at their own expense to the satisfaction of the owner. A suitable path for men and materials around the excavated pit should be maintained throughout the work.

2.2 Shoring

The sides of excavation should be timbered and supported in such a way as is necessary to secure these from falling in and the shoring shall be maintained in position as long as necessary . The Contractor shall be responsible for the proper design of the shoring to be approved by the owner to hold the sides of the excavation in position and ensure safety of persons and properties. The shoring shall be removed as directed after the items for which it is required are completed. Unless & otherwise mentioned in the schedule of quantities , no extra payment will be made for shoring, unless & otherwise specifically instructed in writing by WBSEDCL over and above the general requirement as mentioned in clause no. 1.2.1 under the heading "Excavation" in this tender document.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

2.3 Dewatering

All water which may get accumulated in excavations during the progress of work from whatever cause or source, shall be bailed or pumped out as necessary. The rate for excavation shall be deemed to include for the same.

2.4 Silver sand filling

Filling sand may be silver sand having silt content less than 5% by weight and 300mm compacted thick layers will be spread, wetted & saturated to achieve the compaction. However for any special case, WBSEDCL may instruct filling by sand other than silver sand which the Contractor shall comply. The specification etc shall be guided by relevant IS code.

2.5 Filling

Filling under floors or other places indicated shall be done by fine sand or silver sand brought from outside by the Contractor. The material should generally be good quality. Filling shall be done in layers not exceeding 15 cm. thick and each layer shall be fully inundated and consolidated properly by 8 to 10 tones power rollers in the case of where floor is coming or pneumatic rammers wherever conditions permit. If it is not possible, the consolidation shall be done by hand rollers and pneumatic/plate vibrator followed by hand rammer. The surface of the filling shall be finished true to lines and levels as required. The filling shall be compacted in such a manner as to guarantee full stability. The compaction shall be such that minimum relative density obtained on testing is 90%. In general; test shall be performed for every 1000 M2 of compacted area. The filling final level after compaction then cutting and ready to take up soling work under the floor item, shall be checked by WBSEDCL.

2.6 Disposal of excavated materials

All materials unearthed shall be removed from the site of excavation and disposed off during excavation with prior written permission of WBSEDCL from the site in an approved manner with the approval of local authority. The disposal of the materials can be in any of the following ways as directed by WBSEDCL:

1. Removal of surplus material outside the plot for disposal.

2. Removal of surplus materials to a particular place / dumping ground as directed by the owner. No extra claim on any account will be entertained. The Contractor must also secure the approval of the owner regarding the quantity of surplus materials to be removed prior to commencement of this item of work.

2.7 Back filling

All shoring and form work shall be removed after their necessity ceases and trash of any sorts shall be cleaned out from the excavation. All space between foundation masonry or concrete and sides of excavation shall be refilled to the original surface with approved excavated materials in layers 15 cm in thickness watered and rammed. The filling shall be done after concrete or masonry is fully set and done in such a way as not to cause undue thrust on any part of the structure. Where suitable excavated materials are to be used for refilling, it shall be brought from the place where it is temporarily stacked and used in refilling.

No excavation of foundation shall be filled in or covered up until all measurements of excavation, masonry, concrete and other works below ground level are jointly recorded. Black cotton soil shall not be used for back filling or in plinth filling.

2.8 Measurements

Measurements for all excavation, filling, carting away and earthwork shall be in solid measure. The rates quoted by the tenderers are thus for solid measure units. The following factors shall be applied to obtain quantities of solid measure.

- Excavation : No reduction in volume (as per drawing area).

- Filling : Volume shall be determined and consolidated by levels taken before and in layers after compacted filling and by measuring the length and breadth as required.

The mode of measurement for various types of excavations shall be as under:-

a) In case of trenches, pits and areas, measurements shall be on the basis of size of foundation & the depth of bottom of foundation (bottom of bed concrete if provided) formation. Surface dressing shall be measured in plan projection only.

b) In case of pipe trenches and drains, measurement of width of trench shall be diameter of the pipe plus an allowance of 50 cms. to allow for collars, flanges etc.

c) The relevant clauses of IS Code and/or PWDSOR shall be applicable.

2.9 Sub-grade conditions

Sub soil investigation report will be provided by WBSEDCL, if sought for by the Contractor in writing.

2.10 Brick Soling

Where brick soling is required to be provided, it shall conform to the following specifications:-

It shall be flat of the bricks touching each other as per item. Soling shall be closely packed leaving no interstices or gaps. The interstices to be filled with fine sand and shall be sprayed with water. If crevices appeared between two bricks after spraying with water it shall be mended again by spreading fine sand.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

3. CONTROLLED CONCRETE, PLAIN & REINFORCED CONCRETE

3.1 General

Concrete and reinforced concrete work shall be carried out generally in conformity with the latest Indian Standards IS : 456 except for provisions indicated herein below. All work is to be carried out with utmost precision and up to date scientific know-how and the Contractor shall employ thoroughly competent staff to achieve the highest standards.

3.2 Cement

- Cement for the work shall be either of ordinary Portland Cement conforming to the latest Indian Standards IS:8112 – 1989 for 43 grade and IS 12269 -- 1987 for 53 grade or Portland Pozzolana Cement conforming to IS 1489 (Part 1) 1991- specification (fly ash based), IS 1489 (Part 2) 1991 - specification (Calcined clay based) or Portland Slag Cement as per IS:455 (with latest revision), as instructed & approved by the E-I_C and/or Technical Controlling Officer for the work and of the best normal setting quality unless a quick setting quality is expressly instructed in the specifications or otherwise during the course of the work by WBSEDCL. If directed the Contractor shall purchase Portland cement as fresh as possible after manufacture and where there is reason to believe the cement has been long stored, WBSEDCL may demand a Laboratory Test Certificate regarding the character of cement and the Contractor shall furnish the same at no extra cost. WBSEDCL shall reject any cement which in its opinion does not meet the required standards.
- The list of manufactures for cement shall be as per the list provided in the bid document and/or PWDSOR and/or as instructed in writing by WBSEDCL.

Any field or laboratory test for cement, if asked for by WBSEDCL shall be carried out at the risk and cost of the Contractor as per provision of relevant IS codes.

All bags and containers in which cement is packed shall be stored in a dry, weather-tight, properly ventilated structure with adequate provision against absorption of moisture. The Contractor shall at all times maintain for the inspection of WBSEDCL, a log book indicating the receipt of cement, brand and agent from whom obtained and the age of cement. Cement which has caked or perished by being wet or otherwise shall on no account be used on the work. Cement shall be consumed on the works in the same sequence as that of their receipt at site. Cement reclaimed from cleaning of bags or from spillage from containers or otherwise shall on no account be used. The cement is to be stacked in an orderly and accessible way to permit WBSEDCL physical verification of existing stock at all points of time. The Contractor has to ensure furnishing a copy of manufacturer batch test certificate along with every lot of supply.

If so felt, WBSEDCL may instruct the Contractor for further testing of cement in Govt. laboratories/testing houses as has been detailed in the relevant clause of GCC, over and above the submission of test certificates at the risk and cost of the Contractor.

3.3 Sand

Sand: fine aggregate shall generally conform to latest Indian Standards (IS:383). Sand shall be natural sand, crushed gravel sand or crushed stone sand at the discretion of WBSEDCL. Use offseason is prohibited. It shall be composed of hard siliceous material and shall be clean and of sharp angular grit type. Sand shall be properly graded minimizing all voids.

Its grading shall fall within the limit of grading zone I , II for non-plastering work and Zone III for plastering work, of Table 1 (Ref clause no 3.1.4.3 of CPWD specifications 1996 , revised to 2000 vide page no 33 .).

Allowance for bulking of sand shall be made. Silt content on sand should not be more than 5%. Laboratory equipment such as measuring jars etc. are to be kept at site for time to time checking of bulkage and silt content.

For sand testing periodicity may be given at the rate of every 150 cum of concrete work of all kinds (apart from RMC) and part thereof. For plastering work however, a separate periodicity of testing in term of every 500 SQM of plastering of any thickness irrespective of number of coats and part thereof is to be adopted. For brick masonry one test for 100 cum or part thereof for masonry may be adopted. The tests so mentioned shall have to be carried out through reputed Central/State Government registered testing house/ laboratory and not from site testing facilities.

All tests , to carry out field as well as laboratory tests shall be borne by the Contractor .

3.4 Coarse Aggregate

Coarse aggregate shall be approved hard aggregate generally conforming to latest Indian Standards : IS - 383. The following tests should be carried out for every new lot of supply: -

- Crushing value
- Impact value
- Sieve analysis
- Deleterious material
- Flakiness index

For every 150 CUM of concrete work of all kinds (apart from RMC) and part thereof one test shall be carried out.

All costs to carry out field as well as laboratory tests shall be borne by the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

3.5 Types of concrete, strengths etc.

The Bill of Quantities specifies M20 grade of reinforced cement concrete. The strength corresponding to this grade is given as under :-

TYPE OF CONCRETE

Sl. No.	Type of concrete	Characterize design strength N/mm ²	Target design strength N/mm ²
1.	M - 20	20	≥27

Even though the Bill of Quantities specified various types of concrete, it is possible that the type may be altered to suit the site conditions. The compressive strength indicated above pertains to pressure test on works test cubes 15 x 15 x 15 cm. after normal curing for 28 days. The strength of preliminary test cubes shall be as per IS :456 (latest revision)

Sufficient number of cube mould should be kept ready at site . Relevant IS code of Specification and PWDSOR shall have to be followed.

The type of concrete for any particular situation or work shall be as per instructions given to the Contractor by WBSEDCL notwithstanding anything contained in the foregoing clauses.

3.6 Water

Water conforming to IS 456 - 2000 for all concrete work shall be clean, free from deleterious matter such as oils, acids, alkalis, sugar and vegetable matter. Every attempt shall be made to use potable water. Water storages facilities provided by the Contractor shall be maintained properly to preclude contamination of water by any of the harmful substances. WBSEDCL may instruct the Contractor to carry out test of water sample as per provision of relevant IS code, in Govt. laboratories and the Contractor shall comply the same at his risk and cost. The quantity of water to be added to concrete for mixing shall be such as to afford workability consistent with strength. Water/cement ratio shall be recorded in every batch of concrete. Arrangement for slump cone test shall be kept at site to arrive workability whenever WBSEDCL wants to check at site. The periodicity of testing may be conducted as once in six weeks and part thereof or as specifically instructed by the Owner.

3.7 Tests for determination of strength of Reinforced concrete

As will be apparent from the Bill of Quantities, the strength of concrete specified is the criterion and the Contractor shall make every effort to obtain the specified strengths by good quality control. In case of concrete which does not obtain the specified strength at 28 days, such work shall be demolished and reconstructed to obtain the requisite strengths all as directed by WBSEDCL. To determine whether concrete in any particular part of the work is of the requisite strength or not, test cubes (works test cubes) shall be made from samples collected from the concrete being poured for the particular part and determined as per acceptance criteria detailed hereinafter. The salient features for the collection of samples is as indicated below:

3.8 Testing of Concrete Cubes for determining Compression Strength for Reinforced Concrete Work at own cost

3.8.1. Quality as specified.

3.8.2. Compression Strength shall be as specified for the particular type of concrete.

3.8.3. Criteria for acceptance of work

The test and acceptance criteria shall comply to relevant IS codes including IS :456 Part 1 or element of concrete work shall be deemed to be acceptable, provided the three cubes tested for 28 days strength conform to the following :

3.8.3.1 Average of the three cubes strengths shall not be less than the specified strength.

3.8.3.2 No individual cube strength shall be less than 90% of the specified strength.

3.8.3.3 If any individual cube strength exhibits more than 133% of the specified strength, such cube shall be classified as freak and criteria in 1.3.9.3.1 and 1.3.9.3.2 above, shall be applied for the remaining two cubes only and the acceptability determined.

3.8.4 Quantum of cubes and testing

The decision of WBSEDCL in this regard shall be final and binding. Cube testing shall be done at site regularly and at least 20% of this testing shall be carried out in the reputed laboratory (as approved by the Owner) as defined in the relevant clause of GCC.

Testing machine with valid calibration certificate to be kept at site for crushing of cubes. The testing shall be duly witnessed and approved by WBSEDCL.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

All costs to carry out tests at field as well laboratory shall be borne by the Contractor.

3.9 Making of non-RMC concrete

All mixing of aggregates, cement and plasticizer shall be done by volume which is equivalent to design mix. All the necessary equipment such as measuring boxes, devices for determination of moisture and bulk in sand, slump cone etc. shall be provided by the Contractor. Concrete shall be machine mixed until there is a uniform distribution of materials and uniform colour and consistency is achieved and under no circumstances for less than two minutes.

A wooden board approximately 30 cms. x 40 cms. shall be put up at the concrete mixer on which shall have been legibly written in English and the local language, the quality of concrete that is being mixed, the proportions and other relevant data.

3.9.1 Cubes

The size of cubes to be prepared and tested shall be 15 x 15 x 15 cm. (6" x 6" x 6").

The minimum number of cubes to be collected from each sample as detailed below shall be six. Three cubes each are intended for testing at 7 and 28 days respectively and determining the strength.

Cubes tested at 7 days should give strength of not less than 70% of the corresponding strength at 28 days. It shall however be expressly understood that the test results at 28 days only shall govern and the 7 days tests are intended to obtain a fair idea only.

Relevant IS codes including IS : 456 (latest revision) shall be followed by the Contractor . All costs for sampling and field as well as laboratory testing shall be borne by the Contractor.

3.9.2 Number of tests

The number of cube tests in a work shall be entirely guided by the relevant IS Codes and/or at the discretion and as directed by the Controlling Officer of the work. Cubes shall generally be collected for various structural members and also for works at various levels. It shall also be collected whenever the usual quality for a particular strength is in suspect. The number of cubes may at most be twelve or even more as instructed by WBSEDCL and as per provisions of relevant IS code on any given day in a particular work. However, in case other important casting works are running in parallel with a major concreting work, additional cubes in the range of six or twelve shall be taken for each of them as well.

3.9.3 Preparation and Testing of Cubes

Casting of cubes, preparation of moulds for the same, processing and curing the cubes and pressure testing the same shall be as per detailed instructions which will be issued to the Contractor from WBSEDCL from time to time or as per relevant Indian Standard as amended upto date as directed. All costs including construction of vat for curing of cubes at site shall have to be borne by the Contractor.

3.9.4 Equipment modules, testing etc.

It is the entire responsibility of the Contractor to prepare and get the cubes tested and provide for all material, labour, modules, equipment, facility and charges for sampling, testing, curing etc. The Contractor's quoted rate work shall be deemed to include for these and no extra payment whatsoever is admissible on this account.

3.9.5 Slump

If in the opinion of WBSEDCL, slump cone tests are required to be performed to establish workability the same shall be carried out at free of cost. Slump tests are however, to serve as guide only.

3.10 Transporting and pouring of concrete

No mixing of concrete shall be started unless the situation where they are to be poured are prepared and kept ready. Concrete shall be poured immediately on preparation. Transporting of concrete shall be done as speedily as possible and also in a manner to prevent segregation of aggregates. No re-tempered concrete shall be allowed to be used on the works. No concrete shall be allowed fall through a height more than 1.20 M. where the concrete to be placed from more height it should be done through chute as per relevant IS specification and as directed by WBSEDCL.

Before fresh concrete is placed against an already cast and hardened section, such surfaces shall be roughened, swept clean, moistened with water and treated with cement slurry. Fresh concrete shall then be poured as required. Under no circumstances, concrete mixed more than stipulated initial setting time as per IS code shall be used. Dewatering of excavations for concreting where necessary shall be carried out by the Contractor as directed and the rates quoted by the Contractor are deemed to be inclusive of such dewatering. No concreting shall be done in adverse weather condition, except exigencies with proper precautions or prior approval from WBSEDCL.

3.11 Ready Mixed Concrete

If allowed and approved by WBSEDCL, the Contractor shall buy the RMC from a manufacturer approved by the Owner. The Contractor in association with the manufacturer will make a suggested trial mix with correct water cement ratio, slump and workability. To verify this, the test cubes from the concrete used should be made and tested. The tests results will determine the cement content and water cement ratio that produces the required strength. If the test result satisfies the WBSEDCL this mix design shall be followed throughout the work for RMC work, until and unless there is variation in shape



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

and size of coarse aggregate, fineness of fine aggregate, cleanliness moisture content etc. The design mix as per stipulated strength of concrete mentioned in this technical specification shall be approved by the Consultant or any other designated authority as directed by WBSEDCL.

RMC will be supplied by manufacturer at site from a mixing area by transit mix trucks. The Contractor will get an assurance from manufacturer that initial setting will not start during the distance to be travelled from batching plant to job site. Again the Contractor will take a written statement from the manufacturer that within which time concrete should be delivered and discharged from transit truck mixer after the introduction of water to cement and aggregate and when the initial setting will start.

The manufacturer will also ensure that transit mix truck will discharge concrete with slump designated for the job. The time period between the discharge and placement in position should also be worked out and got approved.

The Contractor should arrange a material hoist to carry the wheelbarrow to the floors under construction for transferring of concrete and a smooth runways is to be provided for their travel to avoid any segregation or concrete mix may be carried by head load for placing of concrete as directed by WBSEDCL from the point of transfer of concrete at upper floors. During transferring of concrete to walls or deep beams baffle board, downspout or chute to be used for prevention of segregation. It is essential to closely supervise the discharging of concrete to prevent segregation at all points. The alternative approach can be to pump out the ready mixed concrete to the location. The method of pumping/placing, the W/C ratio and the plasticizer used need to be approved before commencing the operation as defined herein above in this clause.

Regular mandatory tests on the consistency and workability of the concrete after transferring from transit mix trucks at job site shall be done to achieve the specified compressive strength of concrete. The frequency of testing and the acceptability criteria will be according to I.S : 456 and I.S:516. A register of work test of concrete shall be maintained at site by the Contractor. Cube testing register in standard CTE format is to be kept at site. WBSEDCL shall decide whether a particular set of cubes would be tested at site or at a reputed central/state government registered testing house/laboratory. In any case, at least 20% of the testing would be carried out at such laboratories. The Contractor shall undertake the entire cost of transporting of cubes to such testing facilities outside the site and testing charge therein.

In general, payment for RMC shall be made on the basis of actual measurement or as per drawing whichever is less, of different reinforced concrete elements at site. If any deviation from the original drawing is required as per decision of the Controlling Officer, the Contractor shall comply with the same during execution. In such case, the payment will be made based on the actual measurement of different reinforced concrete elements or as per revised drawing issued subsequently whichever is less. No extra payment will be made for wastage during transfer of RMC at site or extra concreting done by the Contractor at his own. The rate includes the cost of materials and labour for carrying of RMC to upper floors, placing, consolidating, finishing, curing & testing etc.

The Contractor shall submit the design mix report and its further corroboration through trial cube tests (both 7 days and 28 days) from a reputed institute for approval by WBSEDCL and adoption at site. All related cost would be borne by the Contractor.

No RCC work shall be taken up till such time final test report of trial design mix is not available with WBSEDCL.

In case any admixture is used in RMC it shall conform to IS: 9103 latest edition and after obtaining necessary approval from WBSEDCL.

For RMC concreting, regular cube tests in the multiple of six (three for 7 days and three for 28 days respectively) are to be carried out as per IS: 456 (latest revision) and the works to be carried out as per stipulations laid down in IS codes and clearance by WBSEDCL. The decision of WBSEDCL shall be deemed as final in this regard.

3.12 Formwork

3.12.1 Materials and Design

a) The method and design of form work to be adopted by the Contractors is to be produced for approval of the same by the WBSEDCL before any form work is taken up.

The form work shall be of approved 12 mm. thick water proof ply surface to be in contact with concrete, to be planed smooth. In every case joints of the shuttering are to be such as to prevent the loss of liquid / water from concrete. In ply shuttering the joints shall be perfectly close and lined. Steel shuttering using hydraulic jacks shall preferably be used in all possible cases and as directed by WBSEDCL.

If any particular materials or materials be specified in the schedule of quantities for form work such particularly specified material or materials shall be used in work. The form work shall be so constructed as to remain sufficiently rigid during placing of the concrete. All shuttering and forming must be adequately stayed and braced to the satisfaction of WBSEDCL for properly supporting the concrete during the period of hardening. The forms shall have sufficient strength and rigidity to hold concrete and withstand the pressure of remaining and vibration without excessive deflection from the prescribed lines and more so when the concrete is vibrated. The surface of all forms in contact with concrete shall be clean, rigid, watertight and smooth. Suitable devices shall be used to hold corners, adjacent ends and edges of panels of other forms together in accurate alignment.

b) The form work shall conform to the shape, lines and dimensions to suit the R.C.C. members as shown on drawings and be so constructed. Form work shall be adequately designed to support the full weight of workers, fresh placed concrete without yielding settlement or deflection, and to ensure good and truly aligned concrete finished in accordance with the construction drawings. A camber in all directions of 6mm for every 5 M span in all slab and beam centering shall be given to allow for unavoidable sagging due to compression or other causes, unless otherwise specifically instructed in writing by WBSEDCL.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

c) The form work shall be as designed that the sides of the beams retain its position and does not get bulged these however should be so designed that the sides of the beams can be first struck leaving the soffit of beams and the supporting props in position. Props shall be designed to allow accurate adjustment and to permit of their being struck without jarring the concrete. No bamboo propping shall be used. Bulged section shall not be accepted and need to be rectified or rebuilt as per instruction of WBSEDCL. No extra claim, in any case shall be entertained by WBSEDCL.

d) Temporary openings shall be provided at the base of columns forms and at other points where necessary to facilitate cleaning and observation immediately before concrete is deposited.

e) Unused and new waterproof ply of 12 mm thickness is to be sited only and it shall be good enough to withstand a maximum of 5 (five) repetitions. In case in the opinion of WBSEDCL the formwork is seen to be no longer in order even before undergoing the maximum permissible 5 (five) repetitions, the same would be rejected and forthwith removed from site.

f) Vertical Shuttering

The vertical shuttering shall be carried down to such solid surface and is sufficiently strong to afford adequate support and shall remain in position until the newly constructed work is able to support itself. Props shall be securely braced against lateral deflection. Where timber props are used like bullies, they shall be a minimum diameter of 10cm. and shall be straight and adequately strong. The spacing of such struts shall be designed to carry to carry loads imposed on it without undue deflection of the members supported by the props. The spacing of props shall be approved by the WBSEDCL and any alterations suggested by him shall be carried out at Contractor's expense. Bracing shall be provided as directed without extra cost. Contractor shall allow in his rates for providing props and struts for any height shown in the working drawings issued to Contractor from time to time.

g) Curve & Circular shuttering

Unused and new waterproof ply of 6 mm thick supported by good quality wooden batten shall be used. Repetition of the material will be same as stated above for the other shuttering.

3.12.2 Water Tightness

It is the Contractor's responsibility to ensure that the forms are checked for water tightness just before concreting operation starts and to make good any deficiencies.

3.12.3 Cleaning and Treatment of Forms

All rubbish, particularly chippings, shavings and saw dust, shall be removed from the interior of the forms before the concrete is placed and the form work in contact with the concrete shall be cleaned and thoroughly wetted or treated with an approved composition. Care shall be taken that such approval composition is kept out of contact with the reinforcements. Interior of all moulds and boxes must be thoroughly washed out with a hose pipe or otherwise so as to be perfectly clean and free from all extraneous matter previous to the deposition of concrete.

Prior approval of the form work should be taken from the WBSEDCL before placing reinforcements on form work. No concrete shall be commenced until the WBSEDCL has inspected the form work and until his approval is obtained. A notice of at least 24 hours shall be given to the opinion of the WBSEDCL any materials is not accordance with the specification or the form work, is wrongly done or otherwise defective the Contractor shall immediately remove such materials from site and replace the same and rectify any other defects in accordance with the instruction of the WBSEDCL and to his entire satisfaction.

The lines, levels, form work, reinforcement etc shall be checked by the Contractor with subsequent approval / checking by WBSEDCL prior to allowing of concreting , by WBSEDCL . However, the cost, labour etc for such checking shall be borne by the Contractor and this will not relieve any of the obligations under this contract.

3.12.4 Stripping

Forms shall be left in place and removal shall be done as per norms laid down in IS codes and as instructed by the WBSEDCL and shall then be removed with care so as to avoid injury to concrete. In no circumstances shall forms be struck until the concrete reaches a strength of at least twice the strength as to which the concrete may be subjected at the time of striking. The strength referred to shall be that of concrete using the same cement and aggregates, with the same proportions, and cured under conditions of temperature and moisture similar to these existing on the work. Where possible, the form work should be left longer as it would assist the curing. Exposed surfaces of concrete which are indicated/ required to be plastered shall be roughened with wire brushes and hacked out closely immediately after removal of formwork by free of cost.

Any honeycomb , appeared after removal of form work shall be mended as per procedures laid down in IS codes including pressure grouting required , if any, as instructed by WBSEDCL with risk and cost of the Contractor without any further claim.

3.12.5 Stripping Time

In normal circumstances (generally where temperature are above 20°C) and where ordinary cement is used, forms shall be struck after expiry of the following periods and as per relevant IS code , CPWD manuals unless otherwise directed at site by WBSEDCL.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

3.12.6 Form Work In Lift For Continuous Surfaces

Where forms for continuous surface are placed in successive units, (as for example in columns or walls) the forms shall fit tightly over the completed surface so as to prevent leakage of slurry from the concrete and to maintain accurate alignment of the surface.

3.12.7 Procedure While Removing The Form Work

All form work shall be removed without such shock or vibration as would damage the reinforced concrete. Before the soffit and strata are removed the concrete surface shall be exposed where necessary in order to ascertain that the concrete has sufficiently hardened. Proper precautions shall be taken to allow for the decrease in the rate of hardening that occur with all cements in the cold-weather.

3.12.8 Tolerances

The following shall be the maximum permissible tolerance:-

- a) On general setting out dimensions upto 4 M. in length a tolerance upto 3mm will be allowed.
- b) On lengths of more than 4 M. tolerance of not more than 5mm will be allowed.
- c) On the cross sectional dimensions of columns, beams, slabs, faces, chajjas, mullions, grills, fins, louvers, and such other members tolerance more than 2mm will not be allowed.
- d) The top surface of concrete floor slab will be within plus/minus 3mm of the level and line shown on the drawings.
- e) Columns and walls and other vertical members shall not be more than 3mm out of plumb in their storey height and not more than 6 mm out of plumb in their full height.
- f) If work is not carried out within the tolerance set out above (a) to (d) the cost of all rectification measures of dismantling and reconstructing as decided by the WBSEDCL shall be borne by the Contractor. In case of work dismantled, the same shall not be measured and no payment even for cement and reinforcement shall be allowed.

3.13 Consolidation and processing of concrete

Concrete for all works shall be compacted by means of suitable vibrating equipment. One or more spare vibrators which are in complete working condition shall always be kept ready at sites to be put into commission in case of failure of the vibrators under use. The vibrators shall be operated by skilled personnel, thoroughly instructed as regards the mode, frequency, duration etc. regarding vibration. Concrete of low volume/ quantum for a particular work may however, be permitted by WBSEDCL at their sole discretion to be consolidated by hand only after prior permission.

3.14 Finish to concrete surfaces

Finish to concrete surfaces at various situations shall be as per directions of WBSEDCL. Where form finish is specified, the final surface shall be smooth and even and no-undulations, ridges, spots etc. shall be permitted. They shall be laid to pattern as directed. In case surfaces intended and directed for form finish, exhibit any of the defects above mentioned, the surfaces shall be rubbed with carborundum or plastered and finished all as directed at the risk and cost of the Contractor. The decision as to the acceptability or otherwise of a surface will be notified by WBSEDCL and the Contractor will implement the instructions accordingly.

3.15 Concrete cover for reinforcement

Where not specifically indicated in the drawings, concrete cover for reinforcement shall be as per the latest Indian Standards IS 456 - 2000 and as per directions at site from time to time. Proper concrete cover blocks adequately cured to suit various covers as required shall be provided in adequate numbers sufficiently ahead of the work.

3.16 Construction joints

Construction joints in concrete work shall be provided as far as possible only at predetermined places as per direction and in consultation with WBSEDCL. Joints shall be provided as specified in latest Indian Standards or as directed by WBSEDCL.

3.17 Curing

It is very important that all cement concrete work shall be cured properly. All concrete work shall be kept continuously in a damp or wet condition by pouring or by covering with a layer of moist sack, canvas, hessian or similar material for a period as stipulated in the relevant IS codes and specifications from the date of concreting. Water used for curing shall also be free from any deleterious substances and shall generally be fit for drinking. The work shall be adequately protected from drying, winds and direct sun rays. The Contractor should arrange at his own cost a temporary water supply line with provision of centrifugal pump, valves etc. for curing and constructional purpose at higher level. A sample sketch is enclosed for the reference purpose.

3.18 Openings and inserts

All openings and inserts which are designated in due time or as required for services, will be exactly provided by the Contractor. The Contractor should also fix the anchors or such items which may be supplied by the Proprietor in exact position and in perfect lines and levels. Inserts apply to such items as timber, dowels, bolts, loop, brackets, suspension irons, hooks, screws, plates, pipe of various types and diameter etc. etc. Openings in concrete or masonry must



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

be provided in exact location to correct shape, size and depth or slightly bigger, if directed so, as shown in drawings or as instructed. It must be clearly understood that the provisions of inserts and openings as contemplated in this contract are to be carried out with "utmost precision" and any deviation of the same from that as shown in drawing or instructed, have to be rectified by the Contractor at his own cost and responsibility. The Contractor should make provision of openings to deep beams and their members at bottom or at lower level as necessary for cleaning purpose prior to concreting.

3.19 Tor Steel Reinforcement

TMT bar for reinforcement shall be of tested quality and shall conform to the relevant Indian Standards (IS: 1786). Reinforcement shall be fabricated to shapes and dimensions shown on the drawing and shall be placed where indicated on the drawings or required to carry out the intent of drawing and specifications or as directed by WBSEDCL. Before placing, reinforcement shall be thoroughly cleaned of loose rust, coating etc. which would result in reducing or destroying the bend. Oiling the bars to clean them is strictly prohibited. Bending, straightening, cutting etc. operations shall be carried out in a manner not injurious to the material. List of manufacturers for reinforcement shall be as per BOQ and/or as per PWDSOR (Latest amendment) and/or list given in the technical specification of the "Bid Document" and finally, as instructed in writing by WBSEDCL.

All reinforcement shall be bent cold. Unless otherwise directed, reinforcement shall not be spliced at points of maximum stresses. WBSEDCL shall be informed well in advance before such splicing is taken up. Laps and splicing shall conform to the latest Indian Standards.

Reinforcement shall be accurately tied at all intersections and laps with 16 SWG soft drawn binding wire, such that the reinforcement will give a rigid structure. Binding wire will not be measured or accounted for separately. The Contractor's rate for reinforcement will be measured and paid for according to bending lists without allowances for cutting, wastages, binding wire etc. Authorized laps, hooks, chairs, spacers etc. shall, however be accounted for. In case, the Contractor or WBSEDCL desires to resort to welding, there shall however be made as if the laps have been provided and no extra claim whatsoever shall be admissible on this account. The relevant IS code and schedule of specification shall be followed and applicable for the case also.

Reinforcement shall be assembled in place with proper concrete cover blocks to suit various covers as required.

The Contractor has to ensure furnishing of manufacturer certificate with every lot of supply.

If felt necessary, WBSEDCL may ask for testing of reinforcement sample, over and above, submission of manufacturer's certificate, in Govt. laboratories/ testing houses as detailed in the relevant clause of GCC, at the risk and cost of the Contractor.

4. MASONRY AND PLASTERING

4.1 Materials

4.1.1 Bricks

All bricks shall be table moulded, burnt bricks of crushing strength not less than 75 kg/Sq cm. They shall be hard sound and well burnt with sharp edges and of uniform sizes and shapes. Bricks shall be neither under-burnt nor over-burnt and shall be free from cracks, stone floats, or other such defects as defined in relevant IS code and relevant schedule of specification.

When immersed in water for 24 hours, bricks shall not be absorbing more water than 20% of its dry weight. All bricks shall be identical/equal to samples submitted and approved by WBSEDCL before the commencement of the work. Metallic sound of brick is also a criteria.

4.1.2 Cement and Sand

Cement and sand used for masonry and under the heading plastering work shall conform to the specifications laid down under the heading "Plain and Reinforced Concrete" as per clause of 1.3 above and relevant IS code, PWDSOR and schedule of specifications.

4.1.3 Additives

Additives, like integral waterproofing compounds, shall be of the approved type from reputed manufacturers and as per instruction in writing by WBSEDCL. These shall be used strictly in accordance with the manufacturer's instructions/specification. The additives shall conform to IS: 9103.

4.2 Samples

When demanded by WBSEDCL, the Contractor shall produce samples of materials or carry out samples of work for WBSEDCL approval. All materials used as also works carried out shall conform to the quality of approved samples. Production of these samples shall be at Contractor's cost. However, approval of samples by WBSEDCL shall not relieve the Contractor's obligation of the Contract during entire period of Contract.

Testing of bricks shall be carried out in respect of dimension, crushing strength, water absorption and efflorescence in a standard sample size of six bricks. The periodicity of testing may be taken as once for every 50 CUM of brick masonry of nominal thickness not less than 250 mm and part thereof. Similarly for half brick masonry once for every 500 sqm and part thereof. These tests shall be guided as per relevant IS code and CPWD specifications at the risk and cost of the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

4.3 Brick masonry

Brick shall be soaked in clear water for at least six hours in a vat before use. Bricks shall be laid in English bond unless specified otherwise. No half or quarter brick shall be used except as closers. Brick shall be accurately raised to plumb.

Brick work shall be raised uniformly all round and no part shall be raised more than 1 metre above another at any time, and the work shall be properly toothed and raked back. In case of 125 mm. thick brick walls, wire mesh shall be provided in every third course as per relevant specification and as instructed by WBSEDCL. The wire mesh shall be properly bedded in mortar, as directed.

Joints in brick work shall not be more than 10 mm. thick. Brick work shall not be raised more than 10 courses a day. The work shall be kept watered thrice a day for 10 days and afterwards twice a day for 3 weeks. All joints shall be thoroughly flushed with mortar at every course. Care shall be taken to see that bricks are properly bedded and all vertical joints completely filled to the full depth. The jointed of brick work shall be raised out to a depth not less than 10mm. as the work proceeds. The surface of brick work shall be cleaned down and watered properly before the mortar sets.

4.4 Plastering

Plastering work in general shall proceed from top to bottom. An entire unobstructed area shall be plastered in one operation. The surface to be plastered shall be thoroughly cleaned, watered and roughened to provide key. Joints in brick work shall be raked out and cleaned. The surface shall be watered and well wetted for at least 24 hours before the commencement of work.

The entire plastered work shall be truly vertical and to proper lines and levels. All exposed angles shall be carefully flushed to provide neat and even surface. Any work that does not conform to approved samples or is not to the satisfaction of WBSEDCL shall be rejected and the Contractor shall be liable to redo the work at his own cost.

Cement sand plaster will be used. Sand will be coarse or fine (Zone-III).

Where waterproofing compound is specified to be provided in mortar for plaster, approved integral waterproofing compounds shall be used. These shall be used and plastering work shall be carried out strictly as per manufacturer's recommendations.

4.5 Measurements

4.5.1 General

All the rates quoted by the Contractor shall be for a fully finished item of work and shall include for all material, labour, miscellaneous works like storage, loading/unloading, scaffolding, hoisting gear etc. as also all taxes, duties, overheads, profits, etc. complete. The measurement of all items shall be guided by relevant provisions of the GCC and specification, in general.

4.5.2 Masonry

Accounts on masonry shall be settled on the basis of cubic metres or square metres as indicated in the Bill of Quantities. Quantities will be decided on the basis of pertinent plans. Openings and recesses which exceed 0.10sqm. will be deducted from quantities. Openings left initially on specific instructions or as required shall be closed at a later date, if so instructed by WBSEDCL, at no extra cost. Similarly, all openings, recesses, grooves etc. shall be provided at no extra cost.

4.5.3 Plastering

Accounts on plastering shall be settled on the basis of square metre, as arrived at from pertinent plans and for a particular type of plaster. Accounts shall be settled on the basis of dimensions of raw structure.

Grooves, notches, drip notches etc. shall be provided in plaster free of cost, wherever indicated by WBSEDCL or shown in drawings. Similarly, no special compensation shall be paid for plastering in recesses, grooves, etc. shall be accounted for under relevant item of work. However, providing cleavage or similar miscellaneous works shall be deemed to have been included in the rates quoted by the Contractor and shall not be separately paid for.

5. DOORS

5.1 Wood Work

The work consists of supply of materials, fabrication, joinery, carpentry, delivery and erection at site on wooden door and window, flush doors as specified in Bill of Quantities. The measurements, materials etc shall be guided by relevant IS code and relevant specification.

5.1.1 Materials

Timber shall be best quality teak locally available or well seasoned Sal wood (as per BOQ) uniform in texture, free from large, loose dead or cluster knots, waves injurious open shakes, discoloration, soft or spongy spots. It shall have uniform color, reasonably straight grains and shall be free from all defects.

All samples of wood work shall be got approved by WBSEDCL before bringing in bulk quantity at site and the samples shall be kept at site for future reference. Samples of wood may be sent for testing in Govt. laboratories / testing houses, if instructed by WBSEDCL at the risk and cost of the Contractor. The tests shall be governed by relevant IS codes and



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

relevant specifications. Necessary test certificates shall have to be submitted, if asked for by WBSEDCL irrespective of further testing of samples as detailed above.

Wood work abutting against or embedded in masonry or concrete shall be painted with a coat of solignum paint before being placed in position. No wood work shall be painted prior to checking and subsequent approval by WBSEDCL.

5.1.2 Fixing/erection in position of door frames

Before the frames are fixed in position, these shall be inspected and passed by WBSEDCL. The frames shall be placed in proper position and fixed to the walls with suitable holdfasts/clamps as per IS Code and relevant specification as shown in drawing.

In case the door frames without sills the vertical members shall be buried in floor 50 mm. deep at least. `Sills shall be provided where so directed. The door frames without sills while being placed in position shall be provided with temporary wooden bracings well wedged between the styles at the sill level. The sills shall be retained to keep the frames from warping during construction. These frames shall also be protected from damages during construction.

5.1.3 Shutters (Block Board)

Flush doors shall be solid core type with commercial or decorative faces. All flush door shall be obtained from approved manufacturer. This should be solid core with 1 mm thk. decorative laminates on both sides of approved shade & quality as desired by WBSEDCL and as mentioned in the approved list of materials with teak wood lipping all around and bonded with phenol formaldehyde synthetic resin as per IS specification. The specification generally should conform to I.S.2202/1966. Necessary test certificates shall have to be submitted by the Contractor, if asked for by WBSEDCL. Samples shall be approved well in advance prior to bringing in bulk quantities at site. Rejected materials shall be removed from site within 48 hours.

5.1.4 Tolerance

Tolerance on width and height shall be + 2mm and on thickness it will be + 1.2mm. The thickness of shutter shall be uniform throughout with a variation not exceeding 0.8 mm. when measured at any two points.

5.1.5 Adhesives

Only synthetic resin adhesives conforming to IS No.IS-851/1964 or latest amendment shall be used for bonding core members to one another including core frame and other exposed parts. The adhesive used for bounding cross band to core and face veneers to cross band shall conform to IS:848/1957 (Phenolic and Aminoplastic), or equivalent IS standards with latest amendment.

5.1.6 Fittings

Fitting shall be of Stainless Steel made of approved manufacturer.

The sample of fittings to be actually provided in a particular work shall however be approved by WBSEDCL prior to bringing in bulk quantities at site. Approved samples shall be kept at site for any reference.

Screws used for fittings shall be of the same metal.

The rate quoted for doors shall include all necessary hardware and screws as generally required to complete the job, as specified in the relevant items of BOQ and as per IS Code and relevant specifications.

5.2 Measurement

The rate quoted by the Contractor under for the entire work is applicable for a complete finished item and no claims by the Contractor in this regard shall be admissible. Supplying and fixing of all the fittings and iron mongery shall be deemed to have been covered by the relevant item of the S.O.W./B.O.Q and consequently, shall not be paid for separately.

6. FLOORING

6.1 Kota Stone Flooring, Dado & Skirting

Kota Stone shall be of selected quality, hard, sound, dense and homogenous in texture free from cracks, decay, weathering and flaws. They shall be hand or machine cut and shall be of approved colour of even shade as far as permissible. The stones having yellowish strips, dent, black patch and broken edges shall not be used. The slabs shall conform to the sizes of 600 mm. x 600 mm. or as required and shall be laid to pattern as directed. The edges will be perfect vertical and in right angled to each other. Minimum thickness of slabs shall be 20 mm. and the minimum thickness of floor finish including bedding mortar shall be 40 mm or as specified in the relevant items of BOQ and IS specification. The floor surface to be tiled shall be closely picked or hacked and thoroughly watered and cleaned. Mortar for bedding shall be 1 part of cement, 4 parts of sand with a layer of neat cement slurry. The stone slabs shall be laid on this bedding immediately and as each stone is laid it shall be taped with a wooden mallet and set. Flush joints shall not exceed 1 mm thick and shall be as per pattern indicated by WBSEDCL. The joint shall be set close with white cement, stone dust, adhesive and admixture of pigment matching the shade of kota stone. After the work has set, the surface shall be machine polished to the satisfaction of WBSEDCL. The final polished surface shall then be washed of all dirt, mortar, etc. by using Oxalic Acid and handed over in a neat condition. Measurement will be taken on finished dimensions. Before the start of kota laying work, approval should be taken from WBSEDCL on the sample work and the approved sample(s) shall be kept at site for ready reference. For dado, 1200mm high, 300mm wide and 20mm thick Kota shall be fixed in wall, raised from the plastered surface matched with floor joints or as directed by WBSEDCL.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

6.1.1 Rate quoted by the Contractor shall be deemed to include all labour, materials and equipments, cleaning the sub-base laying mortar bed and cement grout and fixing marble slabs and making the joints and polishing and shall also include:

- a) Any cutting and waste if required.
- b) Curing
- c) Cleaning the floor and wall from all stains etc complete.

6.2 Ceramic Tile Flooring and Dado/Skirting :

6.2.1 General

This item relates to the furnishing of materials and installations of ceramic tiles in flooring, dado, etc. Tiles shall conform to IS : 15622 and workmanship shall be per IS : 1443.

6.2.2 Materials :

The ceramic tiles shall be of high quality of approved manufacturers as specified by WBSEDCL. The size of tiles shall be as specified or as directed in the drawing and shall be of appropriate minimum thickness as mentioned in the item of ceramic tile flooring & dado in BOQ. No chipped, cracked, crazed or warped tiles shall be used. Glazed rounded corners and cups (convex or concave) shall be provided at corner of walls, edge, junctions of floor and dado etc., if so specified. The mortar shall be in the proportion 1:4. (Cement : Sand)

6.2.3 Laying:

The fixing shall generally conform to IS : 1443.

6.2.4 Workmanship :

The surface to be covered shall be plastered rough to a thickness of 12 mm. Fix 12 mm size stone chips (5 nos. one in each corner and one in the middle of each tile with Adhesive viz., Araldite of equivalent for keying action) or with approved chemical of reputed brand and the tiles shall be soaked in water for at least 2 (two) hours prior to fixing at site. A thin layer of cement paste shall be buttered on the back of the tile and on the side after which the tile shall be pressed and tapped home taking care that the corner tiles are perfectly matching. After the backing coat has set the tile joints shall be grouted with neat, white cement slurry with necessary pigment. All surplus slurry that remains on the surface shall be carefully wiped off before it sets. Care shall be taken to ensure that the finished surface is absolutely plumb and to proper levels without any profusions, waviness or zigzag. Joints between tiles shall be uniform in straight level lines. After completion of the entire work or part of it, the surface shall be cleared of all stains, cement etc., by washing with oxalic acid (1:10) or any other approved compound.

6.2.5 Fixing tiles for Dado and Skirting / Facia: -

The dado work, shall be done only after fixing the tiles / slabs on the floor. The approved glazed tiles before laying shall be soaked in water for at least 2 hours. Tiles shall be fixed when the cushioning mortar is still plastic and before it gets very stiff.

The back of the tile shall be covered with this layer of cement mortar 1:3 using fine sand (table III, zone IV, IS383-1963), and the edge of the tile smeared with neat white cement slurry. The tile shall then be pressed in the mortar and gently tapped against the wall with a wooden mallet. The fixing shall be done from bottom of wall upwards without any hollows in the bed of joints. Each tile shall be as close as possible to one adjoining. The tiles shall be jointed with white cement slurry. Any thickness difference in the thickness of the tiles shall be arranged out in cushioning mortar so that all tiles faces are in one vertical plane. The joints between the tiles shall not exceed 1.00 mm in width and they shall be uniform.

While fixing tiles in dado work, care shall be taken to break the joints vertically. The top of the dado shall be touched up neatly with the rest of the plaster above.

After fixing the dado / skirting etc. they shall be kept continuously wet for 7 days.

If doors, windows or other openings are located within the dado area, the corners, sills, jambs etc. shall be provided with true right angles without any specials. The Contractor will not be entitled to any extra claims on this account for cutting of tiles if required.

6.2.6 Cleaning

After the tiles have been laid in a room or the day fixing work is completed, the surplus cement grout that may have come out of the joints shall be cleaned off before it sets. After the complete curing, the dado or skirting over shall be washed thoroughly clean. In the case of flooring, once the floor has set, the floor shall be carefully washed clean and dried. When dry, the floor shall be covered with oil free dry sawdust. It shall be removed only after completion of the construction work and just before the floor is used.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

6.2.7 Pointing and Finishing

The joints shall be cleaned off with wire brush to a depth of 3 mm and all dust and loose mortar removed. Joints shall then be flush pointed with white cement and floor kept wet for 7 days and then cleaned. Finished floor shall not sound hollow when tapped with a wooden mallet.

6.2.8 Testing of the tiles

The tiles used for dado including border tiles are to be tested as per IS 13630 from Part I to Part 13 whichever is applicable. In the periodicity of the testing shall be one set of tiles for every 300 Sqm of dado area and part thereof. The tiles used for the flooring are to be tested as per IS 13630 from Part I to Part 13 whichever is applicable and in case of its periodicity of testing may be done as one set of tiles for every 100 sqm and part thereof. The Contractor shall submit the test certificates of the manufacturer (s). Over and above, sample testing may have to be done, if so directed by WBSEDCL, at the risk and cost of the Contractor from Govt. laboratories / testing houses.

6.3 Ceramic Mosaic Tiles

Ceramic mosaic tiles of size 25 mm x 25 mm unglazed of reputed manufacturer as approved by WBSEDCL. Manufacturing company available in sheets of 300 mm x 300 mm shall be used for external building cladding. At first, apply a coat of cement sand plaster on the external surface of 6 mm thick in a proportion of 1:3 (1 cement : 3 coarse sand) with proper leveling and alignment and check it to plumb. Then apply a coating of 4 mm thick pure cement slurry over the wet plastered surface and let the coating dry for 15-30 minutes and then use a wire brush to scratch the surface in zigzag pattern. On the un appeared side of shun mosaic tile sheet apply a thin layer of white cement in paste form and fix the sheet on the plastered wall in such a way that the papered side of the mosaic sheet faces the applicator. Let the tile fix for about 1 to 1 1/2 hours. Then wet the paper with water with a soft painting brush and peel off the paper starting from the top corner and moving down words. Clean the tile surface and apply cement paste putties with colour pigment, as required, to fill the cavities, if any and then wash the shon surface with dilute hydrochloric acid and water combined solution.

6.3.1 Testing of the tiles

The Contractor shall have to submit test certificates from the manufacturer (s). Over and above, the tiles used for wall including border tiles are to be tested as per IS 13630. In the periodicity of the testing shall be one set of tiles for every 400 Sqm of wall area and part thereof or as directed by WBSEDCL and as per specification.

6.4 Granite Cladding

6.4.1 Sampling

6.4.1.1 Granite need for cladding work shall be sampled and criteria for selection shall conform to IS 3376-1974 and IS 14223 (Part-I):1995 and as per CPWD specification.

6.4.1.2 Variation efface dimensions on any granite shall not exceed 1 mm in 900 mm

6.4.1.3 Total variation of thickness on any granite shall not exceed ± 3 mm

6.4.1.4 Any bow or twist on finished faces of any stone shall not vary from the plane by a dimension exceeding 1 mm in 1200 mm.

6.4.1.5 All granite, unless otherwise designed, shall stand up square at all face corners so that any deviation in length or heights dimensions is reasonably uniform.

6.4.1.6 Water absorption shall be maximum 0.5 with a dry density of 2.60 to 2.68, as laid down in relevant IS Code and specification.

6.4.2 Cutting, Drilling and Fitting

6.4.2.1 Provide holes required for anchors, cramps, dowels and other devices requires to support stone and to accommodate other items that connect to or penetrate the stone.

6.4.2.2 Include all cutting, drilling and fitting of stonework required to accommodate the work of other trades. In cutting and fitting, carefully cut and grind edges to a neat tight fit. Execute cutting in such a manner so as not to impair strength or appearance of stone. Use physical templates from the proper trade for all cutting and drilling of work.

6.4.3 Treatment of Granite

6.4.3.1 Mortar mixes, setting beds, leveling screed and joint sealant shall be as specified and to approval.

6.4.3.2 Where required granite joints shall be sealed with joint sealant.

6.4.3.3 Where required shall be grouted with Elastiment Grout.

6.4.3.4 Fabric mesh reinforcement shall be incorporated in the leveling screed exceeding 75 mm thick.

6.4.3.5 Leveling screed shall be laid to the required thickness as indicated in the Contract Drawings or as required by the Architect.

6.4.4 Setting Generally

6.4.4.1 When ready for setting, all stone units shall be clean and free from stains, dirt or dust. If necessary scrub face with mild soap and clean water applied with stiff fiber brushes. Rinse well with clean water.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

6.4.4.2 Keep exposed faces of stone units free of mortar or joint sealant. And mortar or joint sealant that gets on exposed faces shall be immediately removed. To prevent marking of stone masking tape shall be applied to either side of the joint. The materials, labour setc deemed to have been included in the rate quoted by the Contractor and no claim in this regard shall be entertained by WBSEDCL

7. WATERPROOFING

7.1 Waterproofing of underground reservoir

The waterproofing work shall be guided by relevant IS Code and relevant specifications and PWDSOR and as per BOQ also.

Proposed system (Given as guidance only):

- SikaTop Seal 107 or equivalent of reputed manufacturer as approved by WBSEDCL, acrylic, cementitious waterproof coating
- Intraplast EP or equivalent of reputed manufacturer as approved by WBSEDCL, Expanding grout admixture
- A food grade epoxy coating Sikagard 67 or equivalent of reputed manufacturer as approved by WBSEDCL, on concrete

Surface Preparation:

- Clean the PCC surface from dust, oil, grease, loosely adhering particles etc. Apply 12mm plaster (C:S::1:3) on the surface.

Application Methodology (Given as guidance):

Application methodology shall be as per manufacturer. However, as a guidance, the methodology is listed below:

- Apply two coats of acrylic cementitious waterproof coating of Sika® Top Seal 107 or equivalent of reputed manufacturer as approved by WBSEDCL, on the prepared substrate.
- A 12mm thick plaster (C:S::1:4) should be given on the waterproof coating before fixing of the reinforcements. The plaster should be prepared by mixing an integral waterproofing compound, Plastocrete Plus or equivalent of reputed manufacturer as approved by WBSEDCL, @ 100gms per bag of cement or as specified by the manufacturer.
- Drill hole up to half of the depth of the concrete and fix nozzles min. 15mm dia, 100mm long GI nozzle 1.5 m C/C in a grid pattern in the interior surface of retaining wall with the help of quick setting compound Sika 2 or equivalent of reputed manufacturer as approved by WBSEDCL.
- Extra nozzle should be provided on the construction joint.
- Inject Cement slurry enriched with Intraplast EP or equivalent of reputed manufacturer as approved by WBSEDCL - Non shrink grouting compound through the fixed nozzle in a pressure of 2.8 kg /cm² or as specified by the manufacturer (s) with the help of hand operated grouting pump. Injection operation should be executed after 28 days of concreting.

7.2 Retaining Wall (Given as guidance):

- After the release of shuttering, repair all bug or pin hole with polymer modified mortar on the exterior surface of underground retaining wall.
- Make a 20X20 groove along with the construction joint and seal the same with polymer modified mortar, specially the starter joint of the retaining wall.
- Prior to apply SikaTop Seal 107 or equivalent compound of reputed manufacturer as approved by WBSEDCL, the surface should be made SSD.
- Apply first coat of SikaTop Seal 107 or equivalent compound of reputed manufacturer as approved by WBSEDCL over prepared surface. Coating should be continued over the projected portion of the raft and also 300mm above from the G.L. Allow the coated surface air cure for 4 hrs.
- Before application of 2nd coat, surface should be wet again with the help of sprinkling water. Apply second coat of SikaTop Seal 107 or equivalent of reputed manufacturer as approved by WBSEDCL over the executed first coat.
- The coating shall be covered with 12 mm thick plaster added with waterproofing admixture Plastocrete Plus or equivalent of reputed manufacturer as approved by WBSEDCL 0.2% by weight of cement with a cement - sand mortar (1:4) or as specified by the manufacturer.
- Drill hole up to half of the depth of the concrete and fix nozzles min. 15mm dia, 100mm long GI nozzle 1.5 m C/C in a grid pattern in the interior surface of retaining wall with the help of quick setting compound Sika 2 or equivalent of reputed manufacturer as approved by WBSEDCL as per manufacturer specification complying to relevant IS Code and specification .
- Extra nozzle should be provided on the construction joint.
- Injection grouting shall be executed as mentioned above complying IS Code and specifications.

After necessary surface preparation, apply two coats of water based, epoxy coating Sikagard 67 or equivalent of reputed manufacturer as approved by WBSEDCL, on the RCC surface from inside. This is two component system, comp.A :comp.B:: 1:1 by weight and density is 1.2 kg/l or as specified by the manufacturer complying IS and CPWD specifications.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

7.3 Terrace Waterproofing

7.3.1 Proposed system (Given as guidance):

- SikaTop 77 or equivalent of reputed manufacturer as approved by WBSEDCL
- Screed with panels

Surface Preparation (Given as guidance):

- The substrate shall be rendered sound, free from contaminants such as fungus, algae, dust, etc., by removing all weak layers and cleaning with up to 5% solution of Sodium Hypochloride and using water jet.
- The drainpipe openings shall be just above the prepared substrate and if they are not, either the substrate shall be repaired or the drain pipe relocated suitably.
- Should any defect be present in the substrates, the Contractor or applicator shall carryout all the necessary rectification works and preparatory works before the installation of the specified waterproofing system at his risk and cost .
- Cracks running through the sections shall be repaired using low viscosity, solvent free epoxy injection resin system, Sikadur 53 UF or equivalent compound of reputed manufacturer as approved by WBSEDCL.
- Any surface cracks shall be chased open into a 'V' groove, and filled with Sika Latex or equivalent compound of reputed manufacturer as approved by WBSEDCL, modified cementitious mortar. In case the cracks are " Live " , it is recommended to seal the same with a flexible single component polyurethane sealant Sikaflex or equivalent compound of reputed manufacturer as approved by WBSEDCL, Construction after opening up the joint in a V groove at risk and cost of the Contractor ..
- Special attention shall be given on substrate preparation on the internal surfaces of drain pipe openings to ensure it is carried out to properly.
- The detailing at the penetrations of any pipes, cables, air-con mountings, etc., shall be carefully carried out as specified in the drawing or as directed by WBSEDCL .

Application Methodology (Given as guidance):

- The prepared substrate shall be treated with SikaTop Seal 107 or equivalent compound of reputed manufacturer as approved by WBSEDCL, a two component acrylic polymer modified, cementitious, ready to use waterproofing slurry in two coats at right angles to each other and taking the coatings over the vertical parapet up to at least 300mm on the exterior surface of the parapet and as per manufacturer's specification or as directed by WBSEDCL.
- Special care shall be taken to ensure proper coating of the inner surfaces of the drain openings in the parapet wall
- When the cementitious membrane is dried, an acrylic bond coat of SikaTop 77 or equivalent of reputed manufacturer as approved by WBSEDCL shall be applied. When the bond coat becomes tacky, the treated roof area shall be laid with avg. 75mm thick concrete screed admixed with the waterproofing admixture, Plastocrete Plus or equivalent compound of reputed manufacturer as approved by WBSEDCL, ensuring that the screed gently slopes towards the drain pipes. The concrete screed should be cast in panels of 2mx2m maintaining 10mmx10mm groove using solvent free polyurethane pavement sealant, or as directed by WBSEDCL.
- All corners and joints such as those between the parapet wall and the roof slab, chimney and roof slab, etc shall be chamfered with 150mm X 150 mm fillet of mortar (Cement: sand – 1:4) admixed with SikaTop 77 or equivalent of reputed manufacturer as approved by WBSEDCL. Before chamfering a prime coat shall be given with the slurry of SikaTop 77 or equivalent compound of reputed manufacturer as approved by WBSEDCL.

7.4 Sunken slab waterproofing

7.4.1 Proposed system (Given as guidance)::

- SikaTop Seal 107 or equivalent of reputed manufacturer as approved by WBSEDCL, acrylic cementitious waterproof coating
- Coving with acrylic emulsion and waterproof additive SikaTop 77 or equivalent of reputed manufacturer as approved by WBSEDCL
- Sealing of pipe mouth with Sikagard 694 F (I) or equivalent of reputed manufacturer as approved by WBSEDCL, moisture insensitive epoxy putty



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Surface Preparation:

- Clean the RCC surface from dust, oil, grease, loosely adhering particles etc. and it should be rendered smooth with cement sand mortar.

Application Methodology (Given as guidance):

- A 1:3 cement – sand mortar, mixed with SikaTop 77 or equivalent compound of reputed manufacturer as approved by WBSEDCL – the polymer modified high quality emulsion, shall be installed as a coving at the corners of floor and the vertical surface in the sunken area, and between floor and walls in the remaining area.
- SikaTop Seal 107 or equivalent compound of reputed manufacturer as approved by WBSEDCL – the cementitious, flexible waterproof coating shall be applied onto the prepared surface in a continuous film on the floor of the sunken area, taking the coating over the vertical surfaces on to the floor and over the coving on to the wall (before tiling) to at least 300mm above the final finished floor level. The coating shall also be continued on to the inner surfaces of the pipe penetration holes. Two coats shall be applied. The coating shall be protected with 15mm plaster admixed with Plastocrete Plus or equivalent compound of reputed manufacturer as approved by WBSEDCL, an integral waterproofing compound @ 100gms per bag of cement. Application of compound should confirm to manufacturer's specification and as per IS and CPWD specifications .
- Tiles are to be fixed with ready to use tile adhesive for vitrified tiles, Sika Ceram (Grey) or equivalent compound of reputed manufacturer as approved by WBSEDCL.

Pipe penetrations

Where the pipes are already installed:

Sikagard 694F(I) or equivalent compound of reputed manufacturer as approved by WBSEDCL, a moisture insensitive epoxy putty shall be installed in a continuous, 10mm thick gasket around the pipes to a width of approximately 15mm.

8. PAINTING

8.1 Scope of work

The scope of work as enumerated under this tender includes painting of external plastered and concrete surface, steel work, timber surfaces, pipes, as detailed in the Bill of Quantities. The work shall be carried out as per IS Code and PWDSOR and specification and finally, as directed by WBSEDCL .

8.2 Materials

The paints to be used for this work shall be of first class quality paint of reputed manufacturers and of approved type by WBSEDCL.

8.3 Preparation prior to painting

The surfaces to be painted shall be thoroughly cleaned of all dirt, cement slurry with coir or wire brush. The slight surface cracks shall be made good with hard stopping or filled with approved compound. Special care shall be taken in case of exposed concrete or shutter finish work.

8.4 Finishing Coats

All earlier coats of paints shall be thoroughly dry before subsequent coats are applied and shall be rubbed down with fine sand paper. The finishing coats are intended generally as follows: (The exact type of finish shall be as described in Bill of Quantities).

- External wall surface -Cement based waterproofing paint/Textured paint or as directed by WBSEDCL in compliance to the BOQ.

8.5 Samples

The Contractor shall be required to prepare the sample of painting at least three different samples or combinations(each sample not exceeding approx. 4 M2 in area) at the site for approval as per the painting scheme prepared by WBSEDCL at his own risk and cost.

8.6 Mode of Measurement

All measurement unless otherwise specified in these documents shall be as per latest Indian Standard and specifications for mode of measurement.

8.7 General

The rates shall include for all materials like putty, fillets ,rubbing compound primer, paint etc. as also labour for repertory works and painting all for a completed item of work..

The work shall be done as per best engineering practice. Samples and shades of paint should be approved by WBSEDCL prior to execution of work .Consumption of materials and the special precautions etc. shall be as per manufacturer's specifications. Necessary equipment for spray painting shall be supplied by the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Guaranty /warranty for paint should be given by the manufacturer along with cross warranty for entire work by the Contractor .

8.8 Primer : All surface for painting , if they are new , should have a coat of priming before application of the paint as per relevant item of BOQ. The primer should be of approved quality as directed by WBSEDCL of ready mix primer.

8.8.1 Wood Primer: Wood primer of approved brand (by WBSEDCL) and as per manufacturer's specification is to be applied on the wooden surface which would be free from moisture and loose particles.

8.8.2 Steel Primer : For steel surface red oxide primer , zinc chromate primer of approved brand (by WBSEDCL) and is to be applied on the surface as per manufacturer's specification and as approved by WBSEDCL. The surface should be made free of grease , rust , moisture and loose particles. All blistered surface should be made free by hammering , filling or otherwise so as to have smooth surface before priming.

8.8.3 Cement Primer Coat (Alkali Resisting Primer) : Cement primer coat is to be used as base coat on wall finish of cement, lime or lime cement plaster or on asbestos cement surface before application of any wall coating e.g. oil bound distemper ,oil based paints, synthetic enamel, plastic emulsion etc. on them. The cement primer is composed of a medium and pigment which are resistant to the alkalis present in the cement , lime or lime cement in wall finish and provides a barrier for the protection of subsequent coats of oil bound distemper or paints. Priming coat shall be preferably applied by brushing and not by spraying. Hurried priming shall be avoided particularly on absorbent surface. New plaster patches in old work before applying oil bound distemper paints etc. should also be treated with cement primer. The surface shall be thoroughly cleaned of dust ,all white or colour wash by washing and scrubbing. The surface shall then be allowed to dry for at least 48 hours. It shall then be sand papered to give a smooth and even surface. Any unevenness shall be made good by applying putty ,made of plaster of Paris with water on the entire surface including filling up the undulation and then sand papering the same after it is dry. The cement primer shall be applied with a brush on the clean dry and smooth surface. Horizontal stroke shall be given first. Vertical strokes are to be applied after horizontal stroke is absorbed on wall/ ceiling surface immediately afterwards. This entire operation will constitute one coat. The surface shall be finished as uniformly as possible leaving no brush mark. It shall be allowed to dry for at least 48 hours before oil bound distemper or paint is applied. The entire process of application shall conform to manufacturer specification and as per IS Code and specification and as per decision of WBSEDCL.

8.8.4 Waterproofing Cement base paint

Waterproof cement based paint of approved manufacturer , and IS code 5410:1992 Part 2 : 1972 of desired shade/shades shall be applied over the Cement primer coat. Ensure that the surface is thoroughly dry before painting to avoid premature paint failure. When preparing the surface for painting ensure that all loose and flaking paint or foreign matter is removed and get an absolute smooth surface dried at ambient temperature outside. Wherever textured paint is applied it is to be ensured that the textured matt finish of smooth granular feeling is obtained after application of 2 coats of " Weather shield" or equivalent compound of reputed manufacturer as approved by WBSEDCL acrylic exterior textured paint. The entire process of application shall conform to manufacturer specification and as per IS Code and specification and as per decision of WBSEDCL.

8.9 Precaution

8.9.1 Brushes should be quickly washed in water , immediately after use and kept immersed in water during break periods to prevent the paint from hardening on the brush.

8.9.2 In the preparation of walls for plastic emulsion painting , an oil base putty shall be used in filling cracks , holes etc.

8.9.3 Splashes in floors etc. shall be cleaned out without delay as they will be difficult to remove after hardening.

8.9.4 Washing of surface treated with emulsion paints shall not be done within 3 to 4 weeks of application or the time specified by manufacturer.

9. STRUCTURAL GLAZING

9.1 Scope of Works :

The scope of works under this contract includes design, supply installation, protection guarantees, testing and maintenance up to the defects liability period of Structural glazing, openable panels, glass doors and fixed glazing.

The work under the section includes all labour, materials, equipment and services as required for the engineering, preparation of shop drawings, testing, fabrication, assembly, delivery anchorage, installation, installation, protection and waterproofing of the structural glazing openable panels, glass doors and fixed glazing system and all in accordance with the true intent and meaning of the specifications and drawings taken together, regardless of whether the same may or may not be particularly shown on the drawings or described in the specification provided that the same can be reasonably inferred therefrom. Anchorage includes all primary and secondary anchor assemblies and supportive structural framing as required to secure Structural glazing system glass doors and fixed glazing. The materials , work etc shall be as per relevant IS codes and specification and overall direction of WBSEDCL .



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

The detailed scope of work is as outlined hereunder-

The Structural glazing system and openable panels described hereafter shall include but will not necessarily be limited to the following :

9.2 Frames

Openable panels where indicated, inclusive of all accessories, fittings, etc. All caulking, sealing and flashing including sealing at junctions with roof waterproofing and exterior wall, raised kerbs and in window surrounds. Sealant within and around the perimeter of all work under this section. Separators, neoprene / EPDM and silicon gaskets, trims, etc. Inserts in concrete, anchor fasteners etc. for the anchorage of all work under this section is subject to the approval of WBSEDCL. Isolation of all dissimilar metal surfaces as well as moving surfaces similar or dissimilar. Fire-stops, flashing, sealing of all interfaces with buildings etc. Protection during storage and construction unit handing over Engineering proposals, drawings and data . Shop drawings, engineering data and structural calculations of all systems including framing, fasteners. Scheduling and monitoring of the work All samples, mock-ups and test units Coordination with work of Main Civil Contractor and other agencies / Contractors employed on site. All final exterior and interior cleaning of the Structural glazing system, doors, etc. Hoisting, staging, scaffolding and temporary services Specified tests, inclusive of necessary reports , Maintenance manuals , Performance guarantees . Periodic inspection, supervision and advice by tenderer's Principal as well as a back-up guarantee in an acceptance format by the Principal for the quality and performance of works. Construction monitoring for regular quality control and technical inspection to ensure the work conforms to the shop drawing details (including any modification made during testing) and acceptable standards of quality.

9.3 Reference And Standards

Materials and workmanship shall comply with the latest edition of the following standards as follows (but not limited to this list of standards) :

ANSI Z97.1-84.	Safety Glazing Materials used in Buildings
ASTM C1036-90	Specification for Float Glass
ASTM C1048-90	Specification for Heat Treated Float Glass
ASTM C864-90	Specification for Compression Seal Gaskets
ASTM C1115-89	Specification for Silicon Rubber Gaskets
ASTM C920-87	Specification for Sealants
ASTM C509-90	Specification for Sealing Material
GTA Specification	Specification for environment durability for heat strengthened
No. 89-1-6	Spandrel Glass with Applied Opacifiers
BSCP 118	Structural use of Aluminium

In general the Contractor may follow any international Standards subject to his satisfying WBSEDCL that these specifications are equivalent to latest specifications issued by ASTM, ISO, AAMA, BSS & SSIR or equivalent Indian standard as approved by WBSEDCL .

Copies of all codes proposed to be followed for design, materials, installation and testing shall be submitted to WBSEDCL within 2 weeks of issue of Works Order.

9.4 Building Regulations

Design of the Structural glazing system shall comply with all IS codes and regulations for wind design . All calculations shall comply with the requirements of the relevant National Building Code and Indian Standard Code, unless specified otherwise.

9.5 Guarantee/Warranty

The Contractor shall be fully responsible for and shall guarantee proper design safety and performance of this installed system for such a period as per manufacturer by providing guarantee/ warranty provided by the manufacturer along with the cross warranty by the Contractor and as directed by WBSEDCL as per terms of the contract from the date of taking over of works by the Owner.

In addition specific , guarantees/warranties in approved formats shall be given for performance of glass, double-glazed units, anodizing and sealants. All the guarantees /warranties shall be submitted before payment from the date of actual completion of work, and shall not in any way limit any other rights to correction which the WBSEDCL may have under the Contract.

9.6 Contractor's Responsibilities

The Contractor's responsibilities include but are not necessarily limited to the following items :

The Contractor shall provide and install all supplementary parts necessary to complete all items generally implied in the drawings and in the specifications though not specifically shown or mentioned.

This shall include providing, assembly & erection of all sections and anchor assemblies to meet the performance and furnishing and installation of all inserts, fasteners, clips bracing and framework as required for the proper anchorage of the structural glazing system elements to the structure, unless otherwise noted or specified to be furnish / installed by another agency. Alternate anchorage proposals will be considered , if in the opinion of WBSEDCL the general design and intent of the drawings and specifications are maintained.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

The Contractor's system therefore must perform satisfactorily as a whole.

Drawings and specifications indicate the required basic dimensions, profiles and performance criteria. The Contractor shall have the option of modification and addition of details provided the visual concept and performance requirements are fulfilled. Proposed modification shall be clearly shown on shop drawings as "Design Modifications" and acceptance of the same will not relieve the Contractor from sole responsibility for performance of the structural glazing and other system. The Contractor shall be solely and fully responsible for due performance of his installation based on his own design and details. This should be done after approval of WBSEDCL, in writing, subject to the modified design and drawings with all necessary calculations etc and approved by WBSEDCL.

In-plant and job site inspection : The Contractor shall afford for WBSEDCL and / or their authorised agent full access to plants, shops and assembly points to view and inspect the processes and methods employed in the fabrication, assembly and finishing of the structural glazing and other system for this project at their own expense, whatsoever. This should be guided by the relevant clause of GCC of this contract.

WBSEDCL will have the right to reject any Structural glazing and other system, components, assemblies during assembly and erection if the workmanship and intent are not in strict conformity with the approved shop drawings, documentation, certifications, samples and mock-up and shall be binding on the Contractor. Replacement, modification, removal of rejected materials shall be done at the risk and cost of the Contractor.

All costs of shop drawings, documentations, maintenance manuals, certificates, sampling etc. including their resubmissions shall be borne by the Contractors without any extra claim.

Glass, sealants and other items or materials procured by purchase shall be back to back guaranteed by the manufacturer and cross guarantee/ warranty by the Contractor.

9.7 Shop Drawings

Within 15 days upon award of contract, the Contractor shall prepare shop drawings by necessary modifications, if any to the preliminary drawings and two (2) copies of all shop drawings along with the plan and method to execute the job mentioning the brand of materials, other accessories to be used for the work shall be submitted to WBSEDCL for review and approval. WBSEDCL's review of all shop drawings will be limited to their conformity to the concept & specifications. WBSEDCL's approval of the shop drawings will not relieve the Contractor from any of the responsibilities and requirements as stated in Contract documents. No work shall be fabricated until the shop drawings and all other related submission, documentation, certifications, samples and the mock-up for that work have been reviewed and approved by WBSEDCL. On approval the Contractor shall submit 4 copies of drawings to WBSEDCL for release to site.

Shop drawings shall incorporate scaled and dimensioned plans, elevations, sections and full size details for all work in this section.

Shop drawings shall indicate the desired dimensional profiles and modules function, performance standards and, in general, delineate the scope of work. The Contractor shall verify and co-ordinate these items with all applicable and / or related trades, contract drawings and specifications. Since the dimensions and modular references shown on the drawings are for specific and / or typical detail, the shop drawings shall include a full complete layout of all modular and referenced dimensions for all the Structural glazing, openable panels, glass doors and fixed glazing and their related elements. All dimensions / modules, etc. shall be fixed and checked as required.

The full size details shall show and specify all metal sections, types of finishes; areas to be sealed and sealant materials, gaskets; direction and magnitude of thermal expansion, direction and magnitude of all applicable construction including fasteners and welds, all anchorage assemblies and components; the fabrication and erection tolerances for the work and applicable related works adjoining, attached to or in some way related to the work covered by these specifications. The location of all static and dynamic anchor assemblies, the direction of thermal and other applicable building movements, coordination with concrete works and the sequence of installation shall be designated on the applicable plans, elevations and / or sections. All details shall be subject to WBSEDCL's approval.

Shop drawings shall indicate the desired profiles, dimensions, details of metal finish and in general delineate the scope of the work. Profile adjustments in the interest of economy, fabrication, erection, weather-ability to satisfy the performance requirements may be made only with the written approval of WBSEDCL, provided that the general design and intent of the drawings and specifications are maintained.

Six (6) copies plus two reproducible sepia print and one soft copy each of all final approved shop drawings shall be submitted to WBSEDCL.

9.8 Samples and Manuals

Within 2 weeks of issue of order, the following samples of actual job site materials together with detailed technical data / catalogues shall be submitted in duplicate, unless otherwise noted, and in the sizes noted, for WBSEDCL review alike for approval of all other samples to be used for the work at site and approval. Any omission of an item, or items which require the Contractor's compliance with these documents does not relieve him from such responsibility.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Aluminium Extrusions – one of each section, 300 mm long of specified thickness. Glass; Each type and kind, 300 X 250 mm of specified thickness and including frame Glazing gaskets, tapes, separators, glass setting blocks, etc. each section of unit, 300 mm long or unit. Fasteners and connecting devices, each type and size

Finish samples: after approval of the final finish coating WBSEDCL is to be provided with six (6) approved samples.

Patch fitting door mongery and all accessories, as applicable. Flashings and finish samples

Samples submitted should also include assembly of various components forming a typical fixing detail complete with glazing, extrusion, fastener, sealant, etc.

9.9 Maintenance Manual

The Contractor shall submit six (6) copies of maintenance manuals each along with one soft copy at no extra claim, if applicable of detailed procedures for the periodic inspection maintenance and cleaning of all the structural glazing, openable panels, glass doors, windows and fixed glazing, finishes, etc.

9.10 Structural Properties

The design of structural glazing system / other fixing systems and all related components shall comply in general with the requirements of National Building Code IS-875 and Indian Standard Code IS-456 along with all relevant IS Code and specification. No structural glazing / other glazing system including sealants and sealed joint shall sustain permanent deformation or failure under loading equivalent to 1.5 times the design wind pressure herein specified.

Deflections : The specified deflections must be reduced if they are in any way detrimental to the Structural glazing and sealants.

The maximum deflection shall not exceed 1/300 of span of transom / sill/ head members.

Under 1.5 times design wind pressure there should be no permanent deflection of framing member exceeding 1/1000 of span length.

Maximum deflection of glass under design wind pressure at centre of any panel shall not exceed 15 mm or as recommended by the manufacturer whichever is less.

9.11 General

All braces, supports and connections for the structural glazing shall be designed, provided and installed complete as required.

Anchors for curtain wall sections shall be located with a maximum distance of 500 mm above or below the RCC floor slab unless specifically approved otherwise by the WBSEDCL.

Variations from Schematic layouts indicated on the drawings may be permitted at the risk, cost and responsibility of the Contractor but only if a proposed revision does not, in WBSEDCL's opinion, deviate from the design intent, cause excessive stress in the structure, cause excessive deflection, inhibit thermal and building movement or conflict with other requirements.

Member shapes and / or profiles if schematically shown on WBSEDCL's drawings are not necessarily the exact shapes required or best suited for the particular condition. Final shapes and locations shall be as designed by the Contractor and are subject to WBSEDCL's review and approval.

The horizontal or lateral load on such transom / railing (where not backed by an RCC concrete) shall be designed in accordance with the following criteria i.e. a horizontal UDL at 0.74 KN/m run, UDL supplied to the infill of 1.0 KN/m² and a part load applied to part of the infill at 0.5 KN.

No holes shall be burned, filed or drilled in any structural steel members unless expressly approved by the WBSEDCL in writing.

The Contractor shall provide detailed layouts, alignments jigs etc. for the proper and exact placement of all welded anchor studs, anchorage components without any harmful effect to the structural glazing.

No field forming, cutting and / or alterations of primary wall elements will be allowed. All framing members shall be shop fabricated and finish coated. No furnished surfaces will be permitted on exposed surfaces.

9.12 Concrete Tolerances

The Contractor shall take into account tolerance in concrete and masonry surfaces to which the structural and glazing framework is fixed.

Fire stop and Interface with Building

Joints in the structural glazing system between successive floors shall have the required fire resistance of at least 2 hours and shall comply with requirements of CFO.

A fire-stop-cum-smoke seal shall be provided at each window head level. In addition the Contractor shall provide an aluminium flashing to approved design at the window sill level and on 2 sides of vision panels.

All interfaces with building structure, and other elements shall be sealed / flashed provided with expandable gaskets to WBSEDCL's approval.

9.13 Sound Control

Provisions shall be made (e.g. capping of all ends of mullions) to prevent sound transmission through the system. Provisions shall also be made to prevent metal to metal rubbing noise due to thermal changes and wind pressure.

9.14 System Description

The front seal structural glazing system is semi unitized system. In this specially designed extruded aluminium mullions are fixed to the building structure by means of SS brackets of angles 100 X 100 X 12 mm of minimum 300 mm long with necessary aluminium packing for true alignment, suitable chinch anchor bolts of minimum 150 X 10 mm shall be provided for



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

fixing the brackets. On to these mullions, the transoms are fixed by means of pre-positioned angle cleats. After installing the grid work of mullion and transom, the entire frame work is aligned in perfect line, level and plumb. Drainage chamber, pressure equalization system and openable panel shall be provided.

Bonding of glass is not to be done on site. Panels are glazed in the factory under controlled conditions as per silicone manufacturer's recommendation to achieve required bonding result. These pre-glazed panels are brought to the site and fixed on to the preinstalled aluminium grid work. The gap between the adjacent glass panels are thereafter filled with silicone sealant to have complete homogenous surface of glass without any grooves and cavities and this shall depend upon the systems offered. The tenderer will indicate the details of systems offered along with the tender.

9.15 Frame Work

Frame work consists of specially designed mullion of minimum size of 101.6 mm X 57 mm X 3 mm (Alloy 6063-T-5/T-6 temper) B.S. 1474. Selection of mullion will depend upon the floor to floor height, distance between two. Mullions will pressure and other required structural stabilities. Transoms of minimum 83 X 57 X 2.25 mm (E 91 WP(1S) 1285) are attached to this mullion by means of aluminium angle cleats. The material shall be of reputed manufacturer as approved by WBSEDCL. Extruded section sample before anodization shall be produced to WBSEDCL for approval.

All aluminium sections shall be black matt anodized to 15 microns minimum. Bolts for connections of frame work shall be high tensile steel minimum 100 mm length and pop rivets shall be used and two samples shall be submitted for approval. Test shall include, DFT, film hardness, dry, cross batch adhesion, boiling water adhesion, test & glass measurements & general appearance and shall meet the following performance requirements. Sample testing shall be done at Govt. laboratories / testing houses at the risk and cost of the Contractor, as directed by WBSEDCL.

Salt spray resistance 3000 hrsexposure to 5% salt solution at 95% RH, 37.5°C> 125 mm creepage or loss of adhesion from scribed lines or cut edges.

Humidity resistance

Abrasion resistance

Mortar resistance

Detergent resistance

Color retention

Guarantee for peeling, cracking, checking, blistering, fading, chalking, color change.

Cleats & spigots : 6351 alloy T6 temper and SS screws shall be used for fixing the panels.

9.16 Fasteners

The type, size, alloy and quantity and spacing of all fasteners and anchoring devices shall be as required for the specified performance standards. The material shall be of reputed manufacturer, as approved by WBSEDCL.

Bolts, anchors and fastening devices shall be self locking, suitable for conditions encountered and shall be torque tightened when required to achieve maximum Torque Tension relationship in fasteners, washers, nuts all ancillary items shall be same material as fasteners.

Fastening devices between aluminium and aluminium shall be AISC type 302 (18-8) stainless steel unless otherwise approved.

Fastening devices between aluminium and dissimilar material shall be 300 series non-magnetic stainless steel unless otherwise approved.

Exposed fasteners shall be of stainless steel.

Self locking fasteners shall be stainless steel with nylon inserts or patches.

Proper care shall be taken in anodizing process to proper adhesion of the structural silicone to the anodized aluminium substrate. The anodizer shall be apprised that the extrusion to be finished will be used for structural glazing application. Sample of fasteners shall be submitted to WBSEDCL before anodisation for approval.

After a long period of time, anodised surface may develop an aluminium hydroxide surface film. This film shall be removed by detergent free boiling hot water rinse. Random production samples of anodised extrusions must be tested by silicone sealant manufacturers and certified by them. The sample testing shall be done at Govt. laboratories / testing houses at the risk and cost of the Contractor, as directed by WBSEDCL.

9.17 Glazed Panels

These are factory made glazed panels of approved make (as of WBSEDCL) which are brought to site of work and are bolted on the pre-fixed grid work of mullions and transoms. The entire safety and principle of structural glazing depends on these panels, in which the glass is bonded to the aluminium frames by means of structural silicone sealant. This has to be done in perfectly controlled conditions and as per the procedure recommended by sealant manufacturer. The sealant manufacturer shall visit the place of application for on-site testing of bonding by deglazing few panels. Necessary certification by the sealant manufacturer shall be furnished indicating that the glazing has been carried out as per their recommended procedure, based on which the Contractor shall submit the warranty along with the certification of the manufacturer.

9.18 Sealants

All sealant applications must be clearly designated on the applicable shop drawing details and reference to a master sealant schedule specifying materials special instructions and application procedures.

The compatibility and sequence of installation for all sealants must be carefully considered in all proposals in order to ensure the required cure and optimum performance. Sealants must not degrade and / or fail under all design conditions including, but not limited to thermal movement, water, ultraviolet exposure and / or other adverse environmental conditions. The following sealant materials are specified for performance standards only. All proposals must be equal to or better than the materials herein specified. The designation of sealant types noted on the drawings is intended for general design guidance. Final selection by the Contractor for the sealant types shall be based on their conformity with the Performance Requirements



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

herein specified and meet with WBSEDCL's approval. Maximum precautions shall be taken to prevent failure of sealant. Necessary warranty certificate by the manufacturer along with cross warranty by the Contractor shall have to be submitted .

9.19 Front Sealing

After glass panels are installed, leveled and aligned, the groove between two glasses on all the sides which depends upon the systems adopted shall be as minimum as possible. This groove is then filled with weather grade 789/79B black silicone sealant from outside to give one smooth surface. This silicone filled grooves shall allow for thermal movements in the glass. Sleek grooves are to be provided for esthetical requirement.

9.20 Structural Sealant

Dow Corning silicone sealant 995/GE ultra-glaze 4000. All exposed and concealed metal to metal (including tight or butt type metal to metal assembly prior to assembly), perimeter metal to concrete joints shall be silicone base sealant, preferably two component, in approved colour, conforming to the manufacturer's recommendations for the specific uses and performance criteria. The manufacturer shall conduct laboratory test for adhesion for each lot of aluminium sections and glass. Laboratory reports shall be submitted to WBSEDCL. Submission of warranty by the manufacturer and cross warranty by the Contractor is required .

9.21 Weather Sealant

Grade of sealants for concealed metal to metal and metal to concrete joints are to be installed or embedded in a full bed sealant and shall be of Dow Corning / GE. Joint fillers and back up materials shall be of neoprene and as per the written recommendation from sealant manufacturer. Shape, size hardness, compatibility and bond breaking requirements are to be considered. All sealants shall be non-staining as per norms.

All sealants shall be given guarantee/warranty for materials by the manufacturer along with cross warranty including , workmanship and performance from the date of taking over of the work by WBSEDCL.

9.22 Caulking compound

Dow Corning 790, one part gun grade consistency, colour to match adjacent material or approved by WBSEDCL for use around frame or between frame and floor slab.

9.23 Installation

The GI bracket having three way adjustments are first fixed to the building structure as per approved detailed drawings. On to these brackets, the mullions are bolted. The mullion to mullion joint on each floor is achieved by special aluminium sliding sleeve. There is an expansion gap between two mullions to allow thermal movements.

9.24 Smoke Seal

The gap between the building structure and the structural glazing frame is closed with perforated aluminium tubes. These smoke seals will stop the smoke, travelling from one floor to other floor as well as will stop the noise, travelling from one floor to other floor and shall be two hour fire resistant. Necessary tests shall be conducted at the risk and cost of the Contractor to check the functioning of smoke seal as directed by WBSEDCL complying to IS code and specifications.

9.25 Glass

For structural glazing, minimum 6 mm thick grey, tinted heat strengthened glass shall be used for spandrel areas and 24 mm thick insulated glass with 6 mm thick reflective toughened glass +12 mm air gap +6 mm thick clear toughened glass for other areas. The colour of the glass shall be as per the design of the WBSEDCL. Prior to bringing the materials in bulk, sample approval shall be done by WBSEDCL . Material shall be of reputed manufacturer and approved by WBSEDCL .

All glass and glazing materials shall be verified and co-ordinated with the applicable performance requirements.

Furnish and install glass and glazing work as indicated on the drawings and as specified herein. All glass shall be cut to required sizes and ready for glazing. Any pane which does not fit any section of the glazing and shop front will be rejected and a replacement made at the Contractor's expense. All glass shall be of accurate sizes with clear undamaged edges and surfaces which are not disfigured. Sample testing shall be done at the risk and cost of the Contractor as directed by WBSEDCL , over and above , the submission of test certificate from the manufacturer .

Heat strengthened glass shall not deviate in surface flatness by more than 0.23 mm within 260 mm of leading or trailing edge, or 0.076 mm in centre. Direction of ripples shall be consistent . Distortion of glass shall be controlled as much as possible during heat strengthening. Sag distortion shall be uni-directional as per WBSEDCL's option. Surface compression stress of heat strengthened glass shall be within 320-450 kg/cm².

Permanent identification marking on glass shall be accomplished by a technique selected by the manufacturer. The location of the marking shall be proposed by the Manufacturer and approved by WBSEDCL. All glass shall be delivered to site with the manufacturer's label of identification attached along with the test certificate of the manufacturer .

Submit for WBSEDCL's approval a complete list of materials to be used , including the sealants proposed and such samples as WBSEDCL may require. All glass and glazing methods and materials including the design and profile dimensions of glazing pockets shall be as approved and recommended in writing by the applicable glass and sealant manufacturers. A sealant substrate test report shall be submitted for each type of sealant for adhesion and compatibility. If required , WBSEDCL may ask the Contractor for further sample testing of sealants in Govt. laboratories /testing houses at the risk and cost of the Contractor . Warranty of the material by the manufacturer along with cross warranty including workmanship etc. shall be submitted by the Contractor .

Sealants in factory-glazed panels shall be fully cured prior to shipment to project site and installation.

All glass breakage caused by the Contractor or his sub-Contractor because of negligence or caused by the installation of faulty work by him shall be replaced by the Contractor at his own expense without delay to the project completion.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

The Contractor shall be responsible for replacement of any unit of glass and glazing that fails within the guarantee/warranty period of the manufacturer without charge.

The glass glazed panels / structural glazing frames for the structural glazing system shall be designed to withstand lateral imposed loads and comply with requirements of local building codes.

Glass thickness should be selected in accordance with IS 875:1987(Part III) to satisfy design performance requirements and local design codes.

Glass shall be free from defects or impurities detrimental to its performance. Defects such as bubbles, waves, spots, scratches, spalls, discoloration, visibly imperfect coating, chipping and bubbles or delamination of pacifier film shall be limited in accordance with the Manufacturer's / trader's guidelines. The glass is to be produced in such a way that the rollers will be parallel to what will be the horizontal position of the glass. Glass shall be consistent in colour.

Manufacturers' glazing instructions regarding installation, clearance, dimensional tolerance, bite edge clearance etc. shall be followed and shall also be guided by relevant IS codes and specifications.

All solar control glass panels shall be stored with particular care and protected against abrasion, sun and moisture prior to installation.

Precautions specified by glass manufacturers to minimise thermal stress must be followed. A thermal stress analysis shall be obtained from glass manufacturer prior to fabrication and their recommendations shall be followed. Allowances shall be made for thermal movements due to an air temperature range of 600C and a material temperature range of 1000 C.

Glass panels shall be selected / rejected on the basis of product quality standards specified by the manufacturer concerning scratches, pinholes, clusters, distortion, colour variations, flaws in coating and other defects. Decision of WBSEDCL in this regard shall be final and binding to the Contractor .

Each type of glass shall be obtained from only one manufacturer and in one lot. Adequate spare quantity shall be ordered to cover for breakage and for replacement during maintenance period.

Setting blocks for glass shall be extruded neoprene with minimum 80 durometer hardness.

9.26 Gaskets

Gaskets and seals shall be extruded EPDM of approved quality, compatible with substrates, finishes and other components they are in contact with. All gaskets exposed directly on the exterior face shall be silicon gaskets.

Extruded EPDM sections shall have the following properties :

Shore Hardness	:	70 $\pm$ 5A
Tensile strength	:	Min. 70 kg / cm ²
Elongation	:	300%
Ozone Resistance	:	No crack at 50 $\pm$ 5pphm, test temp of 40 $\pm$ 2 ⁰ C, test duration of 96 hours and 20% strain

Extruded neoprene sections if specifically permitted shall have the following properties :

Physical Property	Test Method	Performance
Hardness, Durometer A	ASTM D 2240	601.5 points
Tensile strength	ASTM D 412	1800 psi, minimum
Elongation at break	ASTM D 412	25% min
Brittleness temperature	ASTM D 746	40 ⁰ F
Resistance to heat	ASTM D 573	
Change in original properties after 70 hrs. at 100 ⁰ C		
Hardness	-	+ 10 points, max.
Elongation	-	40%, max.
Tensile strength	-	15% max.
Resistance to permanent set compression set after 70 hrs. at 1000 C	ASTM D 395	25% max.

Expansion joints

Expansion joints shall be with EPDM moulding.

Peripheral Flashing shall be done with aluminium anodized black with extruded 6101 alloy T6 tamper with DC multi seal.

Necessary test certificate from the manufacturer shall have to be submitted, if so instructed by WBSEDCL , the Contractor shall submit the test report of gasket sample tested through Govt. laboratories / testing houses at the risk and cost of the Contractor, over and above submission of the above test certificate .

9.27 Surface Preparation

9.27.1 Solvent cleaning

Dirty glass edges shall be cleaned with a solvent such as isopropyl alcohol (IPA), Oily metal surfaces shall be cleaned with degreasing solvent such as toulene, or xylene. Glass and metal finish manufacturers shall ensure compatibility of the solvent used for cleaning.

Primer shall be applied as per the manufacturer's recommendations. Silicon sealant shall be applied as soon as possible to prevent built up of dirt, moisture and other contaminants from affecting adhesion of silicone to substrates.

Silicone used shall be natural curing type. Acetoxxy curing sealant which release acetic acid during the cure process are not recommended for use.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

All adjacent surfaces shall be masked prior to sealant application. Backer rods shall be carefully positioned.

Sealant shall be applied in a continuous operation from a caulking gun or pump. Positive pressure, adequate to fill the entire joint cavity shall be applied by pushing the sealant bead ahead of application nozzle. The sealant must fill the entire joint and firmly contact with the glass and metal surfaces. Water, soaps or alcohol solutions shall not be used as tooling aids. After tooling, the masking shall be removed.

9.28 Separators

Separators between steel and aluminium members shall be of rigid type, high impact smooth both side Teflon with minimum thickness of 0.8 mm.

9.29 Quality & Certificates

All required certificates shall be furnished against each concerned supply.

Certificate of conformance for anodized finishes and thickness along with the test result.

Test certificates from sealant manufacturers issued at regular intervals during building process, conforming compatibility of materials and adhesion properties and workmanship of the system, testing of adhesion and chemical compatibility of all elements and design review in accordance with sealant manufacturer.

Physical and chemical properties of aluminium sections used.

Over and above the submission of test certificate from the manufacturer, WBSEDCL may instruct the Contractor for sample testing at Govt. laboratories / testing houses at risk and cost of the Contractor.

9.30 Leakage Test

The leakage test shall be conducted through hose pipes with water supplied at a pressure of 5 kg / sq.cm. at his own cost.

9.31 Accessories

All accessories shall conform to the relevant IS standard and shall meet all required functional aspects.

9.32 Warranty

The tenderer shall provide full warranty for structural glazing and other works carried out by them in this contract which shall include :

Against non-falling of glasses

Sturdiness of the system

Against water penetration

Against air infiltration

Smooth operation of the doors.

The structural glazing, door & fixed glazing systems shall be warranted for a period as stipulated in the bid documents or as provided by the manufacturer, whichever is later, and all repairs to the structural, sealant and other items if required shall be carried out without any additional cost. The warranty shall be furnished in stamped paper in the form to be provided after the award of work.

If breakage of glass / structural defects occurs due to faculty design and execution within the warranty period, the same shall be replaced without any additional cost and the same shall be replaced within 2 weeks. The decision of WBSEDCL shall be final.

Complete drainage system in the structural glazing panes. Water leakage and condensation shall be drained or discharged to exterior face of wall and shall be sealed off at every floor and water shall not be retained.

9.33 Drawings

On receipt of the order, the tenderer within 15 days shall submit detailed fabrication and erection drawings indicating all fixing details and panel arrangement, door details etc. for approval and fabrication to be taken up after approval of these drawings.

9.34 Packing

Packing shall be made with PVC adhesive tape for anti-scratch requirements.

Transport of glazed units shall be done only after the sealant is cured fully.

9.35 Payment

The opening area of structural glazing / door opening shall be measured for payment. The measurement shall be guided by the relevant specification and GCC. In case of any dispute, decision of WBSEDCL shall be final and binding on the Contractor. The rate quoted shall be deemed to include cost of all materials viz. Aluminium, sections, making frames, erection, glazing sealants, weather strips, fittings and fixtures, all fixing arrangements testing, fabrication at plants and erection at site including labour, machinery, scaffolding, staging, chipping of wall, beams, columns, tests, pre commissioning test, commissioning test, rectification of plaster, painting if required, for the complete job.

The GCC shall be read and applicable in conjunction with technical specification.

10. GYPSUM BOARD FALSE CEILING

G.I. perimeter channels of size 0.55mm thick having one flange 20mm and another flange 30mm and a web of 27mm. Suspending G.I. intermediate channels of size 45mm, 0.9m thick with two flanges of 15mm each from the soffit at 1220mm. Centres with ceiling angle of width 25mm X 10mm X 0.55mm thk. fixed to soffit with GI cleat and steel expansion fasteners. Ceiling section of 0.55mm thk having knurled web of 51.5mm and two flanges of 26mm each with lips of 10.5mm are then fixed to the intermediate channel with help of connecting clip and in direction perpendicular to the intermediate channel at 457mm Centres. 12.5mm thick tapered edge Gypboard conforming to IS : 2095 (latest amendments) is then screw fixed to ceiling section with 25mm dry wall screw at 230mm centres.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Finally the boards are to be jointed and finished so as to have a flush look which includes filling and finishing the tapered and square edges of the board with jointing compound, paper tape and two coats of primer suitable for Gypboard (as per manufactures specification).

Test certificate from the manufacturer with warranty shall be submitted . The cross warranty attaching warranty of the manufacturer shall be submitted by the Contractor . WBSEDCL may also ask for further testing of sample of material at the risk and cost of the Contractor .

11. ROLLING SHUTTERS :

11.1 General

The rolling shutters shall be of approved make and the design and shall be suitable for fixing in the position shown in the drawing i.e. , inside, outside, or below lintel or below joists. The shutter shall be of the manually push and pull type upto 9 sq.m. If the area of the shutter is between 9 sq.m. and 12 sq.m. There ball bearing shall be provided for easy operation . When the area is more than 12 sq.m. mechanical gear arrangements shall be provided. The rolling shutters shall generally conform to IS : 6248. The shutter shall be complete with door suspension , shafts, locking arrangements, pulling handles and other accessories. The laths shall not be less than 1.25 mm. in thickness .and 80 mm wide. Guide channels shall be of minimum 75 mm depth and made of steel sheets of not less than 3.15 mm thick.

Material testing of samples shall be done at Govt. laboratories /testing houses at the risk and cost of the Contractor and submitted to WBSEDCL .

11.2 Mode of Measurement :

11.2.1 Measurements shall be guided by provisions of GCC and specifications.

11.2.2 Payment shall be made for the clear size of the opening only and the Contractor shall include in his rate for the side guide rails , pipe shaft , springs, hood/ cover and brackets.

11.2.3 Rate shall include for all materials, fabrication , transport , erection , maintaining in place till completion of the job. One coat of shop paint , all tools ,tackle , plant , equipment , scaffolding , testing etc., required for the completion of the job as per the specifications.

12. ALUMINIUM WINDOWS& VENTILATORS

12.1 Materials

12.1.1 All sections shall be obtained from approved , reputed , manufacturers such as Hindalco , Domal, as approved by WBSEDCL and shall be extruded from aluminium alloy conforming generally to IS : 733 - 1983 and IS : 1285 - 1975.

12.1.2 Sections shall conform to IS : 1948-1961.

12.1.3 All sections shall be colouredanodised. Anodising shall be done from reputed agencies as approved by WBSEDCL with the warranty by the anodizing agency . The thickness of anodising shall be a minimum of 15 microns and the Contractor shall furnish necessary evidence in proof of this to the satisfaction of the WBSEDCL.

Samples of extruded aluminium section shall be approved by WBSEDCL and kept at site by the Contractor for ready reference .

12.1.4The engineer at his discretion may send samples to an independent laboratory for testing at the cost of the Contractor and if the test report from the laboratory indicates any deficiency the materials shall be rejected. Warranty certificate from the manufacturer shall be submitted by the Contractor .

12.2 Workmanship :

12.2.1 All frames for windows , ventilators etc., shall be flat , with all corners at right angles and shall not be warped.

12.2.2 Frames shall be fabricated from sections machine cut to length ,mitered and rivetted with clips at corners. Sub-dividing bars shall be tenoned and rivetted into the frame.

12.2.3 Hinged door shall be provided with approved quality floor springs , and aluminium push plates. Push plates shall extend the full width of the shutter , and shall be provided with tower bolts and approved quality lock.

All the members of all shutters have built -in grooves to take on snap on aluminium beading. Neoprene gaskets shall be provided to prevent direct contact between glass and aluminium and make the shutter completely weather seal.

12.2.4 The Contractor shall measure each opening before fabrication. The employer shall not be responsible for any variation in the widths and heights of openings .

1.12.2.5 Frames shall be fabricated so that during fixing 6 mm clearance is obtained all round .



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

1.12.2.6 The Contractor before fabrication shall submit shop drawings to the WBSEDCL for prior approval.

1.12.2.7 Before erecting, frames coming in contact with masonry, plaster, concrete care should be taken that a distinct gap as directed by WBSEDCL should be kept and the same to be sealed with colourless polysulphide sealant all round the frame on both sides. The Contractor shall provide necessary treated wooden spacer blocks or frame before erecting and finalizing the alignment of the aluminium frame with respect to the masonry opening.

12.2.8 Plain or tinted glass glazing, as specified shall be fixed.

12.3 Mode of Measurement and Payment:

12.3.1 Measurements shall be guided by provisions of GCC and specifications.

12.3.2 The rate for window and Glass partitions shall include for all materials including glazing, fabrication, transport to site, erection, cost of scaffolding, maintaining in position till completion of job and including all tools, tackle, plant and equipment, testing etc. and all other necessary works incidental to the completion of the work as per these specifications. For partitions with Bison panel in Aluminium frame the rate should also be inclusive all materials labour and tools and plants.

13. ALUMINIUM COMPOSITE PANEL CLADDING

13.1 Cladding shall be non-toxic composite aluminium panels of adequate strength with approved aluminium details. The panels shall be 4mm thick composite units finished with PVDF (Polyvinylidenedifluoride) coating overall 35 micron thick of approved metallic colour. The resin content of the PVDF (Polyvinylidenedifluoride) coating shall be 75% to 80%. The back of the panel shall be chromatised 3-4 micron thick, compatible with adhesives for stiffeners if any or given a polymer coating.

13.2 The fabrication and installation of the cladding systems shall be carried out as per manufacturer's instructions with invisible/concealed fastenings, aluminium sub-structure, silicon sealants properly tooled etc.

13.3 All cladding panels of one kind shall be obtained in one lot from the manufactures.

13.4 Each panel shall be guaranteed for a flatness of ± 1 mm from the true face after installation under no-wind conditions. Deviations from the true alignment of adjoining panels shall not be cumulative. Full load deflections shall be kept to the minimum possible. Each panel shall be capable of withstanding 300 Kg/Sq.m wind pressure without any permanent deformation.

13.5 The cladding system shall be adequately ventilated. The air-gap between the cladding panels and the concrete /block – wall shall be at least 50 mm to allow proper ventilation of the rain screen system. The cavity shall be closed by a perforated bird/vermin-proof closer at bottom and by a flashing at top or any other method as mentioned in the drawing. The wall behind should be treated with approved water proof paint applied over plastered surface as directed by the WBSEDCL.

13.6 The fabrication processes including cutting, grooving, benching, folding, root-in as well as installation shall be performed as per manufacturer's instructions. The panels shall be backed by approved aluminium support framework, fixed to wall with aluminium/galvanized steel brackets. Cross warranty attaching the warranty of the manufacturer shall be submitted by the Contractor to WBSEDCL in approved form and manner.

13.7 The composite Aluminium panels shall satisfy the following fire codes requirements:

BS476	part6	Class	0
ASTM E-84	Flame Spread Index	0	
Smoke developed	Index		<15

UBC 26-9 & NFPA for 30 minute Intermediate scale Multi-story Apparatus. Test to prove no flame spread beyond the area directly exposed to fire source.

Sample approval from WBSEDCL shall have to be got done by the Contractor prior to bringing the material in bulk at site. Necessary test certificate with warranty from the manufacturer shall have to be submitted by the Contractor. Over and above the submission of test certificate, WBSEDCL at its discretion may ask for sample testing further in Govt. laboratories / test house at the risk and cost of the Contractor.

14. INTERLOCKING PRE-CAST TILES FLOORING

Materials: Interlocking concrete pavers are composed of Portland cement, fine and coarse aggregate, color is often added. Admixtures are typically placed in the concrete mix to reduce efflorescence. Pavers are made in factory- controlled conditions with machines that apply pressure and vibration.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Application: Interlocking concrete pavements are typically constructed as flexible pavements on a compacted soil sub-grade and compacted aggregate base. Concrete pavers are then placed on a thin layer of bedding sand, compacted, sand swept into the joints, and the unit compacted again.

Do not use the sand to fill depressions in the base. These eventually will be reflected in the surface of the finished pavement. Fill any depressions with base materials and compact.

50 mm thick concrete mat finish factory made tiles of M25 grade shall be provided over 50 mm thick coarse sand over 100 mm thick PCC 1:2:4 in the location of road and other areas of the building as shown in drawing. The same will be measured in Sam. The interlocking paving tile shall be factory made of makes as specified in the list of approved manufacturer'. The size, Shapes and pattern shall be as approved by WBSEDCL. The compressive strength shall be checked from reputed laboratory from each lot and shall be kept on record, over and above, the submission of test certificate from the manufacturer.

15 GLASS MOSAIC TILE

After checking the surface for leveling, spread the adhesive (GTA) of Pidilite/ Balendula/ laticrete or equivalent with 2mm notch trowel. Place the tile sheet available in 300 x 300 mm in size in perfect alignment vertically and horizontally. Soak the back paper of tile sheet with a sponge soaked in water. Peel off the water soaked back up paper starting from a corner. After removing the paper, the mosaic tile surface shall be washed with the water to remove any residual glue. Fill the joint grooves with Birla white cement mixed with colour pigment as approved and grouting admixture using a rubber trowel and clean the surface again with wet sponge and leave the surface for 8 hrs for curing. Lastly, clean the surface with diluted HCL in a ratio of acid to water as 5: 95.

16 APPLICABLE CODES AND SPECIFICATIONS

List of major Indian Standards has been given in the list of IS Codes in "Special Conditions of Contract" of this bid document.

LIST OF APPROVED MANUFACTURERS

Sl. No.	Description of Approved Material	Approved Brand / Manufacturer
1	Cement	ULTRATECH (L&T)/AMBUJA/ACC/LAFARZE
2	Reinforcement Steel	SAIL/TATA/RINL/SRMB/SHYAM/JSW/JSPL
3	Structural Steel	SAIL/TATA/RINL/SRMB/SHYAM/JSW/VIZAGSTEEL
4.	Glazed Tile	JOHNSON /KAJARIA /SOMANI
5.	Ceramic Floor Tile	JOHNSON/ KAJARIA / SOMANI
6.	Vitrified Ceramic Floor Tile	JOHNSON / KAJARIA/ RESTILES CERAMIC LTD
7.	Cement Bonded Particle Board Conforming to IS 14276 – 1995	"BISON PANEL" – INDIA – NCL INDUSTRIES LTD. (Boards Division) / EVEREST INDUSTRIES LTD .
8.	Ply Wood, Shuttering Ply Conforming to IS 303-1989 / IS 4990-1993	M/s. Century Plyboards (I) Ltd. / M/s. Green Ply Industries Ltd.
9.	Wooden Frame	Siliguri Sal / Malayasian Sal
10.	Fire Door	Shakti met-dor
11	Rolling Shutter	Bengal Rolling Shutter
12.	Stainless Steel Section	SAIL/ TATA
13.	Stainless steel hardware for doors	Dorma /Haffelle
14	Glazing	Saint Gobain / Asahi Float Glass Ltd / Hindusthan Safety Glass Works Ltd. / Modi.
15.	Injection water proofing, waterproofing coating, water repellents Conc. Admixtures	Sika Qualcrete Ltd./ Structural Waterproofing Co. / Pidilite Industries Ltd. / 'Fosroc
16.	Synthetic Enamel Paints, Distemper, Acrylic Emulsion Paints, Melamine Coating, Aliphatic Acrylate	I.C.I (I) Ltd. / Berger Paints (I) Ltd. / Jenson & Nicholson (I) Ltd. / Asian Paints (I) Ltd. / Goodlass&Nerolac, FOSROC Chemicals(I) Pvt Ltd .
17.	Flush door (Factory made)	Century Ply / Green Ply



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

18.	Aluminium Sections and Extrusion shall conform IS:733-1983 and IS:1285-1975	INDAL / JINDAL
19.	General Hardware	
	a) Latches, hinges etc.	GODREJ / DORMA / HAFELLE
	b) Locks , Flush bolt	GODREJ / DORMA / HAFELLE
	c) Handles	GODREJ / DORMA/ HAFELLE
	d) Screw	GKW / ND/ Nettlefold
	e) Door Closure	GODREJ / DORMA/HAFELLE
	f) Floor Spring	GODREJ /EVERITE Gencies Pvt. Ltd. /Garnish
	g) Aldrop	ISI Marked
	h) Tower bolt	ISI Marked
	I) PVC Buffer block	ISI Marked
	J) Door Stopper	ISI Marked
	k) Patch fittings for toughened glass	Dorma Systems
20.	Laminates	"DECOLAM" (Bakelite Hylam Ltd.) / "MERINO" (Century Laminating Co. Ltd.)/ GREENLAM (GREEN PLY)
21	Marble	
a)	White Variety (Indian)	Abu White Super
b)	Green Variety (Indian)	Udaipur
c)	Italian Marble	As per approved shade
	Granite	
a)	Red	Ruby Red
b)	Black/Grey	Premium
22	Kotah stone (Bluish grey)	Premium
23	Waterproof Adhesive for Tile / Slab fixing to wall or floor	SIKA/Fosroc/Pidilite/Roffe
24	Sealant	
25	Tile Jointing Materials	
26	Decorative Ply (Teak / Cedar / Mahogany / Walnut Veneer)	Century Ply/Green Ply
27.	Cement Based Exterior Textured Paint	ICI/Asian Paints /Berger/ Snowcem India Ltd.
28	Glass Mosaic tiles	Shon/Kent/Bisazza
29	Glass for structural glazing & canopy (Coloured Reflective toughened glass)	Saint Gobain / Hindustan Pilkington/ Ashai float glass
30	Silicone Sealant	GE/Dow Corning
31.	Aluminium composite panel	Aluco bond/Aludecor/Alstrong/Alupan
32.	MS Conduit pipe	BEC /SUPREME/ AKG
33.	PVC Conduit pipe	AKG /PLAZA/ PADAM
34.	Pre-constructional (Chloropyriphos) Anti-termites	Pest Control India or approved by WBSEDCL
35.	Cement Primer	ICI / BERGER / ASIAN
36.	Textured Paint	ICI / BERGER / ASIAN PAINTS ,
37.	Waterproofing acrylic emulsion exterior grade paint	ICI / BERGER / ASIAN PAINTS
38.	Acrylic Polymer waterproofing coat	SIKA / FOSROC / PEDILITE / ROFFE
39.	Expanding grout admixture	SIKA / FOSROC / PEDILITE / ROFFE
40.	Integral waterproofing compound	SIKA / FOSROC / PEDILITE / ROFFE



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

41.	Waterproofing admixture	SIKA / FOSROC / PEDILITE / ROFFE
42.	Plasticizer	SIKA / FOSROC / PEDILITE / ROFFE
43.	APP membrane	SIKA / TEXSA / PEDILITE
44.	PVC door	SINTEX OR AS APPROVED BY WBSEDCL
45.	Aluminium anodized louver	HUNTER DOUGLAS
46.	Structural glazing	JINDAL/HINDALCO
47.	Stainless steel handrail with baluster	GODREJ / DLINE
48.	False ceiling	GYPSON/EVEREST/ARMSTRONG
49.	W/C, Basin, Urinal, cistern	CERA/HINDWARE/PARRYWARE/KOHLER
50.	PVC tanks	SINTEX OR AS APPROVED BY ENGINEER-INCHARGE
51.	Sanitary fittings	JAQUAR/KOHLER/GROHE/CERA
52.	RCC grouting	PIDILITE/DR.FIXIT

Note:

If the approved brands mentioned above are not available, equivalent make as may be approved by WBSEDCL only is to be used for the work. The items for which brand name or name of the manufacturer have not been mentioned in the above list, shall be given by WBSEDCL to the contractor during the execution of work. The above list is not comprehensive and WBSEDCL reserve the right to ask the contractor for use of any alternate brand / manufacturer during execution of work, of equivalent quality.

TECHNICAL SPECIFICATION FOR WATER SUPPLY & SANITARY DRAINAGE SYSTEM (GENERAL)

I. GENERAL:

- The Contractor shall arrange with local municipal authorities for getting the water and sewerage connections.
- The Contractor shall arrange for submission of plans to the statutory authorities / local bodies etc. and obtaining sanction of the same.
- The rates are of complete works/items as defined in the respective items of the B.O.Q. as fixed in position and overall costs- e.g. cutting of holes, chases, etc., and also for provision of fixing arrangement viz., clamps, brackets, wooden blocks priming, painting etc. and include restoration to original condition of all damages to walls, floors etc., during the process of fixing sanitary installations, water supply and drainage. All debris of plumber's excavation, etc., shall be removed without any extra charge. The plumbing work/or the building work effected by the plumber work shall be left thoroughly cleaned to the satisfaction of WBSEDCL.
- Unless specified to the contrary, all material should conform to ISI specification and be of best quality and make as approved by the WBSEDCL. Testing shall be undertaken for various materials samples, pipe lines etc. and as may be directed by the WBSEDCL at the risk & cost of the Contractor.
- All G.I pipes (except concealed pipes and underground pipes) and brackets and fixtures and manhole covers shall be painted with 2 coats of synthetic enamel paints of approved brand over a coat of Red-oxide Primer/ Red lead primer, as directed.
- All concealed and underground G.I pipes and specials shall be painted with 2 coats of bituminous paint & primer of approved brand as directed by WBSEDCL.
- All priming and painting work shall be carried out to the satisfaction of the WBSEDCL and cost thereof shall be covered in the rates of all the respective items.
- The Plumbers shall obtain the drainage completion certificate and the certificate of adequate water supply from the Local statutory body / Panchayat / Municipality and shall abide by the rules and regulations prescribed by them or other authorities concerned, wherever necessary.
- In case of concealed G.I pipe work, the chases in floors and walls shall be made as approved by WBSEDCL. The pipes shall be secured tightly to the walls with clamps. The chases shall be filled with cement concrete 1:2:4 (1 cement: 2 coarse sand : 4 graded stone aggregate of 20mm nominal size). Payment shall be made for cutting chases and filling in the



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

cement concrete and making them good as per relative item in the Bill of quantity for renewal items as per relevant specifications.

10. The cast iron pipes shall be laid exposed on wall with M.S. holder bat clamps made from 32mm thick. M.S. flats of approved design and required size. A clear minimum gap of 25mm between the wall and the pipe shall be left. All the clamps shall be embedded in cement concrete blocks sized 20cm x 20 x 10 cms. in 1:2: 4 mix (1 cement :2 coarse sand : 4 graded stone aggregate - 20mm. nominal size) . The holes in walls and RCC work shall be made at point approved by WBSEDCL, and shall be made by the Contractors. Payment shall be made as per respective item in the Bill of Quantities complying with relevant specifications.

11. All plumbing and sanitary fixtures, pipes and pipe fittings, traps etc., which are to be embedded into the concrete or masonry work or other building work shall be placed in position and embedded for concealed at the time of casting of concrete and during the work shall be placed in position and embedded for concealed at the time of casting of concrete and during the work of construction. In case where chasing or cutting of concrete, masonry, or other structural or constructional work is unavoidable, the location of such fittings, pipe lines and traps etc., shall be chalked out at the various places and the cutting, chasing or disturbing of the construction work shall be proceeded only after the due approval of WBSEDCL.

12. All cuttings, chasing and fixing work shall be completed before commencement of any plastering, tiling or finishing work. Any rectification required shall be done at the risk & cost of the Contractor to the entire satisfaction of WBSEDCL.

13. Galvanized iron pipes of "TATA" make of "Medium" quality, E.R.W. as per IS – 1239, P-I; and Pipe Fittings shall be of "Heavy" quality, as per IS – 1239, P-II, of Galvanized Malleable Cast Iron, with Material code conforming to IS-1879 of "HB", or "NB", "Zoloto", Leader, "JSI" or equivalent Brand.

Test certificates from the manufacturer shall be submitted by the Contractors. Over & above the submission of test certificates; WBSEDCL may also ask to the Contractor's for further testing of samples in Govt. laboratories/test houses at the risk & cost of the Contractor.

14. Samples:

In all cases samples of the materials proposed to be used shall be submitted for approval of the WBSEDCL, before taking up the work in hand and the samples shall be well preserved at site by Contractor at his own risk & cost.

15. Materials, Workmanship & Samples:

All the materials and workmanship are to be of the best possible description and to the entire satisfaction of WBSEDCL and the Contractors shall immediately remove from the site any materials and /or workmanship which, in the opinion of WBSEDCL, is defective or unsuitable and shall substitute proper materials and /or workmanship forthwith at Contractor's risk& cost.

16. The Contractors shall ,if required by WBSEDCL, arrange to test material and / or portions of the works at his own cost in order to prove their soundness and efficiency, physical & chemical properties from Govt. laboratories / test houses. If after any such test, the work or portion of works is found in the opinion of the WBSEDCL, to be defective or unsound , the Contractor shall pull down and re-execute the same at his own cost. DEFECTIVE materials shall be removed from the site within 7 days from receipt of such order at his risk & cost. No extra claim whatsoever shall be entertained by WBSEDCL.

Wherever reference has been made to Indian Standard or relevant specifications or any other specifications, the same shall mean to refer to the latest specifications irrespective of any particular edition of such specifications being mentioned in the specifications or schedule of quantities. In case of any dispute, the decision of WBSEDCL shall be final & binding on the Contractor.

Bidders should note that the quantities in the Bill of quantities are approximate and are subject to variation to any extent.

This Technical specification shall be read in conjunction with other part / specification of the contract, viz. GCC SCC etc.

WBSEDCL shall have the right to modify / change the working drawing even after issue to the Contractor.

II. MATERIALS :

General : a) All materials shall be of best of their kind and shall conform to the latest Indian Standard specifications .

b) A set of specification samples of all approved materials shall be kept well preserved at site, cost of which is to be borne by the Contractor.

1.0 SANITARY WARES :

All sanitary wares and fittings shall be of first class quality white vitreous China as manufactured by Hindware, or Parryware or Cera and sample brand approved by WBSEDCL prior to the procurement in bulk by the Contractor.

Stainless steel sinks and draining board shall be of best quality stainless steel of "Imagine" SS Sink from "Hindware"/ "Nirali" / "Parryware" with sample and brand approved by WBSEDCL prior to the procurement in bulk by the Contractor.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

2.0 CAST IRON SOIL & WASTE PIPE :

All cast iron soil pipes shall be of Sand cast with Socket & Spigot ends of standard make. The thickness and specification shall conform to Indian Standard specifications IS: 3989- "Centri" cast.

Pipes and fittings shall be true to shape smooth cylindrical, their inner and outer surfaces being as nearly as practicable concentric.

Pipe when tested for soundness by striking with a light hand- hammer shall emit a clear ringing sound. The pipes shall be free from cracks, laps, pinholes or other imperfection and shall be neatly dressed and carefully felted.

The fittings shall be of easy clean type. The access door fittings shall be designed so as to avoid dead spaces in which filth may accumulate. Door shall be provided with(3mm) rubber insertion packing and when closed and bolted ,these shall be water tight.

Pipes and fittings shall be supplied without ears. Each pipe fittings shall have the trade mark of the Manufacturer and nominal size suitably marked on it.

M.S. stays and clamps shall be made from minimum 1.6mm thick M.S. flat of minimum 30mm width bent to the required shape and size to fit tightly on the socket, when tightened with screw bolts. Lead to be used for the jointing of the pipes shall be refined lead of best quality.

Floor traps shall be of approved make, 'P' type with minimum of 2" (50mm) water seal. At the top of each of these Floor Traps there shall be provided with 5" dia.(125mm) CP brass circular Grating of approved make.

These shall be Sand Cast iron pipes (class 'SWR') conforming to Indian Standard specification IS: 3989- "Centri" cast.

Sample and brand / make approval shall be done by WBSEDCL prior to procurement in bulk quantities by the Contractor. WBSEDCL at its discretion may ask the Contractor for sample testing through Govt. test house / laboratories at the risk and cost of the Contractor.

2.1 Lead Caulked Joints:

The annular space between the socket and spigot will be first well packed in with spun yarn leaving 25 mm.(1") from the lip of the socket for lead . The joint may be headed by using proper leading rings or if they are not available, by wrapping a ring of hemp rope covered with clay round the pipe. The lead shall be rendered thoroughly fluid and each joint filled in one pouring. Before caulking , the projecting lead shall be removed by flat chisel and the joint caulked round with proper caulking tools and a hammer of 1 to 1.1/2 kg (2 to 3 pounds) in weight in such a manner as to make the joint quite sound. After being well set, the joint is to be flush, neat and even the sockets. The specifications etc, shall comply to the relevant IS & CPWD specifications.

The approximate depth and weight of pig lead for various diameters of C.I.pipes and specials shall be as given below (as a guide-line):

LEAD FOR DIFFERENT SIZES OF PIPES

Nominal Size of Pipe (mm)	Lead/Joint (Kg.)	Depth of lead Joint (mm)
80	1.8	45
100	2.2	45
125	2.6	45
150	3.4	50
200	5.0	50
250	6.1	50
300	7.2	55
350	8.4	55
400	9.5	55
450	14.0	55
500	15.0	60
600	19.0	60
700	22.0	60
750	25.0	60

Note :

The quantity of lead given in the table are provisional and a variation of 20 percent is permissible, at the discretion of WBSEDCL.

The approximate depth and weight of pig lead for various diameters of C.I.pipes and specials shall be as per relevant IS & CPWD specifications.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

2.2 Smoke Testing:

All CI Sewer & Waste pipes and fittings including joints will be tested by a smoke test and left in working order after completion. The smoke test shall be carried out as stated under. No extra payment will be made for the tests. Smoke shall be pumped into the drains at the lowest end from a smoke machine which consists of a blow and burner. The materials usually burnt are greasy cotton waste which form clear pungent smoke which is easily detectable by sight as well as smell if leaking at any point of drain. The Contractor will have to rectify all defects traced in such tests at his own expense to the complete satisfaction of the WBSEDCL. The test shall be carried out at the risk & cost of the Contractor at Site, in presence of WBSEDCL complying to the relevant IS code & relevant specifications.

2.3 Testing of Materials and works:

As and when required by the WBSEDCL, the Contractor shall arrange to test materials and /or portions of works at his own cost to prove their soundness and efficiency. If after tests, any materials, work or any portions of work are considered defective or unsound by the WBSEDCL, the Contractor shall remove the same from the site forthwith at his own risk & cost. No extra claim for this or for any rectification / modification shall be entertained by WBSEDCL. All testing shall be guided by relevant IS code & relevant specifications at the risk & cost of the Contractor.

3.0 G.I PIPES AND FITTINGS :

All G.I. pipes shall be of galvanized iron "Medium" quality (as per IS-1239, P-I) of "TATA" make unless otherwise specified or separately / specifically approved / allowed by WBSEDCL. All fittings shall be of 'HB', or 'NB', 'Zoloto', 'Leader' brand or other equivalent make bearing ISI certification mark. The pipes shall be seamless screwed or socketted conforming to the requirement of IS : 1239-1985. These shall be of the diameter (nominal bore) specified. The pipes and sockets shall be cleanly finished, well galvanized in and other defects. All screw threads shall be clean and well cut. The ends shall be cut cleanly and square with the axis of the tube. Sample tests for physical & chemical properties may be asked for by WBSEDCL at the risk & cost of the Contractor from Govt. laboratories / Test houses over & above submission of Manufacturer's Test certificates.

4.0 (FULL WAY) GATE VALVES :

These shall be of Bronze / Gun metal (PN-10) or (PN-16) quality of "ZOLOTO" or "SANT", 'Leader' conforming to the relevant IS specifications and tested to 21 kg. per sq. cm. for 2 minutes. Necessary Test certificates shall be submitted by the Contractor with warranty from the manufacturer as asked for by WBSEDCL.

5.0 C.P. TOILET FITTINGS:

5.1. C.P. Brass Bib Cocks, Two-way Bib Taps, Stop cocks, Angle Stop cocks, Pillar cocks :

These shall be of Chromium plated Brass 'heavy' quality, threaded to BSPT (F) of Jaquar/Marc/Hindware/Essco make (as per B.O.Q) conforming to IS specification as per IS- 8931. Sample approval shall be taken by the Contractor from WBSEDCL prior to procurement in bulk quantities with samples well preserved at Site at the risk & cost of the Contractor.

C.P. Brass Pillar Cock (with control box) (for wash basins):

This shall be of Jaquar/Marc/Hindware/Essco make with wall mounted Control Box below the Wash Basins, threaded to BSPT (F) and conforming to IS-8931. Sample approval shall be taken by the Contractor from WBSEDCL prior to procurement in bulk quantities with samples well preserved at the risk & cost of the Contractor.

5.3 Health Faucets:

This shall be of Jaquar/Marc/Essco model, to be fitted with the two-way bib cocks inside each W.C.s (except Driver's Toilet), threaded to BSPT (F) and conforming to IS-8931. Sample approval shall be taken by the Contractor from WBSEDCL prior to procurement in bulk quantities with samples well preserved at Site at the risk & cost of the Contractor.

6.0 BALL FLOAT VALVE:



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

The ball float valves shall be of brass body of high pressure or of Pressure as specified. The Ball valve shall be of brass and the float of PVC of high pressure withstanding capacity. The minimum gauge of PVC Ball Float, the body of the ball valve shall be capable of withstanding a pressure of 200 lbs. per sqm. (14 kg. per sqm). The ball valve shall conform to IS specification No. 1708-1962. Necessary test certificates with warranty shall be submitted from manufacturers by the Contractor to WBSEDCL when asked for.

7.0 SUBMERSIBLE PUMP OF BORE WELL

(To supply underground water from subsoil aquifer to the R.C.C underground tank.)

Supply, installation in bore well, testing & commissioning of submersible multistage pump motor set Capacity- 16.5 M3/Hr. max (i.e., 275 LPM) at 50 M head with 'Submersible' type suitable HP Rated Motor (min. 3.7 kw , 5HP) at 2900 / or 1450 RPM; including supplying of 35 Mtr. long suitably rated & suitable cross-sectioned 3 1/2 -core "Submersible" type PVC insulated Sheathed Armoured Cable with Cable Clamps (Cable size as per Manufacturer's standard) as required, and including 415 Volt, 3-phase, 50 Hz Star-delta Starter Panel suitable to withstand $\pm 10\%$ voltage variation and $\pm 3\%$ frequency variations with Switch Fuse units and Isolators etc, of approved Make/Brand, including all other necessary accessories complete as required. (Make: - CALAMA / KSB / CRI).

Necessary test certificates with "warranty" from manufacturers as asked for by WBSEDCL shall have to be submitted by the Contractor with functional testing at site at the risk & cost of the Contractor in presence of WBSEDCL's representative.

7.1 Testing of Water Sample

Necessary chemical and bacteriological tests as per IS specifications for potable water shall have to be done by the Contractor at his risk & cost from Govt. laboratories / test houses as directed by WBSEDCL prior to commissioning of the Project.

7.2 Bleaching Dosing Tank

The bleaching dosing tank as shown in the drawing should be constructed and the dosing shall comply the specification & requirements of relevant IS code & specifications.

8.0 WATER LIFTING PUMP FROM UG TANK TO TERRACE TANK

It shall be of horizontal centrifugal type pumps for transfer of treated water from U/G Domestic Treated Water Reservoir to the Terrace Tanks of both Hostel Block and Training Centre to fill the Terrace Fire Tank first, which will re-circulates to the adjacent Terrace Domestic tank to store the treated water suitable to suit the drinkable water quality (as per IS-10500). The Treated Water from the individual Terrace Tank shall be distributed 'Down-Gravity' to respective individual Toilets.

(Treated water lifting pumps should be with C.I. Impeller, integrally coupled with submersible type 3 – phase 2900 R.P.M., 415 Volts, A.C. Motor, capable to withstand a voltage variation of $(\pm 10\%)$ and frequency variation of $(\pm 3\%)$, including Pump Control Panel).

Pump of Capacity – 162.0 LPM @ 34.0 M head – with 2.2 KW (3 H.P) Motor input, 2900 rpm 3-phase integrally coupled Motor.

(To be located inside the Treated Water U/G Tank)

(Make- Kirloskar/KSB/Crompton Greaves).

Necessary test certificates with "warranty" from manufacturers as asked for by WBSEDCL shall have to be submitted by the Contractor with functional testing at site at the risk & cost of the Contractor in presence of WBSEDCL's representative.

GLOBE VALVE :

Bronze / Gun-metal Globe valve, rising / non-rising Spindle type (IS-778), screwed in Bonnet, provision of repacking under pressure, Teflon Gland packing, Class-I, with 'OPEN' / 'SHUT' indicator and locking device, and also with C.I. Wheel of approved quality (screwed end).

(Make :-Zoloto / SBM / Leader)

It shall be of Bronze body Globe Valve with C.I. Wheel, screwed-in Bonnet, rising Spindle, Lubricated Gland Packing, conforming to IS-778, class-I, Bronze Disc & Disc nut, Brass Stem, with Asbestos Gland packing, and valve of approved quality (screwed end- female threaded).

Necessary test certificates with warranty from manufacturers as asked for by WBSEDCL shall have to be submitted by the Contractor with functional testing at site at the risk & cost of the Contractor in presence of WBSEDCL's representative.

10.0 PRESSURE REDUCING VALVE:



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

(At inlet main to every individual toilets and kitchen/canteen, except the top floor)

It shall be of 50mm and 32mm nominal diameter of Rubber Diaphragm type Pressure Reducing Valve of Bronze Body / Bottom Cover & Lock-nut (as per IS- 318 LTB 2), Spring loaded, screwed (female) end as per B.S.-21 class with reduced Set pressure range (Up-stream - to - Down-stream) of 3.5 Kg. / sq. cm. - to - 1.0 Kg. / sq. cm., with C.I. Camber & Bonnet, Seat Ring & Stem of S.S. (AISI 410), Bolt/nut & Tommy Bar of M.S., C.I. Spring Disc & Carbon Steel Spring, & EPDM Diaphragm, C.A.F. Gaskets (IS- 2712, Gr.-C), and the Valve with a Test Pressure (Hydraulic) of 35 Kg. / sq. cm. & with S.S. Screw / bolts / washers etc., and also with Teflon Thread Seal etc., all complete.

(Make - ZOOTO- Product Catalogue no.-1040 / Leader)

Necessary test certificates with warranty from manufacturers shall be submitted by the Contractor, as asked for by WBSEDCL. The functionality shall be tested at site in presence of WBSEDCL's representative at the risk & cost of the Contractor.

11.0 NON-RETURN VALVE (N.R.V.):

Bronze body "VERTICAL -LIFT" type Non-Return ("Check") valve with S.S. (AISI-410) body Seat Ring, two-piece design, S.S.(AISI-410) Disc, Screwed to BSPT-female (BS-21), with necessary 'Teflon' Thread Seal, including accessories.

(Make - ZOOTO- Product Catalogue no.-1045 / Leader)

(At Submersible Raw water Supply Pump Discharge pipe at the U/G Reservoir).

Necessary test certificates with warranty from manufacturers shall be submitted by the Contractor, as asked for by WBSEDCL. The functionality shall be tested at site in presence of WBSEDCL's representative at the risk & cost of the Contractor.

12.0 GATE VALVE (BRONZE BODY) :-

It shall be of 40mm nominal diameter of Gate Valve of Bronze Body, hand wheel operated, screwed (female) end as per B.S.- 21 class with Non-Rising Spindle, Screwed in Bonnet, and Lubricated Gland packing, & with a provision of re-packing, Valve conforming to IS- 778, Class -I, outer body with Bronze conforming to IS-318 LTB 2, Bonnet, Stuffing Box & Gland of Bronze/ forged Brass conforming to IS-318 LTB 2 / or IS-6912 FLB, Brass Stem, Bronze or Brass Gland nut, with C.I. Hand wheel conforming to IS-210 Gr.- FG 200, & with S.S. Screw / bolts / washers etc., and Valve Test pressure of 1.0 M Pa, and also with Teflon Thread Seal etc., all complete.

(Make - ZOOTO- Product Catalogue no.-1035 / Leader)

(At Submersible Pump Discharge pipe).

Necessary test certificates with warranty from manufacturers shall be submitted by the Contractor, as asked for by WBSEDCL. The functionality shall be tested at site in presence of WBSEDCL's representative at the risk & cost of the Contractor.

13.0 NON-RETURN VALVE (N.R.V): C.I. BODY :- (At Hydro-pneumatic Pump Discharge pipe)

These should be of C.I. Body, Check valve, Horizontal "Lift" – type with PN – 10 rating, with M.S. "Slip-on" type matching Flanges, along with CAF gaskets and appropriate M.S. Bolts, nuts, plain round Washers etc, all complete

(Make:- "Zoloto", code- 1067) / Leader)

Necessary test certificates with warranty from manufacturers shall be submitted by the Contractor, as asked for by WBSEDCL. The functionality shall be tested at site in presence of WBSEDCL's representative at the risk & cost of the Contractor.

14.0 AIR-RELEASE VALVE : BRONZE/GUN METAL BODY:- (At Water Supply Lie top to different Blocks & to Kitchen pipe Riser top)

It shall be of Bronze / Gun metal body "Parallel Slide" – "Blow-off" valve with BS-10 Table-H / E Flanged ends, sliding action Discs, spring loaded, rack-pinion arragt., S.S Discs, Body Seat Ring of S.S., Grahite Asbestos packing, M.S. Key, with Hyd. Test pressure of 500 p.s.i.g, with adjustable 'OPEN' / 'SHUT' arragt. of approved quality (Flanged end)

(Make:- "Zoloto", Code- 1052 / Leader)

Necessary test certificates with warranty from manufacturers shall be submitted by the Contractor, as asked for by WBSEDCL. The functionality shall be tested at site in presence of WBSEDCL's representative at the risk & cost of the Contractor

15.0 BLOW-OFF VALVE : BRONZE / GUN METAL BODY :-

(At Water Supply delivery Main Line Hydro-pneumatic system for blow-off due extra pressure in main back to the U/G treated tank)

It shall be of Bronze / Gun metal body "Parallel Slide" – "Blow-off" valve with BS-10 Table-H / E Flanged ends, sliding action Discs, spring loaded, rack-pinion arragt., S.S Discs, Body Seat Ring of S.S., Grahite Asbestos packing, M.S. Key, with Hyd. Test pressure of 500 p.s.i.g, with adjustable 'OPEN' / 'SHUT' arrangement of approved quality (Flanged end).

(Make:- "Zoloto", Code- 1052 / Leader)



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Necessary test certificates with warranty from manufacturers shall be submitted by the Contractor, as asked for by WBSEDCL. The functionality shall be tested at site in presence of WBSEDCL's representative at the risk & cost of the Contractor.

16.0 DRAINAGE- STONE WARE PIPES:

All pipes shall be of best salt glazed variety conforming to IS specification. The pipes shall be free from visible defects such as fire cracks or hair cracks. The glaze of the pipe shall be free from blisters. The pipes shall conform to IS : 651-1965.

17.0 SANITARY INSTALLATION :

Sample approved shall be done prior to bringing in bulk quantities at site by the Contractor.

17.1 The W.C. Pans shall be of white vitreous China Wall mounted Pattern with C.I. Chair Bracket of fitted with 'P' or 'S' trap (with a conversion bend) of vitreous China with effective 2" seal and 2" vent as per IS : 771-1963 & IS:2556 (Part II & VII) , 1967.

17.2 Fixing:

The W.C. Pan shall be laid in floor sloped towards the pan in a workman like manner, care being taken not to damage the pan in the process of fixing. It shall be fixed on a base of cement concrete 1: 3: 6 mix. (1 cement: 3 coarse sand: 6 stone ballast 40 mm and down gauge) taking care that the cushion is uniform and even without having any hollows between the concrete and pan. The joint between the W.C. pan and the trap shall be made with cement mixed with water proofing compound and made leak proof.

17.3 Flushing by PVC 'Low Level' Cistern : (manually)

The flushing of W.C. pan shall be done by "Hindware" / Parryware / Cera / Neycer make, PVC 'Low Level' Cistern-manually operated with push lever.

17.4 Brackets : (for Wall mounted W.C.- fixing)

The fixing bracket of Wall mounted W.C.'s should be of C.I. 'Chair' Brackets to remain fully concealed & embedded in wall and partially in floor finish. The W.C. shall be fixed to the chair Bracket with proper galvanised fixing Bolts, Nuts, and Washers, to the satisfaction of the Engineer- in charge.

17.5 Flush Pipe :

The outlet of flush pipe from the cistern shall be of 32 mm (1.1/2") rigid P.V.C. (as per ASTM D 1785), schdl.-40 pipe to remain concealed inside the wall & finish upto the mouth of the Inlet port of the 'Wall hung' W.C.'s, and that shall be connected with the W.C. pan by means of an approved type of joint.

17.6 Seat & Lid :

These shall be of black plastic or any approved matching colour hygienic seat and lid or as specified with rubber buffers, CP brass hinges and screws of standard 'Hindware' or 'Parryware' makes relative to the or equivalent approved Models & makes as in the schedule of Quantities.

18.0 URINALS :

The urinal basin shall be flat back of white vitreous China of specified size. It shall be fixed in position by using wooden plugs and screws at a height such that the outside bottom of Urinal Basin remains at 600 mm. from the finished floor level. The Urinal Basin shall be of "Flat-back-Large" type. Standard height of the Urinal Basins shall be as per the respective Manufacturer's standard. At least 200mm is to be given for fixing the "Jaquar" Sensor Installation Box from the top of the urinal (where the CP Spreader inlet Hole), if such installation is directed by WBSEDCL. Each urinal shall have 32 mm. dia. CP Bottle Trap with connected CP Waste Pipes, CP Waste Couplings etc, (as per the drawings).

18.1 Waste Pipes-concealed & Traps :

Each concealed Waste pipes (in proper slope) from the Urinals shall have 32 mm. dia. Rigid PVC (ASTM D 1785), schdl.-40 and this shall be further connected to 40 mm. lead of PVC waste pipe conforming to ASTM D 1785, complete with G.I. unions,



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

elbows, tees (equal or unequal) (as per IS-1879) of approved make as specified in the schedule of quantities, including wiped plumber joint complete with unions shall be terminated upto the mouth of respective extension pieces of the 100mm dia C.I. 'P' traps (below floor finish).

The main and distribution pipes fittings and clamps shall be of C.P. brass unless otherwise specified in the schedule of quantities, distribution pipes shall feed the urinals with C.P. brass spreaders of approved make.

18.2 Painting :

In case of cast iron flushing cisterns, painting shall be done as specified in the Bill of quantity.

19.0 KITCHEN SINK:

The above item shall be of Salem Stainless Steel Kitchen Sink - (AISI-304, conforming to IS-13983), Single Bowl, built with superior steel, with Bowl size not less than- 560 x 410mm and with Bowl depth of 205mm to 215mm; and total overall size - 1145 x 510mm, with a provision of a Drain-board, also including with 40mm Salem Stainless Steel Unique Waste Coupler and Coupler knob with C.I. / MS fixing Brackets, and C.P. screws/washers etc.

(Make - Hindware / Parryware /Nirali)

19.1 Fittings:

Each Sink shall have single pillar tap (Sink Cock with swinging lever of "Jaquar", model-Clarion). It's a special tap for the type of the sink specified and other fittings as specified, of Jaquar/ Marc / Essco make 40 mm (1.1/2") C.P. brass waste (CP) . C.P. brass angle valve with inlet connection of C.P. brass chain and rubber plug.

19.2 Waste Connection:

Waste pipe shall be of 1.1/2" dia. (32 mm.) rigid P.V.C. (concealed) pipe of approved make (as per ASTM D 1785), complete with unions. This shall discharge into a Floor trap.

19.3 Fitting:

Sinks shall be provided with 1/2"(15 mm C.P. brass valve) mixing fitting of 'Jaquar', or 'ESSCO' make complete with swinging spout.

19.4 Waste Connection:

The waste pipe shall be of PVC 1.1/2" (32 mm.) dia. As per ASTM D 1785, discharging upto the Floor trap. The rates shall include the cost of all materials and labour involved in all the operations described above.

20.0 TOILET REQUISITES:

Sample approved shall be done prior to bringing in bulk quantities at site by the Contractor.

20.1 Mirror:

Mirrors shall be of 6.0 mm. thick plate glass Saint Gobain / Modi-guard / Ashai make or approved equivalent make. The glass shall be uniformly silver plated at the back. Silvering shall have a uniform protective coating of red lead paint. The mirror shall have Plastic moulded frame of approved quality and colour. The mirror and its 6mm thick hard backing shall be fixed on the wall face to wooden cleats with C.P. brass screws and washers.

Toilet paper holder shall be of chromium plated as specified in the B.O.Q.

20.2 CP Robe Hooks (with double/ single Forks):

Theses should be of CP Robe Hooks with double / or single forks, of Hindware / Jaquar / Essco supported on anodized chromium plated base, fixed with 40mm long screws, rawl plugs etc., all complete.

WATER CLOSETS:

Samples shall have to be got approval from WBSEDCL prior to bringing in bulk quantities at site by the Contractor.

21.1 European type water Closets (EWC) : "Floor mounted type"



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

(Make - Hindware / Parryware / Neycer)

The W.C. Pans shall be of white Vitreous China Wall mounted Pattern with C.I. Chair Bracket of fitted with 'P' or 'S' trap (with a conversion bend) of vitreous China with effective 2" seal and 2" vent as per IS : 771-1963 & IS:2556 (Part II & VII) , 1967.

Fixing:

The W.C. Pan shall be laid in floor sloped towards the pan in a workman like manner, care being taken not to damage the pan in the process of fixing. It shall be fixed on a base of cement concrete 1: 3: 6 mix. (1 cement: 3 coarse sand: 6 stone ballast 40 mm and down gauge) taking care that the cushion is uniform and even without having any hollows between the concrete and pan. The joint between the W.C. pan and the trap shall be made with cement mixed with water proofing compound and made leak proof.

22.0 FLUSHING BY PVC FLUSHING CISTERN: (MANUALLY)

22.1 Brackets: (for wall mounted W.C. fixing)

The fixing bracket of Wall mounted W.C.'s should be of C.I. 'Chair' brackets to remain fully concealed & embedded in wall and partially in floor finish. The W.C. shall be fixed to the chair Bracket with proper galvanized fixing Bolts, Nuts, and Washers etc, to the satisfaction of WBSEDCL.

22.2 Flush Pipe:

The outlet of flush pipe from the cistern shall be of 32 mm (1.1/2") rigid P.V.C. (as per ASTM D 1785), schdl.-40 pipe to remain concealed inside the wall & finish upto the mouth of the Inlet port of the 'Wall hung' W.C.'s, and that shall be connected with the W.C. pan by means of an approved type of joint.

22.3 Seat & Lid:

These shall be of black plastic or any approved matching colour hygienic seat and lid or as specified with rubber buffers, CP brass hinges and screws of standard 'Hindware' / 'Parryware' / 'Neycer' makes relative to the or equivalent approved Models & makes as in the schedule of Quantities.

22.4 W.C. Pan

22.4.1 The W.C. Pans shall be of white vitreous china wall mounted pattern with C.I. chair bracket fitted with 'P' or 'S' trap (with a conversion bend) of vitreous China with effective 2" seal and 2" vent as per IS : 771-1963 & IS:2556.

22.4.2 Fixing:

The W.C. Pan shall be laid in floor sloped towards the pan in a workman like manner, care being taken not to damage the pan in the process of fixing. It shall be fixed on a base of cement concrete 1: 3: 6 mix. (1 cement: 3 coarse sand: 6 stone ballast 40 mm and down gauge) taking care that the cushion is uniform and even without having any hollows between the concrete and pan. The joint between the W.C. pan and the trap shall be made with cement mixed with water proofing compound and made leak proof.

22.5 Flushing by Flush valve: (manually)

The flushing of W.C. pan shall be done by Jaquar / Essco / Hindware make, CP Flush valve with 32mm dia CP Control cock (Wall mounted), with push lever.

22.6 Brackets: (for Wall mounted W.C.- fixing)

The fixing bracket of Wall mounted W.C.'s should be of C.I. 'Chair' Brackets to remain fully concealed & embedded in wall and partially in floor finish. The W.C. shall be fixed to the chair Bracket with proper galvanized fixing Bolts, Nuts, and Washers etc, to the satisfaction of WBSEDCL.

22.7 Flush Pipe:



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

The outlet of flush pipe from the cistern shall be of 32 mm (1.1/2") rigid P.V.C. (as per ASTM D 1785), schdl.-40 pipe to remain concealed inside the wall & finish upto the mouth of the Inlet port of the 'Wall hung' W.C.'s, and that shall be connected with the W.C. pan by means of an approved type of joint.

22.8 Seat & Lid:

These shall be of black plastic or any approved matching colour hygienic seat and lid or as specified with rubber buffers, CP brass hinges and screws of standard 'Hindware' or 'Parryware' makes relative to the or equivalent approved Models & makes as in the schedule of Quantities.

23.0 RAIN WATER PIPES OF PVC (IS-13592) & PVC/CI PIPE FITTINGS& SPECIALS AS PAR IS: 1729

All Rain Water pipes and fittings shall be of PVC, conforming to the latest Indian standard specifications for rain pipes. CI pipe clips or CI holder bat clamps are to be used for proper clamping on the wall.

These shall be free from cracks and other flaws. The interior of pipes and fittings shall be clean and smooth and the pipes are to be painted outside with paints matching with the colour of the building outside wall paints.

The access door fittings shall be of proper locations and in no circumstances less than as shown in the drawings. Doors shall be provided with 3 mm. (1/8") rubber insertions packing and when closed and bolted they shall be fully water tight.

23.1 Fixing:

The pipes and fittings shall be fixed to walls by using proper holder UPVC Pipe Clips (at every 2.0 metres intervals on the outside Building exterior wall pipes, i.e., Stacks or Pipes in slopes). The pipes shall be fixed perfectly vertical or in a line as directed. The spigot end and the shoulder of the socket leave no annular space in between. All Rain water pipes shall be carried up above the roof and shall have proper UPVC Bends of required degree near the roof and at the bottom of Rain water pipes. Connections between main pipe and the branch pipes shall be made by using proper branches and bends invariable with access-doors for cleaning. All vertical pipes should be covered on top with a wire down. The pipes and fittings should be firmly attached to the wall at least 5 mm. clear of the wall & should be strongly supported at the foot upon a bed of concrete.

23.2 Joints of Pipes & Fittings (by jointed by solvent cement joints / joints with Rubber gasket insertion) for CI pipes etc.

The annular space between the socket and spigot will be joined by solvent cement joints / joints with Rubber gasket insertion between the pipes & Pipe Fittings. This shall be done with 100% Leak-proof under Hydro-static Pressure Test under 4.0 Kg-f / cm² (g) pressure with a minimum Holding time of 1.0 hour and those joints after found tested OK shall be preserved and care is to be taken in such a manner so that there should be no undue load / impact / hammerage on those tested joints so as to make the joint quite sound. After being well set, the joint is to be flushed, neat and even the sockets.

The Pipes shall be of "SWR" class.

Under some extreme conditions and with the approval of WBSEDCL, the joints in a few locations may be considered by Solvent cement joints.

23.3 Testing:

All PVC Rain water pipes/CI pipes and fittings including joints will be tested by Hydro-static Pressure Test under 4.0 Kg-f / cm² (g) pressure with a minimum Holding time of 1.0 hour and those joints after found tested OK shall be tagged "Tested OK" for those portion of the tested pipe and shall be preserved and care is to be taken in such a manner so that there should be no undue load / impact / hammerage on those tested joints so as to make the joint quite sound.

Smoke test can also may be allowed and left in working order after completion. The smoke test shall be carried out as stated under.

Smoke shall be pumped into the brains at the lowest end from a smoke machine which consists of a blow and burner. The materials usually burnt are greasy cotton waste which form clear pungent smoke which is easily detectable by sight as well as smell if leaking at any point of drain. the Contractor will have to rectify all defects traced in such tests at his own expense to the complete satisfaction of the WBSEDCL. The test shall comply to relevant IS code & specifications and shall be done in presence of WBSEDCL's representative at site.

No extra payment will be made for the tests.

23.4 C.I. Floor Traps:

The traps shall be of self-cleaning design provided with a minimum 50 mm (2") Water seal at the Trap to arrest Foul smell there stopping it to enter into the building inside from the respective Stacks. Furthermore every Floor Trap will associated with a S.S. "Chilly" make cockroach arrestor trap with SS Circular Grating.

23.5 Waste Connections:

Waste from Wash Basins, floor traps , Sinks, Ablution Traps inside wc's etc, shall separately discharged into the Waste Stacks that terminated & fed to the Gully Traps on the building outside ground level / Plinth protection level and shall be separately connected to (IP) Inspection Pits that leads to the Septic tank.

23.6 Anti- Syphonage (Vent) Pipes: 50mm dia C.I (sand cast as per IS-1729)



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Anti-syphonage Vent pipe shall be HCI pipes of sand cast (as per IS-1729) with lead caulked joints and top remained connected at a point with the Sewer Stack above every Junction Branches (keeping a gap of at least 450mm above the top-most Junction Branches per floor from the Stack and finally that 50mm dia Vent Stack after running parallelly with Sewer Stack joined again with the Sewer Stack by 100 x 100x 50 mm dia Inverted unequal junction (IS-1729) above the top most finish floor level at a point above all the other horizontal junction points.

In every floor with the main anti-syphonage pipe junction Tees shall be 50 mm. (2") internal diameter or as specified.

23.7 Painting:

All the exposed CI Stacks / Pipes and fittings shall be painted with two coats of synthetic enamel paint over one coat of primer of approved quality, manufacture, colour and shade to match the surroundings. The cost of such painting should be included in the Contractor's rates for pipe work.

The surface of pipes and fittings to be painted shall be cleaned thoroughly, Red lead or other primer shall be painted as specified and allowed to dry. the finishing shall be done by painting 2 or more coats with paint in an approved colour and shade.

24.0 WATER SUPPLY:

Sample and brand / make shall be got approved by WBSEDCL prior to bringing in bulk quantities at site by the Contractor. Necessary test certificates shall have to be submitted from the manufacturer. Over & above the submission of test certificates, WBSEDCL may ask the Contractor for further test from Govt. test house / laboratories at the risk & cost of the Contractor.

24.1 G.I. Pipes and Fittings:

The pipes shall be of galvanized steel, ERW, (IS-1239, P-I) 'Medium', screwed and socketed and shall conform to latest Indian Standard specifications for medium quality.

The pipes shall be tested to a pressure of 50 kg/sqm. (700 lbs. per sq. inch). These shall have threads and the sockets, paralleled threads complying to the relevant IS code & specifications.

24.2 Laying & Fixing:

Where pipes have to be cut or re-threaded, ends shall be care-fully filled out so that no obstruction to bore is offered.

In jointing the pipes , the inside of the sockets and the screwed end of the pipe shall rubbed over with white lead and few turns of hemp yarn wrapped round the screwed end of the pipe which shall then be screwed home in the socket with a pipe wrench. Care must be taken that all pipes and fittings are kept at all times free from dust and dirt during fixing.

24.3 Internal Work:

For internal work, G.I pipes and fittings inside and outside the walls shall be fixed either visible (not in chase) by means of standard pattern holder bat clamps keeping the pipe 12 mm (1/2") clear of the wall everywhere or concealed as specified in Bill of Quantity . When it is imperative to fix the pipe in front of house or in any conspicuous position where it looks unsightly chasing may be adopted.

All pipes and fittings shall be fixed truly vertical and horizontals or as directed by the WBSEDCL.

24.4 External Work :

For external work G.I pipes and fittings shall be laid in trenches. The width of the trench shall be the minimum width required for working the pipes laid underground level .they shall not be less than 60 CMS (2 feet) from the ground level, and wrapped with gunny cloth dipped in hot bitumen. The work of excavation and refilling shall be done in accordance with the instruction of the WBSEDCL.

24.5 Painting:

All internal G.I pipes and fittings shall be painted with two coats of synthetic enamel paint over one coat of red lead primer of approved quality manufacture, colour and shade as directed by WBSEDCL. The cost of such painting shall be deemed to have been included in the rates of respective items of the B.O.Q.

24.6 Testing:

All G.I pipes and fittings shall be tested to a pressure of 7 kg. persqm. (100 lbs. per sq. inch) as specified in the relevant IS code & specifications to ensure that pipes have proper threads and that proper materials (such as white lead and hemp) have been in jointing . All leaky joints must be made leak-proof by tightening at Contractor's expense. WBSEDCL may ask the Contractor to submit the necessary test certificates in this regard.

25.0 BRASS WATER FITTINGS:



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

All water fittings shall be of standard manufacture as approved by WBSEDCL and shall be in all respects comply with the latest Indian Standard Specifications. the brass fittings shall be fixed in the pipe line in a workmanship like manner. Care shall be taken to see that joints between fittings and pipes are made leakproof . The fittings and joints shall be tested to pressure of 21 kg per sqm. (300lbs. per sq. inch) unless otherwise specified. The defective fittings and the joints shall be repaired or replaced.

26.0 SPECIFICATION OF WATER SUPPLY MATERIALS:

General:

- a) All materials shall be of best of their kind and shall conform to the latest Indian Standard specification.
- b) A set of specification samples of all approved materials shall be kept & well preserved at site by the Contractor for ready reference, cost of which is to be borne by the Contractor.
- c) Over & above the list of specifications, WBSEDCL reserves the right to ask the Contractor for fixing of materials / fittings of equivalent quality other than mentioned in the list.

27.0 DRAINAGE :

27.1 Stone Ware Pipe :

Pipes : All pipes must be new and perfectly sound, free from fire cracks and imperfection of glazing, cylindrical straight and of standard nominal diameter, length and depth of socket. They shall be hard burnt stoneware of dark grey colour and thoroughly salt glazed inside and outside. They should conform IS: 651-1965.

27.2 Trenches for S.W. Pipe Drains :

Excavation : The trenches for the pipes shall be excavated to lines and levels as directed. The bed of the trench shall be truly and evenly dressed throughout from one change of grade to the next.

The gradient is to be set out by means of bending rods and should the required depth be exceeded at any point the trench shall be refilled by means of cement concrete of the specification of the bed concrete, at the Contractor's own expense. the bed of the trench if in soft or made up earth shall be well watered and rammed and depressions thus formed filled with sand or other suitable materials as directed by WBSEDCL before laying the bed concrete.

If rock is met with, it shall be removed to 15 cms. (6") below the level of the pipe and the trench will be refilled with concrete, sand or other suitable material as directed by WBSEDCL to bring it to required bed level. the excavated materials shall be kept away from the edge of the trench at a distance equal to 1 Metre (3 ft.) or equal to half the depth of the trench which -ever is greater.

The trench shall be kept free from water. Shoring and timbering shall be provided wherever required.

The trench width shall be the nominal diameter of the pipe plus 36 cms. (15") but it shall not be less than 52 cms. (21") in case of all kinds of soils excluding rock and not less than 92 cms.(3 feet) in case of rock.

Wherever the drain runs deeper, the width of the trench in the upper reaches may be increased as per the directions of the WBSEDCL.

28.0 ROAD CROSSINGS :

All road crossings shall be excavated half at a time, the second half being commenced ,after the pipes have been laid in the first half and the trench refilled. The trench at the existing road crossings shall be filled in with mud concrete for the full depth except for the 15 cms (6") layer ,which shall be filled with cement concrete 1:2: 4 or as directed.

29.0 PROTECTION OF EXISTING SERVICES:

All pipes , water mains , cables etc., met within the course of excavation shall be carefully protected and supported. Such mains will be hung from timbers placed across the trench. Care shall be taken not to disturb the electrical and communication cables. WBSEDCL may, solely at their discretion, arrange for removal of such services, at the Contractor's cost.

30.0 LIGHTING AND WATCH:

The open trenches shall be provided with requisite fencing and watchman to guard against accidents. Red flags during day and red light during night shall be provided at the ends and at intervals along the sides of the trenches.

Sign boards with necessary wording such as "SLOW, ROAD CLOSED" etc. shall be provided at least 30 metres ahead of road crossing where the work is in progress. The precautions will be continued till the surface is restored.

Temporary bridges or planks shall be provided over the trenches for keeping open the access to private or public property.

31.0 REFILLING:

Refilling in trenches for pipes shall be commenced as soon as the joints and concrete have been passed. The refilling on the top and around the drain shall be done with great care and in such a manner as will obtain the greatest amount of compactness and solidity possible. For this purpose the earth shall be laid in regular layers of 15 cms (6") watered and rammed at each layers. All surplus earth shall be disposed off as directed by WBSEDCL at the Contractor's cost.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

32.0 CONCRETING:

All S.W. pipes shall be laid on a bed of 15 cms. (6") thick cement concrete as specified with projection on each side of the pipe to the full width of the trench and surrounding the pipes all-round with 1:4:8 concrete mix.

All NP-3 RCC pipes below Road crossing / Car Parking areas shall be laid on a bed of 15 cms. (6") thick cement concrete as specified with projection on each side of the pipe to the full width of the trench with 1:4:8 concrete mix.

The pipes with their crown level at 1.22 Metre (4 ft.) depth and less from ground shall be covered with 15 Cms. (6") thick concrete above the crown of the pipe and slipped off to give a minimum thickness of 15 Cms. (6") all-round the pipe or as per construction drawing.

Pipes deeper than these shall be concreted upto haunches level with the top of the pipe.

33.0 LAYING AND JOINTING S.W. PIPES :

33.1 Laying :

The pipes shall be carefully laid to the levels and gradients shown on the plans and sections. Great care shall be taken to prevent sand etc., from entering the pipes. The pipes between two manholes shall be laid in straight line without vertical or horizontal undulations.

The pipes will be laid "socket up" the gradient. The body of the pipe shall for its entire length rest on an even bed.

33.2 Jointing :

The cement mortar joints shall be cured at least for seven days.

33.3 Testing :

All joints shall be tested to a head of 61 Cms. (2') of water above the top of the highest pipe between two manholes. The lowest end of the pipe shall be plugged watertight. Water shall then be filled in manhole at the upper end of the line. The depth of water in the manhole shall be 61 cms. (2) plus the diameter of the pipe. The joints shall then be examined. Any joint found leaking or sweating shall be remade or embedded into 15 Cms. (6") layer of cement concrete (1:2:4) in length and section re-tested, at the Contractor's expense until satisfactory results are obtained.

34.0 GENERAL:

34.1 Under-ground Storm Water Drain Pipes:

NP-3 R.C.C. pipes are used for storm water drainage, on a concreting at pipe bed with 1:4:8 mix. The cement mortar for jointing with the Pipes and Collars will be 1:2 or that as specified in the Schedule of Quantities. Testing of joints also. will be required under a Hydro-static Pressure Test under 1.5 Kg-f / cm² (g) pressure with a minimum Holding time of 1.0 hour and those joints after found tested OK shall be tagged "Tested OK" for those portion of the tested pipe and shall be preserved and care is to be taken during back-filling in such a manner so that there should be no undue load / impact / hammerage on those tested joints so as to make the joint quite sound.

34.2 Precaution:

To avoid logging of drains, both ends shall be kept plugged until the construction of manholes is completed in every respect. On completion, care shall be taken that each plug is removed and the face of the drain made smooth.

34.3 Measurements:

The measurements for providing, laying and jointing R.C.C. pipes shall be recorded for the finished length of the pipe line i.e., from inside of one manhole to the inside of other manhole.

35.0 S.W. GULLY TRAPS :

This must be new, perfectly sound free from fire cracks and other imperfections of glazing of standard nominal diameter and other dimensions . It shall be made of hard burnt stoneware of dark grey colour and thoroughly salt glazed inside and outside.

Each gully traps shall have a C.I. piping 15 x 15 Cms. (6" x 6") and one water tight C.I. cover with frame 30 x 30 Cms. (12" x 12") (inside dimensions) with machine seating faces or as specified.

35.1 Excavation :

The excavation for gully traps shall be done true to dimensions and levels as indicated on plans or as directed by the Engineer-in- Charge.

35.2 Fixing :

The gully trap shall be fixed on cement concrete foundation 70 Cms. (2'3") square and not less than 10 Cms. (4") thick.

The mix for the concrete will be 1 : 3 : 6 (1 Cement : 3 Sand : 6 Stone ballast) 40 mm (1.1/2" gauge) or as specified. The jointing of gully outlet to the branch drain shall be done similar to jointing of S.W. pipes.

35.3 Masonry Chamber :



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

After fixing and testing the gully and branch drain, a brick masonry Chamber 30 x 23 Cms (12" x 9") (inside in first class brick in cement mortar 1:5 shall be built with 11 Cms. (4.1/2") thick around the gully trap from the top of the bed concrete upto ground level. The space between the Chamber walls and the trap being filled in with cement concrete of the specifications of bed concrete. The upper portion of the Chamber i.e. above the top level of the trap shall be plastered inside with cement mortar 1:3 (1 cement: 3 sand) finished with floating coat of neat cement. The corners and bottom of the Chamber shall be rounded off so as to slope towards the grating.

35.4 C.I. Cover :

C.I. cover with frame 30 x 23 Cms. (12" x 9") or as specified with mechanical seating faces shall then be fixed on the top of the brick masonry with cement concrete 1 : 2 : 4 and rendered smooth. The finished top of cover shall be left 15 Cms. (6") above the adjoining ground level so as to exclude the surface water from entering the gully trap.

36.0 MANHOLES , INSPECTION PITS, GULLY CHAMBER ETC. :

36.1 Manholes : (The size of Manholes) : The size specified shall be in the internal size of the manhole. The work shall be done strictly as per drawings and specifications. The following specifications shall be adopted.

36.2 Excavation: The manhole shall be excavated true to dimensions and levels, shown on the plan or as directed by WBSEDCL.

36.3 Brick Work : The brick work shall be with best quality brick in cement mortar 1:4, brick work in arches shall be with 1st class brick in cement mortar 1:4, brick masonry round the pipes shall also be with 1st class brick in cement mortar 1:4, the joints shall be made thoroughly leak proof.

36.4 Bed Concrete : The manhole shall be built on a bed of 15 Cms. (6") thick cement concrete (1 : 3 : 6) over a layer of brick flat soling.

36.5 Plaster :

Inside of the walls be plastered with 12 mm. (1/2") thick cement plaster 1:3 (1 cement: 3 coarse sand) finished with a floating coat of neat cement.

In wet ground, 12 mm. (1/2") thick cement plaster of the above specifications shall be done on the outside surface of the walls also. This plaster shall be done with waterproofing admixture as approved by WBSEDCL. The plastering shall be done upto 30 cms.(1 foot) above the wet soil line. Extra shall be paid for plastering the outside surface wherever directed.

36.6 Pointing :

Pointing shall be done with cement mortar 1:2.

36.7 Benching :

The channels and benching shall be done in cement concrete 1:2:4 and rendered smooth with neat cement. The following sizes of the channels shall be adopted for the benching:-

Size of the Drain	Depth at the Centre	Depth at sides i.e. , at walls
100 mm. (4")	15 Cms (6")	20 Cms
150 mm. (6")	20 Cms (8")	25 Cms
250 mm. (9")	28 Cms (11")	38 Cms
300 mm. (12")	35 Cms (14")	45 Cms

36.8 R.C.C. WORK :

R.C.C. work for slabs or lintels shall be in cement concrete 1:1 1/2:3 with steel reinforcement as per details. Plain concrete, if used for fixing manhole covers, shall be of (1:2:4) proportion, unless otherwise mentioned specifically in the BOQ / drawings etc.

36.9 FOOT RESTS :

These shall be of C.I. standard / or by M. S square rod 22 mm. (7/8") or as specified and shall be galvanized or painted with coal tar. These shall be embedded in masonry in cement mortar at least 23 Cms. (9") while the brick work is in progress. These shall be fixed 30 Cms. (1 foot) apart vertically and staggered laterally and shall not project more than 11 Cms., (4.1/2") from the wall.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

36.10 C.I. MANHOLE COVERS :

The C.I covers shall be of tough homogeneous cast iron of 'heavy' or 'Medium' type as specified in the Bill of quantities, are the clear internal dimensions. The approximate weights of the various types of manhole covers with frames and their internal size will be as per specification in schedule of quantities & conform to IS : 1726-1966. Variations in weight to the extent of 6 percent on either sides shall be permissible. the covers used in manhole on sewer lines shall invariably bear the work 'SEWER' on the top and those used for storm water drains shall bear the word 'S.W.D.' .These markings shall be done during casting of the covers.

The frame of manhole cover shall be embedded firmly in the R.C.C slab or plain concrete as the case may be on the top of the masonry.

After the completion of the work , manhole covers shall be sealed by means of thick mortar greased. All exposed surfaces of the frames and covers shall be painted with coal tar. The cost of such paintings should be included in the Contractor's rates for the manhole cover.

37.0 PLAIN MANHOLE (INTERNAL WORKS):

As per drawing or 60 cms. x 45 cms. (3' x 1'-6") when not mentioned / shown specifically. This type of manhole is minimum generally constructed within compounds for house drainage only. Due to shallowness and narrowness the manhole is provided with cover with bigger opening to facilitate cleaning and repairs. Cover of size 90 Cms. x 45 Cms. (3' x 1'-6") shall be used.

38.0 PLAIN MANHOLE (EXTERNAL WORKS):

As per drawing or 1.2 X 0.9 M (4" x 3") when not mentioned / shown specifically. This type of manhole is constructed for main drainage work for depth less than 2.4 Meters (8").

When the manhole is built on the footpath ,this shall be provided with 45 Cms. (18") internal diameter light type C.I cover , when it is built within the width of the road under traffic, it shall be provided with 53 Cms. (21") internal diameter heavy type C.I cover.

39.0 LEVELS OF INVERT OF INSPECTION PITS AND STORM WATER MANHOLES :

All Invert levels as specified in the drawing to be maintained strictly as minimum requirement. All Invert levels (I.L.) given in the drawings are with respect to the ($\pm$) 0.00 level as specified in the drawings.

Unless some acute problem as per the Site conditions the Invert levels as mentioned in the drawing shall have to be maintained.

For any alterations in Invert levels as per the Site conditions (if any) shall have to be approved by WBSEDCL before executing the job.

The invert of the smaller sewer at its junction with main shall be at least 2/3rd dia. of the main above the invert of the main . The branch sewer should deliver sewage in the manhole in the direction of main flow and the junction must be made with ease so that flow in the main is not impeded.

40.0 MEASUREMENTS:

The depth of the manhole wall be reckoned from the invert level of the channel to the top level as to the C.I cover . The depth shall be measured correct to nearest 25 mm.

41.0 HOUSE CONNECTIONS :

No drain from house fittings e.g. gully trap or soil pipe etc., to manhole shall exceed a length of 6 Meters (20 feet) unless it is unavoidable.

42.0 DROP CONNECTIONS (DROP MANHOLES) – IF ANY :

In case where branch pipe sewer enters the manholes on main pipe sewer at a higher level than the main sewer, a drop connection should be provided.

C.I. Inspection bend shall be fixed in position at right angle to the drop pipe at the level of the inlet branch drain. The plain C.I. shoe at the bottom shall be fixed in the benching cement concrete 1:2:4 (1 cement : 2 sand : 4 stone ballast ¾" size) so as to discharge into the channel (the joints be lead caulked as per specification for the cast iron pipes for water supply).

43.0 C.I. PIPE DRAINAGE :

43.1 C.I. Drainage :

C.I. pipe drainage shall be adopted (IS-3989 or IS-1729) in the case mentioned below:-

- When the drain passes under a structure.
- When the drain passes under a road which is subject to heavy traffic and where the covering cushion is not considered sufficient.
- When the drain passes through a place where it is subjected to vibrations.
- In hilly places where the slopes are very steep.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

e) When drainage lines run on the surface or above ground.

43.2 Trenches :

Specifications for trenches for stoneware pipe drains will apply in this case.

43.3 Pipes :

The pipes used shall conform to the Indian Standard specifications for class "A" pipes.

43.4 Fittings :

C.I. trap with hopper, C.I. inspection bends C.I. inspection Chambers etc., shall conform to Indian Standard specifications for C.I. fittings.

43.5 Laying :

For laying C.I pipes and fittings, specifications for C.I water mains will apply.

The joints for pipes and fittings shall be lead caulked joints under water supply. the joints shall be leak proof.

All inspection doors etc., shall be provided with felt washers and strong brass bolts and nuts.

43.6 Testing :

Testing of joints for C.I pipes and fittings shall be done by smoke test as specified under C.I pipes and fittings.

43.7 Masonry Chamber :

C.I inspection chambers and bends for underground shall be enclosed in masonry chambers.

Note:

In case of non- availability of any particular brand of material as specified in the Bill of Quantities bidder may propose any other equivalent approved brand or material or equipment conforming to the latest I.S specifications subject to the approval of WBSEDCL.

LIST OF APPROVED MANUFACTURER

Sl. No.	Description of Approved Material	Approved Brand / Manufacturer
1	G.I. Pipes - medium class (As per IS-1239, P - I)	TATA
2	G.I. Pipe fittings (As per IS-1239, P - II); of material with Galvanized Cast Iron Fillings, with material code conforming to IS- 1879	HB/ "NB' I "ZOLOTO"/Leader or as approved by WBSEDCL
3.0	C.P. on brass fittings	
3.1	CP Bib cock	ESSCO 'Delux' or equivalent as approved by WBSEDCL
3.2	CP 'Long Nose' /or' Long Body' Bib cock	Do -
3.3	CP Angle valve	Do -
3.4	CP 'Concealed' Stop cock 'Heavy' type with adjustable CP wall Flange	Do -
3.5	CP Shower Rose	Do -
4	Gun metal body Ball Float valve with PVC (High pressure) Ball Float	Zoloto" / Leader"/ "Sant" or as approved by WBSEDCL
5	15 mm dia. PVC Connector pipe with Symet nuts at both ends. - (for Wash Basin Pillar tap &W.C. &Urinal -Cistern connections)	PRAYAG or equivalent as approved by WBSEDCL
6	Wall Outlet Connection Flexible Pipe - 15mm dia	"Jaquar" or equivalent as approved by WBSEDCL
7	Bronze /Gun metal-body Gate valve with threaded screwed ends, "Non-rising Spindle" type (PN-1.0) / or (PN-1.6) class	Sant / "Leader" / "Zoloto"-for Bronze body or equivalent as approved by WBSEDCL



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

8	Bronze -body Globe valve with 'BSPT(F), threaded screwed ends, "Non-rising Spindle" type (PN-1.0) (PN-1.6) class	'Zoloto' / 'Leader' or equivalent as approved by WBSEDCL
9	CI body Gate /Sluice valve with flanged ends rising Spindle" type IPN-1.0\ 1 or IPN-1.6) class	Zoloto / Leader / Sant or equivalent as approved by WBSEDCL
10	CP Urinal Spreader-15mm (for Urinals only)	Hindware / Parryware / Neycer or equivalent as approved by WBSEDCL
11	Soil, waste & vent pipes I and Pipe Fittings & Specials :- C.I. Centri cast (as per 15-3989)	'NECO'I 'HEPCO' 1 'KAPILANSH DHATU UDYOG (P) L TD.'
12	Sanitary wares (Vitreous chinaware) :- W.C. - (European type) – with 'S' I 'P' -Trap - Floor mounted type, without PVC Flushing Cistern, ii) Wash Basins - "Oval" pattern "Under Counter" type - with Jaquar Sensor Pillar Tap, iii) Urinal - Flat back "Large" with CP Spreader, CP Waste coupling, CP Bottle Traps with waste pipes & also with "Jaquar" Sensors with installation box.	'Hindware- /'Parryware' / 'Cera' /'Neycer' or equivalent as approved by WBSEDCL
		Wash Basin :- 'Hindware' - /Parryware / Neycer or equivalent as approved by WBSEDCL
		WC flushing :- PVC 'Low-level' "Dual- Flush" Cistern of 'Hindware' / Parryware / Neycer
		Urinals :- Hindware / Parryware /Neycer
		Urinal Partitions 'Division Plate' :- 'Hindwarwe'/Parryware/Neycer or equivalent as approved by WBSEDCL
13	Wall Mirror	6mm thick 'Saint Gobain' /'Modiguard' / 'Ashai' or equivalent as approved by WBSEDCL, with 12mm thick hard-board backing
14	C.P. on brass fittings	
14.1	C.P. on brass fittings C.P. Waste Coupling, ii) C.P. Bottle Trap, iii) C.P. Robe Hook, iv) C.P. Towel Rail. v) CP Two way Bib Tap	ESSCO 'Delux' or equivalent as approved by WBSEDCL
14.2	CP Toil. Paper Holder	Do -
14.3	CP Towel Ring	Do -
14.4	CP Soap Dish Holder	Do -
14.5	CP Bottle Trap with CP wall connection Pipe	Do -
14.6	CP Robe Hooks	Do -
14.7	CP "Two-way" Bib cock	Do -
14.8	CP Shower Rose	Do -
15	Rigid PVC (Concealed) Waste pipe, [Schdl.-40], (as per ASTM D .1785)- (concealed or exposed)	Supreme / Oriplastor equivalent as approved by WBSEDCL
16	Rain Water Pipes :- PVC' - "SWR" class, ' as per (IS: 13592)	NECO/'HEPCO'/'KAPILANSH DHATU UDYOG (P) Ltd. or equivalent as approved by WBSEDCL
17	Rain Water Pipe Fittings :- 'Sand cast Iron' - "SWR" class, as per (IS: 13592)	DO
18	Salem Stainless Steel Sink as per AISI 304 (18/8) conforming to I.S.- 13983	"Hindware" / "Hafele" / ""Nirali" / 'Parryware' or equivalent as approved by WBSEDCL
19	Stainless Steel Kitchen Chimneys	Kutchina / Hindware or equivalent quality as approved by WBSEDCL



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

20	Stone- Ware Pipes, and S.W. Pipe Fittings	Sonali / GINNI / NIRALI or equivalent as approved by WBSEDCL
21	C. I. Manhole Cover (I.S. - 1726) - "Medium" or "Heavy" Grade' (Light duty only on Oil/Grease Trap Chamber)	NECO' / 'HEPCO' / Swastika / 'BPL' or equivalent as approved by WBSEDCL
22	NP-2 class R.C.C. Pipes and Pipe Fittings (i.e., RCC Collars etc. ,)	Eastern Spuncrete / 'West Bengal Concrete Industries (P) Ltd. / 'HINDUSTAN' / 'SUR' or equivalent as approved by WBSEDCL
23	Stone- Ware Gully Trap	Sonali / GINNI / NIRALI / Hind or equivalent as approved by WBSEDCL
24	C. I. Grating- (Over Catch Pit I Yard Gully Chamber), (I.S. - 1726) - "Medium" or "Heavy" Grade	NECO' / 'HEPCO' / 'BPL' or equivalent as approved by WBSEDCL
25	"Enclosed" type Analogue type Water Meter ("Bulk" Type), conforming to IS- 2373 with Calibration Certificate, including all necessary accessories	"Dashmesh" / 'Kaycee" / "Capstan" or equivalent as approved by WBSEDCL
26	Bronze body "Parallel Slide" 'Blow-off valve ("Spring loaded, blow-off pressure sellable" type), with flanged ends, also with matching Flanges (PN-1.0) / or (PN-1.6) class	'Zoloto' / Sant / Leader or equivalent as approved by WBSEDCL
27	Air-Release Valve	
	Bronze body "Parallel Slide" 'Blow-off valve ("Spring loaded, blow-off pressure sellable" type), with flanged ends, also with matching Flanges (PN-1.0) / or (PN- 1.6) class	Zoloto' / Sant / Leader or equivalent as approved by WBSEDCL
28	Bronze I Gun metal -body Ball valve with 'BSPT(F), threaded screwed ends, "quarter turn Lever operated" type IPN-1.m / or (pN-1.6) class	'Leader' / 'Zoloto' / Sant or equivalent as approved by WBSEDCL
29	Gaskets-CAF 'Full face' conforming to IS-2712, Gr.- C; (3mm thick)	"Klinger" / "Permanite" / "Champion" or equivalent as approved by WBSEDCL



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

SECTION-VIII

SPECIAL CONDITIONS OF CONTRACT AND TECHNICAL SPECIFICATION FOR ELECTRICAL WORKS



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

SPECIAL CONDITIONS OF CONTRACT AND TECHNICAL SPECIFICATION FOR ELECTRICAL WORKS

1.1. GENERAL:

1.1.1. These Special Conditions of Contract supplement the preamble and General Instructions, General Condition of Contract, Bill of Quantities and basic rates and Technical Specifications and tender drawings (if any) enclosed thereto, and shall be considered as part of the Tender Papers. Where the provisions of these Special Conditions of Contract are at variance with General Conditions of Contract, the Provisions of these Special Conditions of Contract shall prevail.

1.1.2. The several documents forming the tender are to be taken as mutually complementary to one another. Detail drawings (if any) shall be followed in preference to small-scale drawings and figured dimensions in preference to scaled dimensions.

1.1.3. If there are varying or conflicting provisions in the documents forming part of the contract, the Engineer-in-Charge shall be the deciding authority with regard to the intentions of the provisions and his decision shall be final and binding on the contractor.

1.1.4. The Employer reserve the right to exclude any of the Schedule Items on reasons of the rates not being reasonable or subsequent change of design for evaluation of tender and deciding the contract.

1.1.5. The Contractor may be required to carry out any additional or alteration work other than the specified in the Schedule of work/bill of quantities as and when required, by the 'Employer' within the completion period of the project.

1.2. SCOPE OF WORK:

The works to be governed by this contract shall cover designing and transportation up to destination, safe custody at site, insurance, erection, testing and commissioning of the following:

Electrification of new building including outer spaces.

Earthing of installations as per relevant Indian Standard Specifications. All other earthwork and masonry work required to be done concerning the electrical works.

1.3. DRAWINGS:

Contractors shall prepare all the detailed design and working drawings and submit them to the Employer for approval within, 15 days from the date of award of contract.

The working drawings shall be furnished in triplicate furnishing physical dimensions of the equipment, constructional details, disposition of bus bar, terminal connection etc.

The electrical layout, clearly indicating the electrical clearances with Schematic diagram shall be furnished in triplicate for approval.

1.4. EXECUTION OF WORK:

All the works included in electrical schedule of works i.e. power panels, distribution boards, equipment layout, electrical wiring, street lighting, cable laying, earthing etc., have to be done as per approved drawings and directions given at site by the Engineer-in-Charge.

1.5. ELECTRICAL LICENSE:

Only a Contractor holding a valid Electrical License and issued by the Licensing Board, Government of West Bengal/India (Current engagement of Electrical Supervisor at prospective bidder's firm needs to be established through notary attested contract agreement on Non-Judicial Stamp Paper)

1.6. INSPECTION:

The inspection officer(s) for this contract shall be nominated by the Employer and notified to the contractor. The cost of the inspection will be on Employer's account subject to any other provisions contained hereunder elsewhere in the contract. One week's notice must be given by the Contractor to the Inspecting Engineer to take Inspection. The Contractor shall provide without any extra cost of the Employer all materials, equipment, tools, labour maintenance of every kind which the Employer's



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Inspecting Engineer may consider necessary for any test examination to be made at the Contractor's premises and at site and shall pay all attended thereon.

All the equipment and materials shall be tested / inspected by the Employer or its authorized Inspecting Engineer approved before they are installed / used in the execution of the works covered in the contract. If the Contractor any equipment / materials without the prior approval of Employer, those are liable to be rejected. The exact position of all switch boards, OPDs and all runs-of-mains, sub-mains and distribution wiring to individual points including exact positions of all light fittings and switch-boards shall be first worked on the buildings and shall have to be approved by the Engineer-in Charge before actual commencement of work.

1.6.1. The Inspecting Engineer or his authorized Representative shall have at all times access to the Contractor's premises and shall have the power to :

- i) Inspect and examine the materials and workmanship of the work at any time during the manufacture at the manufacturer's premises or in the premises of the contractor or at the site of the erection.
- ii) Reject any part of the work submitted by the Contractor as not being in accordance with the contractor.
- iii) Reject the whole of the work including equipment tendered of inspection if after the inspection of such portion as he may, in his discretion think fit, he is satisfied that the same is unsatisfactory.
- iv) Mark the rejected equipment with a rejection mark so that the same may be easily identified
- v) Re-inspect at the time of erection at site any equipment both previously inspected and approved by the inspecting Engineer at the Contractor premises. Notwithstanding any approval given earlier, the Contractor shall make good such rejections made based on such re-inspection at site to the satisfaction of the Engineer.
- vi) The decision of the Inspecting Engineer as regards to the acceptance or rejection of equipment /work shall be final and binding to the Contractor.

1.7. CONSEQUENCE OF REJECTION.

On the equipment /assemblies being rejected by the Inspecting Officer of the Employer at destination the Contractor shall replace such rejected equipment/assemblies of the work forthwith but in any event not later than a period of 2 (two) weeks in the case of minor equipment and 4 (four) weeks in the case of major equipment from the date of rejection. The Contractor shall bear all the costs of replacement including freight, etc., but without being entitled to any extra time on this account. The decision as to whether the equipment is to be classified as Minor or Major for the purpose of this clause shall be that of the Engineer and it is not questionable.

1.8. INSTALLATION:

1.8.1 All works connected with and inclusive of installation and erection under this contract shall be done in accordance with the standard and established methods of installation and erection of electrical equipment and shall comply with relevant Indian Electricity Rules, National Electrical Code, BIS Codes of Specifications and Standards. The work shall also be strictly in accordance with the instructions / recommendations of the manufacturers. The equipment shall be levelled carefully before being fixed finally in position- All fragile and sensitive equipment shall be protected adequately and handled carefully during installation and erection.

1.9. COMMISSIONING TESTS.

1.9.1. As soon as the installations are ready for commissioning / sub-station, the Contractor shall arrange for all the tests / inspection as required by the relevant ISS and / or IE Rules and advise the Employer and others concerned. Employer shall depute their Inspecting Officer for witnessing the tests and to carry out inspection independently and also jointly with other concerned agencies where ever necessary and only after the installation passes the required tests and inspection, it should be commissioned / energized.

1.9.2. The Contractor shall take full responsibility for these tests. For site tests the Employer where possible, may permit the Contractor for the purpose of testing, the use of any instruments / apparatus and electric power which the Employer can conveniently work not complying with the specifications, the Employer at their discretion ask the Contractor to pay the cost of providing the additional energy required. The Contractor shall provide all apparatus and energy, which may be required for drying out the equipment in a manner approved by the Employer. If, by reasons of the Contractor failing to comply with any of the provisions of this clause, any of the said tests are to be repeated the Contractor shall pay all fees and expenses in connection therewith.

1.9.3. Visual Inspection shall include checks for satisfactory workmanship, all connections, painting, plastering, cleanliness of all fittings etc., and compliance with Indian Electricity Rules.

1.9.4. The ammeters, voltmeters, and energy-meters shall be checked for their calibration, scale, accuracy, etc. for compliance with the specified requirement.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

1.9.5. Manufacturer's Test Certificates shall be furnished as evidence that type tests have been made in accordance with IS: 3231. Type test results together with appropriate drawings and records of any relevant alteration, which may have been made to any relay after the type test, shall be made available.

i) Certificates of compliance to routine test shall also be furnished.

ii) Routine tests shall be carried out at manufacturer premises before commissioning in compliance with IS:3231

iii) Routine-tests are to be carried out on presence of Engineer-in-Charge and test certificates are to be submitted.

1.9.6. All cables shall be tested at manufacturer's works in compliance with relevant standards. All cables and connections after erection shall be tested as required by the Employer for:

i) Pressure Test,

ii) Insulation Test.

1.9.7. Earth resistance shall be measured separately for each earth electrode and when they are connected together and to the equipment recorded.

1.10. WARRANTY:

1.10.1 Contractor shall guarantee that all the equipment and the works executed under this contract shall be free from all defects and faults in materials, design, workmanship and manufacture and shall be of acceptable standards for the contracted work and in full conformity to the technical specifications, drawings and other contract stipulations.

1.10.2 The Contractor's liability in respect of any complaint defect and/or claim shall be limited to the execution, installation and erection of replacement parts free of charge, or the repair of defective parts only to the extent that such replacement or repairs are attributable to or arise from faulty workmanship or design or material in the manufacture of the equipment/stores, and or negligence in any manner and also in the event of failure of the equipment to perform as intended.

1.10.3 The Contractor shall, if required, replace, repair, execute and / or install the goods or such portion thereof as in rejected by the Employer free of cost at site or at the option of the Employer the contractor shall pay to the Employer the value thereof and such other expenditure and damage as may arise by reason of the breach of the conditions therein specified.

1.10.4 If, any defect is not rectified satisfactorily within the above mentioned one month, the Employer may proceed to do the work at Contractor's risk and cost and without prejudice to any other rights of the Contractor under this contract.

1.10.5 If the Contractor so desires, the replaced parts can be taken over by him or his Representative for disposal as he deems fit within a period of one month from the date of replacement of goods/parts. At the expiry of this period, no claim whatsoever shall lie on the Employer.

1.10.6. The Employer may, at their discretion recover the ground rent for the goods/parts which have been rejected during the warranty period for the specified period of one month, if the rejected materials are not taken over within that period one month, by the Contractor or his Representative.

1.10.7. The warranty herein contained shall not apply to any material which have been repaired or altered by the Employer, or on their behalf in any without the consent of the Contractor so as to affect its strength, performance and reliability or to any defects to any part due to misuse negligence or accidents and to items of normal wear and tear to be specifically mentioned by the Contractor in his offer and got accepted by the Employer. The decision of the Employer concerning Contractor's liability and the amount if any payable, under this warranty, shall be final and conclusive.

1.11. SUPERVISION OF ELECTRICAL WORKS:

The said works will be supervised by the concerned Officers of the Electrical Wing of WBSEDCL.

1.12. MODE OF MEASUREMENT:

1.12.1. Measurement of Electrical works should be done by the competent officers of the Electrical Wing of WBSEDCL in Measurement Book according to Priced Schedule and Agreement.

2.0 SUB POWER-DISTRIBUTION BOARDS (PDB/EPDB) AND LIGHTING DISTRIBUTION BOARDS (LDB/ELDB) SERVICE/METER BOARDS AND MAIN SWITCH BOARDS.

2.1 All the PDB/EPDB/LDB/ELDB, Service Meter and Main Switch Boards shall be of robust construction and suitable for flush-mounting /wall mounting type. They must be of industrial heavy duty type, compartmentalized and fabricated out of 14 SWG sheet-steel with MS angles and channels of suitable sizes wherever necessary, totally enclosed, fully gasket, dust and vermin proof, removable top and bottom plates with suitable knockouts at appropriate location for entry of 20.25 and 40 mm dia PVC/MS conduits, hinged front doors (single or two half doors depending upon the size of the board) with locking arrangements & two earthing terminals etc. to be provided.

2.2 Service Meter Boards housing front operated SFUs, terminal blocks, fuse cut-outs, kWh meters etc, shall be provided with suitable arrangements for locking and sealing front door. Suitable cut-outs and glass windows in front of kWh meters shall be provided for taking readings and for periodical watching meters working.

2.3 PDB/EPDB, LDB/ELDB service meter boards and main switch boards shall be complete with all the equipment such as MCCBs, MCBs, Isolators, SFUs, Fuse Cut-outs, kWh meters etc. as indicated in the Schedule of Quantities for the incoming



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

and outgoing circuits, suitably rated copper bus bars, neutral links, internal wiring, phenolic phase barriers wherever necessary, clearances between phases, phases-neutral and earth maintained as per relevant IS and properly painted with anti-corrosive primers and finish paints. Finish colour should be as per client's choice.

3. Moulded Case Circuit Breaker (MCCB)

MCCBs are required for use in three phases, 400 Volt feeders for "On-load" closing and opening. Current rating shall be as indicated in the Schedule of Quantities. Breaking capacity at 415 V and P. Between 0.2 and 0.4 shall not be less than 25 KA for 100 A, 35 KA for 200 A, 35 KA for 250 A, 50 KA for 400 A and 50 KA for 630 A rated MCCBs. The MCCBs shall have mechanism for quick make and break operation and provided with thermal magnetic release for short circuit and over current protections. There shall be provision for setting the short circuit tripping between 300% and 800% and over-load tripping between 50% and 100% of the nominal rating in addition to continuous current setting (IR) in 5 steps between 100% and 50% of nominal rating. All the PCCs, MCCs are to be provided with door interlocking arrangements.

3.1. A power circuit shall always be originated from a distribution fuse boards and the same shall run in a separate PVC conduit/cable as considered in general scheme.

3.1.1. Insulated or covered earthing conductors where used, shall have green insulation braiding or covering as appropriate. Under as circumstance shall the colour green be used for other than earthing conductor. In addition where it is required that cables of different colours be used for identification purposes; the following system shall be employed. Red, Yellow and Blue colour for phases and black for neutral only.

3.1.2. The electric load of all lights, power outlets etc. shall be balanced across the three phases.

3.1.3. Unless otherwise mentioned in the schedule of quantities, single way porcelain /Bakelite terminal connector with nickel-plated brass pin and screws to suit the conductor. Size shall be used for intermediate wiring joints in junction boxes and switch-boards.

3.1.4. Distribution wiring in PVC conduit casing capping to light, fan, socket outlets, exhaust fan points etc. shall be done in looping in system. In this system except at stopping points such as at terminals of switches, ceiling-roses, etc, and in case of socket outlets at the socket terminals. Intermediate wiring joints in junction boxes will not be permitted.

3.1.5. The maximum number of wires drawn in one PVC conduit shall not be greater than the recommended number given in the table of IS. 732-1963, contractor must consult the specification given above.

3.1.6. Sub-mains are considered for the wiring from PDB to power outlets LDBs and point control switch boards. These may be by two-core PVCA cable/PVC insulated sheathed copper conductor wires as considered in bill of quantities.

4. POINT WIRING IN BUILDINGS.

4.1 Wiring in the buildings shall be concealed /surface drawn. PVC conduits, conduit accessories, PVC casing, capping cables, ceiling-roses, switches etc. used in the wiring shall be of approved makes. All wiring to be done by stranded single core copper PVC cable of sizes 1.5 Sq.mm. for phase and neutral and one sq. mm., copper PVC cables for earth wire (Green colour). In case of rewiring partially, the similar cables are to be used as existing.

4.2 Laying of conduits, conduit accessories and wiring in concealed and surface system shall meet the requirements of IS-732; National Electrical Code and National Building Code.

4.3. The PVC and MS conduits shall conform to IS: 9537 (part 1 and 3) and IS: 1653 respectively. Metal junction boxes/PVC junction boxes shall be used with PVC/MS conduits as the case may be. Conduit accessories such as junction boxes / pull boxes, outlet boxes, bends. Sleeves etc shall conform to IS: 5133. Necessary GI pull wire of 14 SWG shall be provided in the conduits from one end to the other as required for drawing electrical wires.

4.4. PVC conduits/Alkathene pipes shall be laid as far as possible in straight runs tied to the reinforcement bars to prevent the getting dislocated during concreting. Where conduits are required to be embedded in the walls, the walls shall be chased to the required depth and conduits fixed in position by means or suitable pipe hoods at every 600 mm distance in an approved manner. The walls chased for conduit embedding shall be covered suitably by the Electrical Contractor.

4.5. Preparing switch board covers, control switches for all lights, fans, call bells, exhaust fans, ceiling roses, PVC insulated electrical wires, bond wire etc. are parts of Schedules for point wiring. Similarly, conduits laying covered under a separate schedule item include providing and embedding Alkathene pipe/MS conduits in RCC roof slabs/beams, walls, MS junction boxes, bends, outlet switch boxes with 3 mm thick Phylum sheet, fixing brass screws and cup washer etc. in running meter measurement. Switch-boards may be of double teak-wood board with Phylum cover or MS with Phylum cover as the case may be.

4.6. Terminal/outlet/switch boxes shall be of MS sheet of not less than 1.5 mm thick and provided with 4/6/8 threaded holes depending upon the size of the box. The depth of the boxes shall not be less than 75 mm and the centre cross sectional area in between from 100 to 750 Sq. cm. The boxes shall be provided with two coats of anti-corrosive paint and the inside surface finished with suitable white paint. The front cover should be of 3 mm thick colored or white Phylum sheet and over size by 1 cm, all round shall be provided with suitable brass screws & cup-washer for MS Board only.

4.6.1. Sheet Metal Connector Box (16 SWH) of the following sizes with 3 mm thick white Phylum sheet cover is to be used:

6" x 4" x 2.1/2"

7"x4"x2.1/r

8"x6"x2.1/2"

4" x 4" x 2.1/2"

4.6.2. In case of surface wiring by casing capping, the double T. W. Switch Board and Junction Box of the following sizes (with 3 mm thick white Phylum sheet cover fixing by four Nos brass wooden screw with Cup-washer) are permitted:

i) Double T. W. Switch Board: 7- x 4" x 2" / 8" x 6" x 2" / 8" x 10" x 2" / 8" x 12" x 2".



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

ii) Junction Box: 7"x 4"x 2"/ 4"x 4"x2".

4.6.3. **T.W. Round Block (75" mm dia):** There shall be 3 mm wide and 3 mm deep-groove cut all round the surface against which the bottom of cover will rest and approved plastic compound shall be filled before fixing it finally.

4.6.4. **Installation of Switch Board:**

These shall be installed at a height of 1.3 meters (4'-3") above the floor level.

4.6.5. **Brief details of use of specific wire-sizes/switches/sockets are given below:**

- a) For light, fan, call bell and Standard 1.5 Sq. mm single core 6A plug point PVC Unsheathed copper
- b) For connecting air-conditioners Board with 20 amp capacity industrial type socket (Crompton/Standard/Havells) with MK-I starter.(L&T) with 20 ampere MCB.
- c) All main and sub-main power cables will be of Aluminium armoured.
- d) For air-conditioners, in-coming power supply cable will be of 7/0.36 mm stranded size (phase and neutral) and for earth 2.5 sq. mm (3/0.036 mm) stranded single core copper cable from separate way of PDB

e) Composite 6 in 1 plug-socket board (with following provisions) should be provided in selective areas:

i) 16 Amp Socket flush type

ii) 6 Amp Socket flush type

iii) One switch 16 Amp Socket flush type

iv) One fuse flush type

v) One indicating lamp flush type

vi) 6 Amp one way flush type switch

f) Such composite 6 in 1 plug-sockets should be provided in different places as per Guide line. I) All vertical-drops (wiring) should be concealed for horizontal portion only.

g) In horizontal cases, PVC casing and capping permits surface-drawn wiring. But in new OT — both horizontal and vertical wiring should be concealed.

h) OT switch boards should be water protected as design to be approved by site-m-charge.

i) For lights/fans/call bells/engaged sign etc. circuit wiring is a part of point wiring. Maximum load per circuit will be 800 watts but number of points should not exceed eight (8) leaving behind two (2) points for future loads.

5.1 EQUIPMENTS AND FITTINGS.

5.1 The type, rating, the required features, location of fixing etc. are indicated in the Schedules. The schedule includes all other required accessories, fasteners, small wiring etc., fixing, aligning, connecting, testing and commissioning. The materials shall be of good quality acceptable to Engineer-in-Charge and to be fixed in position as directed by him.

5.2 Box/Rail Type Fluorescent Light Fittings.

Both single and twin tube assemblies shall be of standard fittings made out of cold-drawn sheet steel stove enameled, the box finished in grey colour and its cover plates in white colour, complete with copper chokes, starters, starter holder, tube holders, lamps and earth terminal etc.

5.3. Decorative Type Fluorescent Light Fittings.

Similar to 7.2. with opal acrylic diffuser Mirror Optics Type Fluorescent Light Fittings Both single and twin tube assemblies shall be of standard fittings made out of cold-drawn sheet steel, stove enameled, the box finished in grey colour and its cover plates in white colour, complete with copper chokes, starters, starter holder, tube holders, lamps and earth terminal etc. with mirror reflector.

5.4. Compact Fluorescent Type Light Fittings.

Compact fluorescent fitting with 2 x 11 Watts lamps, holders, stainless steel reflector with housing and OPEC **Street Light (TFL) Fittings.**



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

5.5 The fittings shall be SON/70W/150W or weather proof type fluorescent street light fittings. The fittings shall be made of Aluminum sheet and finished outside in hammer tone grey colour, stove Enameled and white inside complete with copper wire chokes, starters condensers, suitable lamp.

5.6. Control switches for lights, fans, call bells, exhaust fans etc. shall be of rating 6 Amps, 230 Volt, Piano-type flush mounted, cream colour conforming to relevant Indian Standards. Ceiling roses also shall be of 6 Amps, rating 230 V. cream colour deluxe conforming to the relevant IS - Specification Switches of 16 Amp capacity and associated 16A socket would also be required to provided facility of connection of power load upto 1 kW. Alternatively, Industrial type plug-socket board may be used in specific cases. Cable used for power load should be of suitable capacity.

5.7. After successful completion of the work, the final drawing/Blue Print Plan showing the details circuit diagrams and fittings, fixtures are to be submitted along with the final bill.

6.0. EARTHING

6.1. All non-current carrying metal parts of the electrical installations such as switch gears, LT panel, distribution boards, power plugs, exhaust fans, air conditioners, cable glands, MS conduits, switch boxes etc. shall be bounded together suitably and connected to earth-stations in accordance with the requirements of Indian Electricity Rules and IS: 3043.

6.2. All earth stations shall be of the same type similar to one illustrated in IS: 3043, using pipe electrode of galvanized steel Class B having 65 mm dia and a length of 3.04 meter buried vertically in the ground and providing layers of charcoal/coke and salt as necessary. The top end of the pipe electrode shall have suitable arrangements for making connections of earth wire/flats in the manner approved by the Engineer-in Charge. The earth stations shall be located at least 2 M away from the buildings and not less than 6 M apart. Nearby earth stations (at least two) shall be interconnected with suitable size GI flat.

6.3. The earth inspection pit should be provided with brick and cement work of 254 mm (10") thick with 1st Class bricks in cement mortar (6:1) both inside and outside plastered 19 mm (3/4") thick and including neat cement finish 1.6 mm in thickness both inside and top outside & C. 1 manhole 0.46 Mt. dia. complete with C. I. cover (weight being 32 kg) fixed flush with ground surface. The inside dimension when finished should be 0.60 m x 0.60 m (2 x 2) and 0.40 m (1' -3" in depth).

6.4. Earth connections shall be as follows:

i) For building wiring the earth lead will be drawn from earth electrode to earth bus-bar by 19/10 G.L stranded wire and from earth bus-bar to PDB 8 SWG GI wire & from PDB to , SDB & LDB etc. by No. -10 SWG G.I wire. For Power plug and 6 amp plug, either by 1 Sq. mm stranded copper/16 SWG G.I. wire as the case may be which will be mentioned in B.O.Q.

ii) Double connections shall be made for medium voltage supply. (251 to 650 V).

iii) All earth wires and flats from one end to the other shall be continuous and without any joints and so laid to protect them against mechanical damage.

iv) If the required earth resistivity is not obtained with the earth-pits, additional pits shall be made for improving the system resistivity. The rates payable for additional pits shall be same as the rates quoted in the tender.

v) Earthing Schedule includes supply of all required material, digging pits, providing charcoal / cake and salt, filling up the pits (providing cement concrete chamber with cover for substation earthing only for laying of earth wires / flat making connection with proper fasteners, finishing machinery works that have been disturbed for electrical works, testing etc.

THE FOLLOWING INDIAN STANDARD CODES ARE APPLICABLE

i. IS: 732/1989 - Code of practice for elec. installation.

ii. IS: 1646-1961 - Code of practice for safety of Building (General Electrical Installation)

iii. IS: 3646 Part -I - Code of practice Principles Part - H and Part - m for good lighting and aspects of design, schedule for values of illumination and glare level and calculation of Coefficient of utilization.

iv. IS: 4347-Code of practice for Hospital lighting.

v. NEC - 1985 - National Electrical Code for hospital and-Operation Theatre.

vi. IS: 3480 - Flexible Steel Conduits for Electrical Wiring

vii. IS: 2667 - Fittings for rigid Steel Conduits for Electrical Wiring

viii. IS: 3837 - Accessories for rigid Steel Conduits for Electrical Wiring.

ix. IS: 9537 Part-II- 1983-PVC Conduits for Electrical wiring.

x. IS: 694 - 1977 - Specifications for PVC insulated Cable for working voltage up to and including 1100 Volts.

xi. IS: 8130-1984 - Specification for Conduits for insulated Electrical Cable and Flexible Cords.

xii. IS-5563 -Electrical Power Connectors.

xiii. IS: 3854-1958 - Flush type Switches.

xiv. IS: 1293-1985 - 3 Pin Sockets.

xv. IS: 6538- 1971 - 3 pin piano top.

xvi. IS: 371-1979-Ceiling Roses.

xvii. IS: 374-1979-Ceiling Fan.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Section-IX
ANNEXURE



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-I

PROFORMA OF BANK GUARANTEE FOR BID GUARANTEE/SECURITY

The non-Judicial stamp paper of Rs 100.00 should be in the name of issuing bank.

Ref..... Bank Guarantee No.

Date.....

To

The

.....

.....

West Bengal

Dear Sirs,

In accordance with Invitation to bid under your Bid No..... M/s..... having its Registered/Head Office at.....(hereinafter called the "Bidder") wish to participate in the said Bid of.....and you, as a special favour have agreed to accept an irrevocable and unconditional Bank Guarantee for an amount of..... valid upto..... on behalf of Bidder in lieu of the Bid deposit required to be made by the bidder, as a Condition precedent for participation in the Said Bid.

We, the.....Bank (Name) at.....(address) having our Head Office at..... guarantee and undertake to pay immediately on demand by West Bengal State Electricity Distribution Company Ltd., the Amount of..... (in words & figures) without any reservation, protest, demur and recourse. Any such demand made by said 'Owner' shall be conclusive and binding on us irrespective of any dispute or difference raised by the Bidder.

This Guarantee shall be irrevocable and shall remain valid upto and including.....

If any further extension of this guarantee is required, the same shall be extended to such required period (not exceeding one year) on receiving instruction from M/s..... on whose behalf this guarantee is issued.

In witness where of the Bank, through its authorized office, has set its hand and stamp on this.....day of20.....at

.....
WITNESS

.....
(Signature)

.....
(Signature)

.....
(Name)

.....
(Name)

.....
(Official Address)

.....
(Official Address)

* This date shall be 30 (thirty) days after the last date for which the bid is valid.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure- II

PROFORMA OF LETTER OF UNDERTAKINGS (To be submitted by the Bidder along with his Bid) (To be executed on non-Judicial stamp paper of requisite value)

Ref.....

Date.....

To

Dear Sir,

1. I/We* have read and examined the following Bidding Documents relating to the (full scope of work).
 - a) Notice Inviting Tender
 - b) "Invitation to Bid" (INV), "Instruction to Bidders (ITB)", "General Conditions of Contract (GCC), Scope, and other conditions of contract.
2. Technical Specification.
 - a) and relevant Drawings.
3. I/We* hereby submit our Bid and undertake to keep our Bid Valid for a period of 120/180* days from the date of opening price bid. I/We* hereby further undertake that during said period I/We* shall not vary alter or revoke my/our Bid. This undertaking is in consideration of WBSEDCL, agreeing to open my/our* Bid and consider and evaluate the same for the purpose of award of Work in terms of provisions of clause entitled "Award of Contract" under Section "Instruction to Bidders (ITB)" in the Bidding Documents. Should this Bid be accepted, I/We* also agree to abide by and fulfill all the terms and conditions of provisions of the above mentioned Bidding Documents.

Signature along with Seal of Co.....

(Duly authorized to sign the Tender on behalf of the Contractors)

Name.....

Designation

Name of Co.....

(IN BLOCK LETTERS)

WITNESS

Signature.....

Date.....

Name & Address.

Telegraphic Address.

Telephone No. Fax No.....

E-mail.....

***Strike out whichever is not applicable**



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure -III

Page 1 of 2

PROFORMA OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (To be executed in non-judicial stamp paper of Rs. 100.00)

Ref.....

Bank Guarantee No.....

Date :

To

.....
.....
.....

West Bengal

Dear Sirs,

In consideration of West Bengal State Electricity Distribution Company Ltd., (herein after referred to as the "Owner" which expression shall unless repugnant to the context or meaning thereof include its successors, administrators and assigns) having awarded to M/s..... with registered/Head office at.....(hereinafter referred to as "Contractor" which expression shall unless repugnant to the context or meaning thereof include its successors, administrators, executors and assigns), a Contract issued by Owner's Letter of Award No... ..dated.. ..for..... ..(scope of work) and the same having been acknowledged by the Contractor, resulting in a Contract bearing No..... dated Contractor having agreed to provide a Contract Performance Guarantee for the faithful performance of the entire Contract equivalent to Rs..... being (3%) (Three Percent) of the said value of the Contract to the Owner.

We (Name & Address) having its Head Office at.....(hereinafter referred to as the "Bank", which expression shall, unless repugnant to the context or meaning thereof, include its successors, administrators, executors and assigns) do hereby guarantee and undertake to pay the Owner, on demand any or all monies payable by the Contractor to the extent of Rs. as aforesaid at any time up to.....* (day/month/year) without any demur, reservation; contest, recourse or protest and/or without any reference to this Contractor.

Any such demand made by the Owner on the bank shall be conclusive and binding notwithstanding any difference between the Owner and the Contractor or any dispute pending before any Court, Tribunal Arbitrator or any other authority. The Bank undertakes not to revoke this guarantee during its currency without previous consent of the Owner and further agrees that the guarantee herein contained shall continue to be enforceable till the Owner discharges this guarantee.

The Owner shall have the fullest liberty without affecting in any way the liability of the Bank under the guarantee from time to time to extend the time for performance or the Contract by the Contractor. The Owner shall have the fullest liberty, without affecting this guarantee, to postpone from time to time the exercise of any powers vested in them or of any right which they might have against the Contractor and to exercise the same at any time in any manner and either to enforce or to forbear to enforce any covenants, contained or implied in the Contract between the Owner and the Contractor or any other course or remedy or security available to the Owner. The Bank shall not be relieved of its obligations under these presents by any exercise by the Owner of its liberty with reference to the matters aforesaid or any of them or by reason of any other act of omission or commission on the part of the Owner or any other indulgences shown by the Owner or by any other matter or thing whatsoever which under law would, but for this provision have the effect of relieving the Bank.

The bank also agrees that the Owner at its option shall be entitled to enforce this guarantee against the Bank as a principal debtor, in the first instance without proceeding against the Contractor and notwithstanding any security or other guarantee the Owner may have in relation to the Contractor's liabilities.

Notwithstanding anything contained herein above our liability under this guarantee is restricted to Rs. and it shall remain in force upto and including*(day/month/ year) and shall be extended from time to time for such period as may be desired M/s.....on whose behalf this guarantee has been given.

Unless a demand or claim is lodged on us within and including*(day/month/year) we shall be discharged from all liabilities thereafter.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Page 2 of 2

Dated this.....day of.....20.....at.....

WITNESS

..... Signature)	 (Signature)
..... (Name)	 (Name)
..... (Official Address)	 (Official Address)
Attorney as per Power of Attorney No.	
Date.....	

*** Till 3 (three) months after the validity of the Bank Guarantee.**

**** Upto 3 (three) months after the expiry of warranty/guarantee period.**

Notes:

1. The stamp paper of appropriate value shall be purchased in the name of issuing bank. .
2. The sum shall be 03% (threepercent) of the Contract Price.The performance Bank Guarantee/Security Deposit Bank Guarantee shall be valid as per terms of contract. A period of three (3) months should be added as claimed period from the last date of validity of the Bank Guarantee.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-IV

PROFORMA OF BANK GUARANTEE FOR ADVANCE PAYMENT (To be executed In non-judicial stamp paper of Rs. 100.00)

Ref. Bank Guarantee No.

Date :

To

The

.....

.....

West Bengal

Dear Sir,

In consideration of West Bengal State Electricity Distribution Company Ltd., (hereinafter referred to as the "Owner", which expression shall unless repugnant to the context or meaning thereof include its successors, administrators and assigns) having awarded to M/s..... (hereinafter referred to* as the 'Contractor', which expression shall, unless repugnant to the context or meaning thereof, include its successors, administrators, executors and assigns), a Contract by issue of Owner's Letter of Award No.....dated..... and the same having been acknowledged by the Contractors, resulting in a Contract bearing No.....dated..... valued (at.....(in words and figures) for.....Contract (scope of work)..... (hereinafter called the "Contract") and the Owner having agreed to make an advance payment to the Contractor for performance of the above Contract amounting Rs..... (In words and figures) as an advance against Bank Guarantee to be furnished by the contractor. We..... (Name of the Bank) having its Head Office at..... (hereinafter referred to as the "Bank", which expression shall, unless repugnant to the context or meaning thereof, include its successors, administrators, executors and assigns) do hereby guarantee and undertake to pay the Owner, immediately on demand any or, all monies payable by the Contractor to the extent of Rs. as aforesaid at any time upto and including..... @ (day/month/year) without any demur, reservation, contest, recourse or protest and/or without any reference to the Contractor. Any such demand made by the Owner on the bank shall be conclusive and binding notwithstanding any difference between the Owner and the Contractor or any dispute pending before any Court, Tribunal Arbitrator or any other authority. We agree that the guarantee herein contained shall be irrevocable and shall continue to be enforceable till the Owner discharges this guarantee. We guarantee, to postpone from time to time the exercise of any powers vested in them or of any right which they might have against the Contractor, and to exercise the same at any time in any manner and either to enforce any covenants, contained or implied in the Contract between the Owner and the contractor or any other course or remedy or security available to Owner. The Bank shall not be relieved of its obligations under these presents by any exercise by the Owner of its liberty with reference to the matters aforesaid or any of them or by reason of any other act or forbearance or other acts of omission or commission on the part of the Owner or any other indulgence shown by the Owner or by any other matter or thing whatsoever which under law would be for this provision have the effect of relieving the Bank.

The Bank also agrees that the Owner at its option shall be entitled to enforce this guarantee against the Bank as a principal debtor, in the first instance without proceeding against the Contractor and notwithstanding any security or other guarantee that the Owner may have in relation to the Contractor's liabilities.

Notwithstanding anything contained herein above our liability under this guarantee is limited to Rs.and it shall remain in force upto and including.....(@.....) and shall be extended from time to time for such period as may be desired by M/s..... on whose behalf this guarantee has been given.

Dated this day of20.....at.....

WITNESS

.....
(Signature)

.....
(Signature)

.....
(Name)

.....
(Name)
Designation.....
(Official Address)
(with Bank Stamp)

Attorney as per Power
of Attorney No
Dated.....

@ The date will be Three (3) Months after the Scheduled date of completion of Supply (Supply Contract)/ Three (3) Months after taking over the work by WBSEDCL (Erection Contract).

Note: The non-judicial stamp papers of appropriate value shall be purchased in the name of bank who issued the Bank Guarantee.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-V

PROFORMA OF EXTENSION OF BANK GUARANTEE

Ref.

Date:

To

.....

.....

.....

West Bengal

Dear Sirs,

Sub: Extension of Bank Guarantee No..... for Rs..... favoring yourselves, expiring on..... on account of M/s..... in respect of Contract No.....doted (hereinafter called original Bank Guarantee).

At the request of M/s..... We.....Bank, branch office at..... and having its Head Office at do hereby extend our liability under the above mentioned Bank Guarantee No..... dated for a further period of.....(Years/Months] from..... to expire on..... Expect as provided above, all other terms and conditions of the original bank guarantee No.....dated..... shall remain unaltered and binding.

Please treat this as an Integral part of the original bank guarantee to which it would be attached.

Yours Faithfully,

For.....

Manager/Agent/Accountant.

Power of Attorney No.....

Dated.....

SEAL OF BANK

NOTE: The non-judicial stamp paper of appropriate value shall be purchased in the name of the bank who has issued the Bank Guarantee.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-VI

PROFORMA FOR EVIDENCE OF ACCESS TO OR AVAILABILITY OF CREDIT /FACILITIES (TO BE GIVEN BY BANKER OF BIDDER)

BANK CERTIFICATE

This is to certify that M/s. (FULL NAME AND ADDRESS) who are submitting their Bid toagainst their tender specification vide Ref. No..... and date..... is our customer for the past years.

Their financial transactions with our bank have been satisfactory. They enjoy the following fund based and non fund based limits including, guarantees, L/C and other credit facilities with us against which the extent of utilization as on date is also indicated below:

SI.No.	TYPE OF FACILITY	SANCTIONED ON DATE	UTILIZATION AS ON DATE

This letter is issued at the request of M/s.....

Sd/-

Name of Bank.....

Name of authorized Signatory.....

Designation

Phone No.....

Address.....

SEAL OF THE BANK



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-VII

BID PROPOSAL

Bidders Name & Address:

Bid Proposal Reference :

Person to be contacted:

Designation:

Telephone No.:

Fax :

To

The

Sub : Proposal for

Ref : Tender Notice no :

Dear Sirs,

1.0 We, the undersigned Bidder, have read and examined in detail the specifications and Bid documents of the above work and hereby propose to execute the work as detailed in specification and documents.

2.0 PRICES AND VALIDITY

2.1 Our prices stated in the bid are Firm/Variable*. Price adjustment is applicable /not applicable* in line with the bidding documents. Our quoted prices and other terms and conditions of this proposal are valid for a period of 120 days/180 days* after the date of opening of price bid. We further declare that prices stated in our Proposal are in accordance with your "Instruction to Bidders" included in Condition of Contracts of Bid documents.

2.2 We do hereby confirm that our bid prices as quoted in Quotation sheet includes all the taxes, duties and levies and confirm that any such taxes, duties and levies additionally payable shall be to our account. We further confirm that no tax & duties in any form shall be payable by the Owner except GST.

3.0 We have studied clause 25.1 & 25.2 of Section ITB relating to Tax and we hereby, declare that if any income-tax, surcharge on income-tax or any other corporate tax is attracted under the law, we agree to pay the same.

4.0 BID GUARANTEE

We have enclosed a Bid Guarantee, in the form of

(Please fill in alternative chosen)

for a sum of

(Amount in Words & Figures)

in original and two copies of the original, valid for a period of 30 days beyond the bid validity date, in accordance with documents, for packages as per the following details :

Form of Bid Guarantee	Value of Bid Guarantee	Valid upto and Including

We have also ensured that the above Bid guarantee furnished by us is in line with the Bid documents and complete in respect of following:

- Value of non judicial stamp paper purchased in the name of executing bank.
- Signature, foil name, designation and address of witness are there.
- Complete mailing address of the Head Office of the Bank is indicated.

5.0 BID PRICE

We declare that our total bid price in Indian Rupees is given in of Schedule submitted in Cover-II for the entire scope of work as specified in your Bidding Documents.

6.0 DEVIATIONS

6.1 We declare that the Works shall be performed strictly in accordance with the specifications and documents all of which have been detailed out exhaustively in the following Schedules (submitted in cover-II), irrespective of whatever has been stated to the contrary anywhere else in our proposal.

We confirm that specified stipulation of following Clauses are acceptable to us and no Deviation/exceptions are taken on any account, whatsoever in the following Clauses:

a)	Terms of Payment	Clause No. 21.0 of Section : IV (GCC)
b)	Bid Guarantee	Clause No. 8.0 of Section: III (ITB)
c)	Contract Performance Guarantee/Additional Performance Guarantee	Clause No. 5.0 of Section: IV (GCC)



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

d)	Liquidity Damages for Delay	Clause No. 27.0 of Section: IV (GCC)
e)	Bid Price basis	Clause No. 6.0 of Section: III (ITB)

7.0 **BID PRICING**

We further, declare that the prices stated in our Proposal are in accordance with your 'Instruction to Bidders¹ included in Conditions of Contract of Bid documents.

8.0 **PRICE BASIS**

We declare that our price components are on FIRM BASIS.

9.0 **CONTRACT PERFORMANCE GUARANTEE**

We further agree that if our proposal is accepted, we shall provide an irrevocable Contract Performance Guarantee, of value equivalent to 3% (Three percent) of the Contract Price valid upto the end of 3 (three) months after the end of the contract warranty period with a further claim period of 3 (three) months thereafter in the form of Bank Guarantee in your favour within 30 (thirty) days from the date of issue of Letter of Award and shall enter into a formal agreement with you within 30 (thirty) days from the Letter of Award.

10.0 **QUALITY PLANS:**

The contractor is responsible for the proper execution of work as per drawing. The work beyond the customer's hold points will progress only with the Owners consent. The Owner will also undertake quality surveillance and quality audit of the Contractor's/Sub contractor's works, systems and procedures and quality control activities. The Contractor farther agrees that any change in the Quality Plan will be made only with the Owner's approval. The Contractor shall also perform all quality control activities, inspection and tests agreed with the Owner to demonstrate full compliance with the contract requirements.

10.1 The Contractor also agrees to provide the Owner with the necessary facilities for carrying out inspection, quality audit and quality surveillance of Contractors and its Sub-Contractor's Quality Assurances System.

10.2 It is expressly agreed to by the contractor that the quality tests and inspection by the Owner shall not in any way relieve the Contractor of its responsibilities for quality standards, and performance guarantee and their other obligations under the Agreement.

10.3 If Is further agreed by the -Contractor that the contract performance guarantee shall in no way be constructed to limit or restrict the Owner's right to recover the damages/compensation due to poor workmanship or under any other clause of the Agreement. The amount of damages/compensation shall be recoverable either by way of deduction from the contract price, contract performance guarantee and or otherwise.

10.4 The contract performance guarantee furnished by the contractor is irrevocable and unconditional and the Owner shall have the powers to invoke it notwithstanding any dispute or difference between the owner and the contractor pending before any court, tribunal or any other authority.

10.5 This Agreement constitutes full and complete understanding between the parties and terms of the presents. It shall superseds and prior correspondence terms and conditions contained in the Agreement. Any modification of the Agreement shall be effected only by a written instrument signed by the authorized representative of both the parties.

11.0 **CHECKLIST**

We-have included a Check List duly filled in.

Dated this day of 20

Signature.....
of..... duly authorised to sign for and on behalf

.....
(IN BLOCK CAPITALS)

*Strike out the portion which is not applicable



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-VIII

SPECIMEN COPY OF INDEMNITY BOND

(To be executed on Non judicial Stamp Paper of a Rs.100/-)

BY THE PRESENT INDEMNITY BOND EXECUTED by me/us on thisDay of20..... I/We having Registered Office/residing at

..... (herein after called "OBLIGOR/ OBLIGORS" which expression shall mean and includes my/our successors legal representatives, assigns) do hereby binds myself /ourselves and also our company/firm

after having the power to bind so with the promise and undertaking in favour of the West Bengal State Electricity Distribution Company Limited a government company within the meaning of sec. 617 of the Company's Act, 1956 having registered office at BidyutBhavan, Block-DJ, Sector-II, Salt Lake City, Kolkata - 700091 (hereinafter called as OBLIGEE, which expression shall mean and include it's legal representative, administrators assigns.

Whereas OBLIGOR/OBLIGORS has/have been awarded to execute the job/works under letter no.....dated issued by the OBLIGEE after having observing necessary formalities, the details of which is described in the schedule given hereunder as per letter mentioned herein-above and whereas the said job/works will be/likely to be done in places covered under Employees' State Insurance Act (ESI) and/or the Employee Compensation Act, 1923 (W. C. Act) and/or other laws relating to the Labour Management and Welfare.

And whereas according to the condition of the contract the OBLIGOR/ OBLIGORS is/are under obligation to execute this Indemnity Bond before the commencement of actual execution and OBLIGOR/ OBLIGORS is/are aware that unless this Indemnity Bond is executed in accordance with the condition of contract before the actual execution in accordance with law the OBLIGEE shall have the power to deem that actual work has been started within the meaning of the contract before the execution of this Indemnity Bond.

Now this indenture witnesses that I/we the OBLIGOR/OBLIGORS do hereby undertake:-

1. THAT the OBLIGEE shall not be held responsible for any type of accident which may take place during the course of work undertaken by the OBLIGOR/OBLIGORS.
2. THAT the OBLIGOR/OBLIGORS will take/adopt all safety norms in respect of each and every workmen labour personnel according to the rules or to the satisfaction of the OBLIGEE in all cases.
3. THAT the OBLIGOR/OBLIGORS undertakes/undertake to engage only those labour worker or any other personnel whether skilled or unskilled or any other person whether in technical management or non-managerial or any other capacity in the area covered under Employee' State Insurance Act, 1948 who has/have insurance coverage within the meaning of Employees' State Insurance Act and further undertakes NOT to engage any person in the area covered under Employees State Insurance Act., who does / do not has / have insurance coverage within the meaning of Employees' State Insurance Act, 1948.
4. That the OBLIGOR/OBLIGORS further undertakes/undertake to engage only those labour, worker, or any other personnel, whether skilled or unskilled, whether in technical, managerial or non-managerial or any other capacity in the area NOT covered under Employees' State Insurance Act 1948, who has life insurance for the sum assured equivalent to the amount of Compensation under the Employees Compensation Act in case of accidental death or inquiry and such insurance has been effected by the OBLIGOR / OBLIGORS.
5. THAT the OBLIGOR/OBLIGORS undertakes/undertake to Indemnify and keep harmless the OBLIGEE from all claims, action, proceedings and of risk, damage, danger to any person whether belonging to/or not belonging to OBLIGOR / OBLIGORS.
6. THAT the OBLIGOR/OBLIGORS shall keep harmless the OBLIGEE from all claims, compensation, damages, any proceedings in respect of any of its employee/workmen under the Employee Compensation Act. Act or any other laws for the time being in force.
7. THAT, if during the course of execution of work as stated in the letter mentioned hereinabove issued by the OBLIGEE, it is found that the OBLIGOR/OBLIGORS has/have not complied with guidelines/formalities within the meaning of Employees' State Insurance Act or Employee Compensation Act or any other laws relating to the Labour Welfare for the time being in force, and also has not observed the safety norms in accordance with the law to the satisfaction of the OBLIGEE, the OBLIGEE shall have the right to stop the execution of work/job and the period of such stoppage shall continue till adequate safety and other compliance mentioned hereinabove under the labour welfare legislation have been observed and such period of stoppage shall not be taken into account for the calculation of the total period of completion of work for which the OBLIGOR/OBLIGORS is responsible to complete the work/job and it will be deemed that discontinuance was due to default of OBLIGOR/OBLIGORS.
8. THAT, if at any time, due to exigency, the OBLIGEE i.e. the West Bengal State. Electricity Distribution Company Limited as the Principal Employer, becomes liable to pay any such compensation mentioned hereinabove, whether on failure of the OBLIGOR/ OBLIGORS or for any other reason, the OBLIGEE shall have the right to recover the said amount from any amount receivable by OBLIGOR/OBLIGORS or any bank guarantee deposited or anything payable whether in connection with this contract or other contract by the OBLIGEE to the OBLIGOR/OBLIGORS.
9. THAT the OBLIGOR/OBLIGATOR is/are aware and accept that for the persistent or repeated violation of any condition mentioned in this Indemnity Bond, the OBLIGEE shall have right to terminate the contract of work issued by the OBLIGEE to OBLIGOR/OBLIGATOR.



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

SIGNED AND DELIVERED BY
THE OBLIGOR/OBLIGORS

.....
.....

Signature

WITNESS:

1) Name, Designation

.....
.....

Signature

2) Name, Designation

.....
.....

Signature



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-IX

PROFORMA OF AGREEMENT

(To be executed on Non judicial Stamp Paper of Rs.100/-)

ARTICLES OF AGREEMENT MADE thisday ofin the year between WEST BENGAL STATE ELECTRICITY DISTRIBUTION COMPANY LIMITED (WBSEDCL), a statutory body constituted by the Govt. of West Bengal having its Head Office at "VidyutBhavan", Block-DJ, Sector-II, Salt Lake City, Kolkata-700091, hereinafter referred to as the "Company" (which expression shall unless excluded by or repugnant to the context be deemed to include its successors and assigns) of the ONE PART.

AND

hereinafter referred to as the "Contractor" (which expression shall unless excluded by or repugnant to the context be deemed to include its heirs, executors, administrators, representatives and permitted assigns) of the OTHER PART.

WHEREAS the Company invited tender vide Tender Notice No..... (annexed hereto) for "....."

AND WHEREAS in pursuance of such invitation for tenders the Contractor submitted a tender vide no. dt..... the Techno-commercial part of which was opened on and the Price bid was opened on (the tender offer is in custody of the Company at present).

AND WHEREAS AFTER consideration of the tender submitted by the Contractor, with clarification(s), the Company accepted the said tender submitted by the Contractor and placed Letter of Award no.

NOW THEREFORE, The Company and the Contractor agree as follows:

1. The Contractor agrees to undertake the work of..... "as per Letter of Award no dt referred to above.
2. The Company agrees to pay the contractor as per the Letter of Award nodt..... referred to above.
3. Both the Contractor and the Company agree that for the purpose of jurisdiction of court in regard to any dispute arising out of this agreement, this agreement shall be deemed to have been executed within the jurisdiction of the original side of the High Court, Kolkata.

IN WITNESS WHEREOF the parties have hereunder affixed their signature, on the day, the month and year written as above.

SIGNED, SEALED AND DELIVERED

..... Contractor	 Company
..... Witness	 Witness
..... Witness	 Witness



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

ANNEXURE-X

DECLARATION BY THE TENDERER

I/We have inspected the site of work and have made myself/ourselves fully acquainted with local conditions in and around the site of work. I /We have carefully gone through the Notice Inviting Tender and other tender documents mentioned therein. I/We have also carefully gone through the 'Bill of Quantities'.

My/Our tender is offered taking due consideration of all factors regarding the local site conditions stated in this Detailed Notice Inviting Tender to complete the proposed construction in all respects.

I/We promise to abide by all the stipulations of the contract documents and carry out and complete the work to the satisfaction of the department.

I/We also agree to procure tools and plants, at my/our cost required for the work.

Signature of Tenderer

Dated:_____

Postal address of the Tenderer



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-XI

PROFORMA OF DECLARATION OF BLACK LISTING **HOLIDAY LISTING**

In the case of a Proprietary Concern:

I hereby declare that neither I in my personal name or in the name of my Proprietary concern M/s which is submitting the application for enlistment nor any other concern in which I am proprietor nor any partnership firm in which I am involved as a managing Partner have been placed on black list or holiday list declared by WBSEDCL, WBSETCL or any central/state power utility services, except as indicated below:

(Here give particulars of blacklisting or holiday listing, and in absence thereof state "NIL")

In the case of a Partnership Firm:

We hereby declare that neither we, M/s submitting the application for enlistment nor any partner involved in the management of the said firm either in his individual capacity or as proprietor or managing partner of any firm or concern have or has been placed on black list or holiday list declared by WBSEDCL, WBSETCL or any central/state power utility services except as indicated below:

(Here give particulars of blacklisting or holiday listing, and in absence thereof state "NIL")

In the case of a Company:

We hereby declare that we have not been placed on any holiday list or black list declared by WBSEDCL, WBSETCL or any central/state power utility services, except as indicated below:

(Here give particulars of blacklisting or holiday listing, and in absence thereof state "NIL")

It is understood that if this declaration is found to be false in any particular WBSEDCL, WBSETCL or is Administrative Ministry, shall have the right to reject my/our enlistment/bid and if the bid has resulted in a contract, the contract is liable to be terminated.

Signature with date & seal of the Bidder



West Bengal State Electricity Distribution Company Ltd.

(A Govt. of West Bengal Enterprise)

Annexure-XII

PROFORMA FOR ADDITIONAL PERFORMANCE GUARANTEE

File No. POW-13099/3/2018-SECTION(POWER)-Dept. of POWER

5

2021

(in words). We undertake to pay you, upon your first written demand and without cavil of argument, a sum within the limits of

(amount of guarantee) as aforesaid without your needing to prove or to show grounds or reasons for your demand for the sum specified therein.

We (indicate the name of the bank and branch) hereby waive the necessity of your demanding the said debt from the contractor before presenting us with the demand.

We (indicate the name of the bank and branch) further agree to pay to you any money so demanded notwithstanding any dispute or disputes raised by the contractor(s) in any suit or proceeding pending before any court or Tribunal.....the present absolute and unequivocal.

The payment so made by us under this bond shall be a valid discharge of our liability for payment there under and the contractor(s) shall have no claim against us for making such payment.

We (indicate the name of the bank and branch) further agree that no change or addition to or other modification of the terms of the Contract or of the works to be performed there under or of any of the Contract documents which may be made between you and the Contractor shall in any way release us from any liability under this guarantee, and we hereby waive notice of any such change, addition or modification.

We (indicate the name of the bank and branch) lastly undertake not to revoke this guarantee except with the previous consent of you in writing.

This Guarantee shall be valid upto..... It come into force with immediate effect and shall remain in force and valid for a period upto the time of completion of the work under the stated contract plus claim period of Six months for the Bank Guarantee. Notwithstanding anything mentioned above our liability against this guarantee is restricted to Rs..... (Rupees.....) and unless a claim in writing is lodged with us within the validity period i.e. upto.....of this guarantee all our liabilities under this guarantee shall cease to exist.

Signed and sealed this day of 2021..... at

SIGNED, SEALED AND DELIVERED

For and on behalf of the BANK

by:

(Signature)

(Name)



West Bengal State Electricity Distribution Company Ltd.

45/2021

File No.POW-13099/3/2018-SECTION(POWER)-Dept. of POWER

(Designation)

(Code Number)

(Address)

NOTES: (1) The bank guarantee should contain the name designation and code number of the officer(s) signing the guarantee

The address, telephone number and other details of the Head Office of the Bank as well as of issuing Branch should be mentioned on the covering letter of issuing Branch.