



WEST BENGAL STATE ELECTRICITY DISTRIBUTION CO. LTD.

(A Govt. of West Bengal Enterprise)

Office of the Chief Engineer : Procurement & Contracts Department

Vidyut Bhavan (4th Floor):: Block-DJ : Sector-II : Bidhannagar

WBSEDCL

Kolkata-700 091:: Phone No. 033-2359-8397:: Fax No. 033-2359-1921

CIN-U40109WB2007SGC113473/www.wbsedcl.in/materialcontroller@yahoo.co.in

Memo No. : P&C/P-20/Pre-Bid/106

Dated: 06/10/2020


Subject: MINUTES OF PRE-BID MEETING HELD ON 05/10/2020


Reference: Rate Contract for supply and delivery of Re-Wireable porcelain Cut-out Fuse Unit of different Ratings (16,32,63,100 Amp & 200,300,400,500 Amp) against Tender No. P-20/2020-21/PC-I/RC due on 03/11/2020 for Rate Contract for 2 (Two) years.


Pre-Bid discussion held in the conference room of P&C Dept. 4th Floor 'D' Block on 05/10/2020 at 11:30 hrs. for Rate Contract for supply and delivery of Re-wireable porcelain Cut-out Fuse Unit of different ratings (16, 32, 63, 100 Amp & 200,300,400,500 Amp) for Rate Contract for 2 (Two) years.

After elaborate discussion, the following issues are discussed & modified/corrected/added in Tender Specification:

| Sl. No. | Points of discussion |
|---------|--|
| 1. | Against page no. 20, clause no. 2.3 B under heading 'other plants & machinery', only four machines are required – i) Power/ Ball press, (ii) Drill Machine, (iii) Grinding Machine & iv) Shearing Machine. |
| 2. | Against page no. 20, clause no. 4 (i), IS will be <u>9926:1981</u> , in place of 9962:1981. |
| 3. | Against page no. 23, clause no. 16 Marking (i) (d), "Nature of Supply" <u>is not required</u> . |
| 4. | Against page no. 29, row 200 Amps. & 300Amps. of table on Dimensions of carrier and base, length "L" in respect of 200A and 300 A <u>will be 35 & 45mm respectively</u> in place of 31 & 41mm. |


05/10/2020


05/10/2020


05-10-2020