West Bengal State Electricity Distribution Company Limited

(A Govt. Of West Bengal Enterprise)

Purulia Pumped Storage Project

Bagmundi, Purulia-723152

Ph:-(03252) 250201, Fax:- (03252) 250202, Email:-ppspsite@yahoo.com

NOTICE INVITING TENDER

NIT NO. WBSEDCL/PPSP Site/ Procurement/ OPH/ Tender/22-23/ 127/810

Date: 08/11/2022

- West Bengal State Electricity Distribution Company Ltd. (WBSEDCL) invites sealed quotation for supply and delivery of different types of accessories i.r.o 7.5 MVA PTR & 6.3 MVA PTR at Purulia Pumped Storage Project Site, Bagmundi, Purulia
- Scope of Work: supply and delivery of different types of accessories i.r.o 7.5 MVA PTR & 6.3 MVA PTR at Purulia Pumped Storage Project Site, Bagmundi, Purulia, within the stipulated time period.
- 3) Quantity and Specification: Quantity and Description of different type of materials as mentioned in Annexure- I.
- 4) The Bidder shall submit offer duly signed and filled in with their letter head superscribing the **NIT No. Name** of the Tender and "Date & Time of opening of the Tender". The Bidder may submit their offer by post or by dropping their offer in Tender box at the office of the Addl. C.E & PSIC, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia, West Bengal.
- 5) Place and time of Submission of offer: The sealed offer will be received at the Office of The Addl.C.E & Project Site –In- Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia, West Bengal, during office hours on all working days except Saturday, Sunday and Holidays.
- 6) End time of submission of offer: Up to 11:00 hrs Dated 28.11.2022
- 7) Place, Date &Time for opening of Offer: The Office of the Addl.C.E & Project Site –In- Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia West Bengal on 28.11.2022 at 12:00 Hrs.
 - *Offers will be opened in presence of available Bidder's authorized representative.
- 8) Estimated Cost: Rs 46,135 (Rupees Forty Six Thousand One Hundred Thirty Five) only excluding GST
- 9) Availability of Copy of Tender:
 - a) WBSEDCL official Website: www.wbsedcl.in
 - b) Office of the Chief Engineer & Project Manager, PPSP HQ, WBSEDCL, Vidyut Bhavan, Salt Lake City, Kolkata, West Bengal PIN: 700091
 - Office of Addl. Chief Engineer & Project Site- in-Charge, PPSP Site, WBSEDCL, Bagmundi Dist: Purulia, West Bengal PIN: 723152
 - d) Contact Person, If any clarification is needed: Mr. D. Murmu, Divisional Engineer (Electrical), OPH, PPSP Site(Mob No:-8170043823)

Terms and Conditions:

YBSEDII

- I. Delivery Period: Within 25 (Twenty Five) days from the date of issuance of the order.
- II. Place of Delivery: The materials will be delivered at PPSP Site Store, WBSEDCL, Bagmundi, Purulia.
- III. **Price**: Price should be firm inclusive of all incidental charges. GST value and percentage to be written separately in quotation. However GST will be applicable as per law of land at the time of placement of order .STDS and GST to be deducted as per norms.
- IV. **Payment**: 100% Payment shall be made after successful delivery of Materials and sample checking. Materials will be received at site store through raising Store Receipt Voucher (SRV).Bill in triplicate along with challan in triplicate & advance Pre-Receipt copy must be given by the party with revenue stamp at the time of delivery of Materials. Payment will be made through R.T.G.S./N.E.F.T.(R.T.G.S / N.E.F.T charges to be borne by the Agency).

- V. Agency to provide Invoice with following details. (1) GSTIN, 2) Invoice No. of Supplier/ Service Provider, 3) Rate of Tax, 4) Taxable Value 5) IGST/ SGST/CGST, 6) Region code, 7) HSN/ SAC code, 8) Description as per HSN/ SAC code 9) Tax Invoice
- VI. FOR: PPSP Site, Bagmundi, Purulia
- VII. Packing & Forwarding: The Material should be duly packed taking all reasonable precaution to protect the materials against damage and loss during transit.
- VIII. Liquidate Damages: Liquidate damages for delay in Completion of work @1/2 % (half percent) of value of material for each week delay or part thereof up to ten(10) weeks and @1% of the order value per week or part thereof beyond ten (10) weeks subject to maximum limit of 10% (Ten percent) will be deducted from your bill.
- IX. Guarantee/Warranty: a) Original manufacturer guarantee/warranty or 12 months whichever is greater is to be provided for equipment and material. In case the supply materials are beyond our specification or found defective/damage /broken within declared Guarantee/Warranty period from the date of delivery of the item, the same should be replaced by you at your own cost and responsibility.
- X. PAN/GST NO: Bank Details with cancelled cheque is to be provided. GSTIN acknowledgement of registration is to be provided & STDS will be deducted as per norms.
- XI. Validity: The offer must remain valid for 120 days from the date of opening of the Tender.
- XII. Rejection: : WBSEDCL reserve the right to reject any or all offer at its own direction without assigning any reason whatsoever and do not blind itself to accept the lowest bidder.
- XIII. WBSEDCL reserves the right to accept or reject any or all offer at its discretion without assigning any reason whatsoever.
- XIV. Risk purchase clause & Force majeure: will be applicable as per norms of WBSEDCL.
- XV. Evaluation of Bid: Offer will be evaluated on lowest cumulative.
- XVI. In case of non compliance of the order by the L1 bidder necessary action will be taken as per norms of WBSEDCL. It may also leads to Holiday listing of L1 bidder.

Note:-*Any Offer submitted after the expiry of the time prescribed for submission or incomplete in any respect shall be rejected. Late receipt of Offer in case of postal delivery will not be considered. Offer by FAX/E-mail will not be accepted.

- Overwriting is not allowed.
- Quantity may be increased or decreased subject to discretion of WBSEDCL.

Was bridge to be a state of

(K.K.Maiti)
Addl.C.E & PSIC,
PPSP Site, WBSEDCL
Bagmundi, Purulia

Schedule of Matrials:

SI. No.	Item Description	Qty (in Nos.)	Unit Price Excl. GST (is Rs.)	GST %	Total Amount (in Rs.) including GST
1	MOG:				
	Model No. : SO-6 Dial Size- 150 MM				
2	PRV:				
	Model No T-3				1
	Size: 80 mm				1
	Tolerance: ± 1 PSI				
3	WTI:				
	Model No 1006				
	Temp. Range: 0°C to 150°C				
	No. Of switch: 2S				
	Capilary Length: 3Mtr.				
	Switch type: MS 5A				
	Dial Graduation: 2°C				
	Accuracy: ± 1.5 % of FSD				
	Switching Rating: 5 Amps continuous 250 V AC, 05		1		
	Amps @ 220 V DC for Make or Break				
	Switch Differential: 3°C Fixed			_	-
4	OTI:		3		
	Model No 1006				
	Temp. Range: 0°C to 150°C				
	No. Of switch: 25				
	Capillary Length: 3Mtr.				
	Switch type: MS 5A Dial Graduation: 2°C				
	Accuracy: ± 1.5 % of FSD Switching Rating: 5 Amps continuous 250 V. AC, 05				
	Amps @ 220 V DC for Make or Break				
	Switch Differential: 3°C Fixed				
	Grand Total Including GST	(in Rs.)			
1	<u> </u>	±9			

(K.K.Maiti) 17

Addl. C.E & PSIC,

PPSP Site, WBSEDCL

Bagmundi, Purulia