



West Bengal State Electricity Distribution Company Limited

(A Govt. Of West Bengal Enterprise)

Purulia Pumped Storage Project

Bagmundi, Purulia-723152

Ph:-(03252) 250201, Fax:- (03252) 250202, Email:-ppspsite@yahoo.com

NOTICE INVITING TENDER

NIT NO. WBSEDCL/PPSP Site/ Procurement/ OPH/ Tender/21-22/ 73/ 88

Date: 06.05.21

- 1) West Bengal State Electricity Distribution Company Ltd. (WBSEDCL) invites sealed quotation for the supply & delivery of **several electrical essentials** for Purulia Pumped Storage Project Site.
- 2) **Scope of Work:** Supply and delivery of **LED Street light, LED tube and Energy Efficient fan** for Purulia Pumped Storage Project Site, Bagmundi, Purulia, within the stipulated time period.
- 3) **Quantity and Specification:** Quantity of different types of LED Street light, LED tube and Energy Efficient as mentioned in **Annexure- I and there technical specifications as mentioned in Annexure - II**
- 4) The Bidder shall submit offer duly signed and filled in with their letter head superscribing the **NIT No. Name of the Tender and "Date & Time of opening of the Tender"**. The Bidder may submit their offer by post or by dropping their offer in Tender box at the office of the Addl. C.E & PSIC, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia, West Bengal.
- 5) **Place and time of Submission of offer:** The sealed offer will be received at the Office of the Addl.C.E & Project Site –In- Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia , West Bengal, during office hours on all working days except Saturday, Sunday and Holidays.
- 6) **End time of submission of offer:** Up to 12:00 hrs Dated 28.05.2021.
- 7) **Place, Date &Time for opening of Offer:** The Office of the Addl.C.E & Project Site –In- Charge, Purulia Pumped Storage Project Site, WBSEDCL, Bagmundi, Purulia West Bengal on 28.05 .2021 at 12:30 Hrs.

*Offers will be opened in presence of available Bidder's authorized representative.
- 8) **Estimated Cost:** Rs. 485685.00 (Rupees four lakh eighty five thousand six hundred eighty five) only excluding GST.
- 9) **Availability of Copy of Tender:-**
 - a) WBSEDCL official Website: www.wbsecl.in
 - b) Office of the Chief Engineer & Project Manager, PPSP HQ, WBSEDCL, Vidyut Bhavan, Salt Lake City, Kolkata, West Bengal PIN: 700091
 - c) Office of Addl. Chief Engineer & Project Site- in-Charge, PPSP Site, WBSEDCL, Bagmundi Dist: Purulia, West Bengal PIN: 723152
 - d) Contact Person, If any clarification is needed : Mr. D. Murmu, Divisional Engineer (Electrical), OPH, PPSP Site(Mob No:-8170043823)

Terms and Conditions:

- I. **Delivery Period:** Within 20 (Twenty) days from the date of issuance of the order.
- II. **Place of delivery:** The materials will be delivered at PPSP Site Store, WBSEDCL, Bagmundi, Purulia.
- III. **Price:** Price should be firm inclusive of all incidental charges. GST value and percentage to be written separately in quotation. However GST and STDS will be applicable as per law of land at the time of placement of order
- IV. **Delivery Charge:** Delivery charge will be borne by the Agency.
- V. **Payment:** 100% Payment will be made within 45 (Forty Five) Days after successful delivery of materials and sample checking. Materials will be received at site through raising Store Receipt

Voucher (SRV). Bills in triplicate along with challan in triplicate and advance pre-receipt copy with revenue stamp must be given by the Agency at time of delivery. In case of part delivery of materials payment will be made accordingly. Payment will be made through R.T.G.S/N.E.F.T (R.T.G.S/N.E.F.T charge to be borne by the Agency).

- VI. **Agency to provide Invoice with following details.** (1) GSTIN, 2) Invoice No. of Supplier/ Service Provider, 3) Rate of Tax, 4) Taxable Value 5) IGST/ SGST/CGST, 6) Region code, 7) HSN/ SAC code, 8) Description as per HSN/ SAC code 9) Tax Invoice
- VII. **FOR:** Bagmundi, Purulia
- VIII. **Packing & Forwarding:** The Material should be duly packed taking all reasonable precaution to protect the materials against damage and loss during transit.
- IX. **Liquidate Damages :** Liquidate damages for delay in delivery @1/2 % (half percent) of value of material for each week delay or part thereof upto ten(10) weeks and @1% of the order value per week or part thereof beyond ten (10) weeks subject to maximum limit of 10% (Ten percent) will be deducted from your bill.
- X. **Guarantee/Warranty:** Original manufacturer guarantee/warranty or 12 months whichever is greater is to be provided. In case the supply materials are beyond our specification or found defective/damage /broken within **declared Guarantee/Warranty period** from the date of delivery, the same should be replaced by you at your own cost and responsibility.
- XI. **PAN/GST NO. ,** Bank Details with cancelled cheque is to be provided. **GSTIN acknowledgement of registration** is to be provided
- XII. **Validity:** The offer must remain valid for **120 days** from the date of opening of the Tender.
- XIII. **WBSEDCL reserves the right** to accept or reject any or all offer at its discretion without assigning any reason whatsoever.
- XIV. **Risk purchase clause** will be applicable as per norms of WBSEDCL.
- XV. **Evaluation of bid:** Offer will be evaluated on cumulatively lowest offer after passing eligibility criteria.

Note:- * Any Offer submitted after the expiry of the time prescribed for submission or incomplete in any respect shall be rejected. Late receipt of Offer in case of postal delivery will not be considered. Offer by FAX/E-mail will not be accepted.

* **Overwriting is not allowed.**

* **Quantity may be increased or decreased subject to discretion of WBSEDCL.**

②
26/05/2017

Sd/
(A. Sarkar)
Addl.C.E & PSIC,
PPSP Site, WBSEDCL
Bagmundi, Purulia

Memo No. WBSEDCL/PPSP Site/ Procurement/ OPH/ Tender/21-22/ 73/ 88 (i-vi) Date: 06.05.21

Copy forwarded for information and necessary action to: -

- 1) The CE & PM, PPSP, WBSEDCL, Vidyut Bhavan, Kolkata-700 091.
- 2) The SE(E), OPH, PPSP Site, WBSEDCL, Bagmundi, Purulia -723 152.
- 3) The Manager (HR&A), PPSP Site, WBSEDCL, Bagmundi, Purulia - 723 152.
- 4) The Assistant Manager (HR&A), PPSP Site, WBSEDCL, Bagmundi, Purulia - 723 152.
- 5) The Jr. Manager (Stores), PPSP Site, WBSEDCL, Bagmundi, Purulia-723 152.
- 6) Notice Board.

A. Sarkar
06/5/2021
(A. Sarkar)

Addl.C.E & PSIC,
PPSP Site, WBSEDCL
Bagmundi, Purulia

@m...
06/05/2021

Annexure – I

0.: WBSEDCL/PPSP Site/ Procurement/ OPH/ Tender/21-22/ 73/

Dated :- 06.05.21

Supply and delivery of **LED Street light, LED tube and Energy Efficient fan** at Purulia Pumped Storage Project Site,
WBSEDCL Bagmundi, Purulia.

Sl no.	Description of Item	Make	HSN Code (8 Digit Code to be provided)	Qty.	Unit	Unit rate (Rs.)	GST per Unit (%)	GST per unit (Rs.)	Unit rate with GST (Rs.)	Total price including GST (Rs.)
1(a)	15 W LED Street light(As per Technical specificatio n TS-1)	Havells/ Philips/ Bajaj/ SIMOCO		220	Nos.					
1(b)	Installation kit for 15 Watt LED Street light as stated in 1(a)	-		220	Nos.					
2	20W LED Tube light (As per Technical specificatio n TS-2)	Havells/ Philips/ Bajaj/ SIMOCO		12	Nos.					
3	Energy Efficient Fan(As per Technical specificatio n TS-3)	orient/ havells/ CGL		15	Nos.					
Total price including GST considering 1(a)+1(b)+2+3										

*@m...
06/05/2021*

A. Sarkar
06/05/2021
(A. Sarkar)
Addl.C.E & PSIC,
PPSP Site, WBSEDCL
Bagmundi, Purulia

Annexure – II

O.: WBSEDCL/PPSP Site/ Procurement/ OPH/ Tender/21-22/

Dated :-

Technical specification for LED Street light - TS1

Intended use	Outdoor
Rate luminous flux	1500 lumen
Colour Temperature	6500 Kelvin
Colour	Cool white
Rated power	15 Watts
Nominal voltage	140 V AC – 270 V AC , 50HZ
Starting time	0.5 s
Street light installation kit	As per requirement

Technical specification for LED tube light fixtures – TS 2

Main Application	Indoor
System Lumen	1625 lm
Color	White
Color Rendering Index(CRI) (NOM)	≥ 80
Rated power consumption	20 W
Starting time	0.5 s
Power factor	≥ 0.95
Nominal voltage	140 V AC- 270 V AC , 50HZ

Technical specification for energy efficient fan – TS3

Certification BEE 5 star rating	Certification BEE 5 Star rating
sweep	1200 mm
Nominal input voltage at maximum speed and rated voltage	50 Watts at 230 V
Air delivery at rated voltage	≥ 210 cfm
Service value	≥ 4
Down rod length	300 mm

(Signature)
06/05/2021

(Signature)
06/05/2021

(A. Sarkar)
Addl.C.E & PSIC,
PPSP Site, WBSEDCL
Bagmundi, Purulia